

DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

**CUSTOMER NAME**: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

## **SUMMARY OF LABORATORY ANALYSIS**

NO. OF SAMPLES : 21 TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 04/17/2024-04/26/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC <sup>B</sup> (CFU/mL)
BRGY. BIÑAN					
04/11/2024 12:39	S24-1928	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN					
04/18/2024 12:18	S24-2141	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
04/18/2024 13:11	S24-2142	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
04/18/2024 12:32	S24-2145	Block 2 Lot 16, Phase 8 Southville	ABSENCE	ABSENCE	<1
04/18/2024 12:01	S24-2143	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
04/18/2024 10:42	S24-2138	Block 18 Lot 2, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
04/18/2024 10:04	S24-2137	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	<1
04/18/2024 10:26	S24-2144	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
04/18/2024 09:11	S24-2135	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1

**NOT VALID WITHOUT QR CODE** 

**REVIEWED BY:** 

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:** 

ANNA KARLA S. GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM <sup>A</sup>			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC <sup>B</sup> (CFU/mL)	
BRGY. TAGAPO						
04/17/2024 09:42	S24-1988	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1	
04/17/2024 10:12	S24-1990	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	74	
04/17/2024 10:32	S24-1998	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1	
04/17/2024 10:44	S24-1999	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	< 1	
04/17/2024 09:10	S24-1989	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1	
04/17/2024 09:32	S24-1991	Block 14 Lot 7 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1	
04/17/2024 11:41	S24-1992	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	140	
04/17/2024 11:49	S24-1993	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1	
04/17/2024 11:12	S24-1994	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	< 1	
04/22/2024 14:06	S24-2229	Sonyda, Robinson's Mall	ABSENCE	ABSENCE	< 1	
04/18/2024 12:28	S24-2133	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1	
04/18/2024 12:28	S24-2132	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

**LEGEND:** <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quantification; <u>NA</u> – Not Applicable ( - ) Not performed

**DEVIATIONS:** No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

**NOT VALID WITHOUT QR CODE** 

REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:** 

ANNA KARLA & GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

**CUSTOMER NAME**: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

## **SUMMARY OF LABORATORY ANALYSIS**

NO. OF SAMPLES : 40 TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 04/17/2024-04/25/2024

DATE/TIME COLLECTED		SAMPLE LOCATION	PARAMETER		
	SAMPLE CODE		COLIFORM <sup>A</sup>		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC <sup>B</sup> (CFU/mL)
BRGY. BIÑAN					
04/11/2024 12:39	S24-1928	Laguna Wellfield 1	ABSENCE	ABSENCE	<1
BRGY. BALIBAGO					•
04/18/2024 13:39	S24-2136	#4354 Facundo Compound	ABSENCE	ABSENCE	6
04/23/2024 12:07	S24-2258	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	<1
04/23/2024 12:27	S24-2264	Water Pump, South Hampton Residences	ABSENCE	ABSENCE	12
04/23/2024 10:43	S24-2253	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	<1
04/23/2024 10:30	S24-2254	2 <sup>nd</sup> Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	<1
04/18/2024 10:12	S24-2130	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	<1
BRGY. DILA					
04/18/2024 11:59	S24-2118	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	<1
04/18/2024 12:10	S24-2119	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	<1
04/18/2024 11:39	S24-2121	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	<1
04/18/2024 11:39	S24-2122	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	<1
04/23/2024 12:09	S24-2259	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	<1
04/18/2024 10:31	S24-2123	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	<1
BRGY. DITA				•	•
04/18/2024 10:41	S24-2124	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	<1
04/18/2024 09:05	S24-2126	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	<1
04/18/2024 09:18	S24-2127	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

**CERTIFIED CORRECT BY:** 

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336)

ANNA KARĹA Ś. ĠUŢſĒŖŖEZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM <sup>A</sup>			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC <sup>B</sup> (CFU/mL)	
04/18/2024 09:30	S24-2128	#1780, National Road	ABSENCE	ABSENCE	<1	
04/18/2024 10:22	S24-2134	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	<1	
04/23/2024 11:59	S24-2260	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	<1	
BRGY. DON JOSE						
04/17/2024 15:35	S24-2111	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	<1	
04/17/2024 14:56	S24-2110	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	<1	
04/17/2024 14:44	S24-2114	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	< 1	
04/17/2024 13:04	S24-2105	Clubhouse. Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	< 1	
04/17/2024 13:18	S24-2106	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	<1	
04/17/2024 13:29	S24-2107	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	<1	
04/17/2024 13:36	S24-2108	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	<1	
04/17/2024 14:21	S24-2115	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	<1	
BRGY. MACABLING	•					
04/17/2024 08:50	S24-2000	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	6	
04/17/2024 08:26	S24-1996	Water Pump, Corinthian Subdivision	ABSENCE	ABSENCE	<1	
04/17/2024 08:39	S24-1997	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	< 1	
BRGY. MALITLIT						
04/18/2024 09:59	S24-2129	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	<1	
04/25/2024 09:51	S24-2327	Clubhouse, Terra Fortuna	ABSENCE	ABSENCE	<1	
04/23/2024 11:01	S24-2261	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	13	
04/23/2024 11:24	S24-2262	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	<1	

NOT VALID WITHOUT QR CODE

**REVIEWED BY:** 

CERTIFIED CORRECT BY:

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) ANNA KARLAS. GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED		SAMPLE LOCATION TOTAL	PARAMETER		
			COLIFORM <sup>A</sup>		
	SAMPLE CODE		(Coliforms/	FECAL/ E. coli (Coliforms/ 100 mL)	HPC <sup>B</sup> (CFU/mL)
BRGY. POOC					
04/18/2024 11:26	S24-2139	Water Pump, Villa Mercedez	ABSENCE	ABSENCE	< 1
04/18/2024 11:38	S24-2140	Block 2 Lot 1, Villa Mercedez	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CR	UZ				
04/23/2024 13:16	S24-2255	Manzano Residence	ABSENCE	ABSENCE	< 1
04/23/2023 13:09	S24-2265	Water Pump	ABSENCE	ABSENCE	<1
04/23/2024 12:52	S24-2257	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	<1
04/23/2024 12:43	S24-2256	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	<1
BRGY. SANTO DOMINGO	0				
04/17/2024 13:46	S24-2109	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	<1
04/17/2024 14:03	S24-2116	Water Pump	ABSENCE	ABSENCE	<1
04/17/2024 14:00	S24-2117	Tope Residence	ABSENCE	ABSENCE	<1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

**LEGEND:** <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quanitification; <u>NA</u> – Not Applicable ( - ) Not performed

**DEVIATIONS:** No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

**NOT VALID WITHOUT QR CODE** 

REVIEWED BY:

**CERTIFIED CORRECT BY:** 

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager License No(s). (PRC 0090336) ANNA KARLAS. GUTHERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis.