

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY :	BIÑAN	MONTH :	JULY	YEAR :	2016
DOH ACCREDITATION NO :	04A-010-16-LW-2	VALIDITY :	December 31, 2018		

NO	SAMPLE LOCATION ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BIÑAN							
1	Laguna Well Field 1	Source	7/26/2016	5:00 PM	<1	ABSENCE	ABSENCE
2	Pump 6, Santol St., Phase 4C, San Jose Village I	Source	7/4/2016	12:16 PM	-	ABSENCE	ABSENCE
3	Blk 3 Lot 28, Santol st., Phase 4C, San Jose Village I	Distribution	7/4/2016	12:24 PM	35	ABSENCE	ABSENCE
4	Pump 2, Jacana St., Phase 3B, San Jose Village I	Source	7/4/2016	11:38 AM	-	ABSENCE	ABSENCE
5	Blk 2 Lot 18, Jacana St., Phase 3B, San Jose Village I	Distribution	7/4/2016	11:54 AM	23	ABSENCE	ABSENCE
6	Pump 11, Phase 5, San Jose Village II	Source	7/4/2016	10:19 AM	-	ABSENCE	ABSENCE
7	Blk 1 Lot 23, Camia St., Phase 5, San Jose Village II	Distribution	7/4/2016	10:45 AM	2	ABSENCE	ABSENCE
8	Clubhouse, Phase 6, San Jose Village III	Distribution	7/4/2016	11:18 AM	-	ABSENCE	ABSENCE
BRGY. CANLALAY							
9	#132 A. Bonifacio St.	Distribution	7/13/2016	11:28 AM	180	ABSENCE	ABSENCE
10	Golden City Canlalay Clubhouse	Distribution	7/11/2016	1:51 PM	-	ABSENCE	ABSENCE
11	Drinking Fountain, Canlalay Elementary School	Distribution	7/11/2016	2:10 PM	-	ABSENCE	ABSENCE
BRGY. DELA PAZ							
12	9028 WP GP Sta. Bernardina St. Kapitana Dela Paz	Source	7/13/2016	10:55 AM	-	ABSENCE	ABSENCE
13	Barangay Hall	Distribution	7/13/2016	11:14 AM	1	ABSENCE	ABSENCE
14	Drinking Fountain, Dela Paz Elementary School	Distribution	7/13/2016	12:00 NN	-	ABSENCE	ABSENCE
BRGY. GANADO							
15	Drinking Fountain, Ganado Elementary School	Distribution	7/14/2016	9:16 AM	-	ABSENCE	ABSENCE
BRGY. HALANG							
16	9999 WP Metroville Complex	Source	7/11/2016	2:32 PM	33	ABSENCE	ABSENCE
17	Clubhouse, Metroville Complex	Distribution	7/11/2016	2:48 PM	-	ABSENCE	ABSENCE
BRGY. LANGKIWA							
18	Block 3 Lot 9 Phase 2, Southville Langkiwa	Distribution	7/26/2016	12:12 PM	-	ABSENCE	ABSENCE
19	Block 65 Lot 5 Phase 1, Southville Langkiwa	Distribution	7/26/2016	12:22 PM	16	ABSENCE	ABSENCE
20	Block 20 Lot 7 Phase 3, Southville Langkiwa	Distribution	7/26/2016	12:32 PM	-	ABSENCE	ABSENCE
21	Block 21 Lot 8 Phase 2, Southville Langkiwa	Distribution	7/26/2016	12:04 PM	51	ABSENCE	ABSENCE
22	Block 17 Lot 27 Phase 4, Southville Langkiwa	Distribution	7/26/2016	12:45 PM	-	ABSENCE	ABSENCE
23	Block 31 Lot 27, Phase 3, Southville Langkiwa	Distribution	7/26/2016	12:58 PM	8	ABSENCE	ABSENCE
24	Drinking Fountain, Langkiwa Elementary School	Distribution	7/26/2016	11:52 AM	-	ABSENCE	ABSENCE
BRGY. LOMA							
25	Block 2 Lot 16, Phase 1, Laguna Bel-Air 3	Source	7/4/2016	12:06 PM	56	ABSENCE	ABSENCE
26	Hillcrest Road, Block 2, Laguna Bel-Air 3	Distribution	7/4/2016	2:32 PM	-	ABSENCE	ABSENCE
27	4NR Block 99, Phase 4, Laguna Bel-Air 3	Source	7/4/2016	11:20 AM	3	ABSENCE	ABSENCE
28	Brenna Model House, Phase 1, Laguna Bel-Air 3	Distribution	7/25/2016	3:55 PM	-	ABSENCE	ABSENCE
29	Block 50, Phase 2, Laguna Bel-Air 3	Source	7/4/2016	11:39 AM	30	ABSENCE	ABSENCE
30	Block 61 Lot 20, Laguna Bel-Air 3	Distribution	7/4/2016	11:45 AM	-	ABSENCE	ABSENCE
31	Drinking Fountain, Loma Elementary School	Distribution	7/26/2016	1:34 PM	60	ABSENCE	ABSENCE
BRGY. MALAMIG							
32	Block 5 Lot 16	Distribution	7/26/2016	1:18 PM	-	ABSENCE	ABSENCE
BRGY. MAMPLASAN							
33	Tank, Verdana Homes Subdivision	Source	7/26/2016	10:22 AM	-	ABSENCE	ABSENCE
34	Clubhouse, Verdana Homes Subdivision	Distribution	7/26/2016	10:12 AM	-	ABSENCE	ABSENCE
BRGY. POBLACION							
35	9018 WP Public Market 4024 Town Proper	Source	7/13/2016	10:31 AM	-	ABSENCE	ABSENCE

BRGY. PLATERO							
36	Drinking Fountain, St. Michael School of Biñan	Distribution	7/13/2016	8:49 AM	13	ABSENCE	ABSENCE
37	Sea-oil, National Road	Distribution	7/13/2016	9:11 AM	-	ABSENCE	ABSENCE
BRGY. SAN ANTONIO							
38	9022 Water Pump (WP) Faraon Subdivision	Source	7/18/2016	1:34 PM	-	ABSENCE	ABSENCE
39	Block 5 Lot 12, Margarita Homes Subdivision	Distribution	7/13/2016	9:27 AM	98	ABSENCE	ABSENCE
40	Drinking Fountain 1, Faraon Elementary School	Distribution	7/13/2016	10:12 AM	-	ABSENCE	ABSENCE
41	Cistern Tank, Pavillion Mall	Distribution	7/21/2016	3:38 PM	<1	ABSENCE	ABSENCE
42	Jollibee, Pavillion Mall	Distribution	7/21/2016	3:48 PM	-	ABSENCE	ABSENCE
BRGY. SANTO NIÑO							
43	Jollibee National Hi-Way	Distribution	7/21/2016	3:25 PM	<1	ABSENCE	ABSENCE
BRGY. SAN VICENTE							
44	9001 GP San Vicente	Source	7/14/2016	1:06 PM	<1	ABSENCE	ABSENCE
45	B8 L6, Bayabas St., Olivarez 7	Distribution	7/14/2016	11:06 AM	-	ABSENCE	ABSENCE
46	Cistern Tank, Central Mall	Distribution	7/21/2016	3:11 PM	<1	ABSENCE	ABSENCE
47	Drinking Fountain, San Vicente Elementary Sch.	Distribution	7/11/2016	9:30 AM	11	ABSENCE	ABSENCE
BRGY. SANTO TOMAS							
48	Phase 2, Adelina Complex III Subdivision	Source	7/14/2016	1:30 PM	<1	ABSENCE	ABSENCE
49	Gate Entrance, Adelina Complex III Subdivision	Distribution	7/14/2016	1:41 PM	-	ABSENCE	ABSENCE
50	1 LT Water Pump, Phase 1B, Olivarez Homes South	Source	7/11/2016	11:36 AM	14	ABSENCE	ABSENCE
51	Block 1 Lot 26, Phase 3, Olivarez Homes South	Distribution	7/11/2016	2:31 PM	-	ABSENCE	ABSENCE
52	5555 Block 1, Phase 4, Olivarez Homes South	Source	7/11/2016	11:08 AM	<1	ABSENCE	ABSENCE
53	Block 2 of 9, Phase 4, Olivarez Homes South	Distribution	7/18/2016	11:18 AM	-	ABSENCE	ABSENCE
54	Pump House, Kalibo St., South City Homes	Source	7/14/2016	10:37 AM	<1	ABSENCE	ABSENCE
55	Block 76 Lot 6, Tangub St., Pragmatic	Distribution	7/14/2016	10:44 AM	-	ABSENCE	ABSENCE
56	Pump, South Plains II Subdivision	Source	7/14/2016	10:19 AM	<1	ABSENCE	ABSENCE
57	Block 11 Lot 2, South Plains II Subdivision	Distribution	7/14/2016	10:24 AM	-	ABSENCE	ABSENCE
58	Pump, Amsterdam St., Phase 2, Town & Country	Source	7/18/2016	11:09 AM	150	ABSENCE	ABSENCE
59	Block 35 Lot 21, Town & Country	Distribution	7/14/2016	2:10 PM	-	ABSENCE	ABSENCE
60	Block 2 Lot 5, Town & Country	Distribution	7/11/2016	10:49 AM	<1	ABSENCE	ABSENCE
BRGY. SORO - SORO							
61	9067 Soro-soro	Source	7/11/2016	3:17 PM	15	ABSENCE	ABSENCE
62	#76 Soro-Soro	Distribution	7/11/2016	3:05 PM	-	ABSENCE	ABSENCE
BRGY. TUBIGAN							
63	#60 Forinda Compound	Distribution	7/11/2016	3:30 PM	-	ABSENCE	ABSENCE
BRGY. ZAPOTE							
64	Water Pump, Althea	Source	7/18/2016	12:56 PM	240	ABSENCE	ABSENCE
65	Model House, Block 6, Althea	Distribution	7/18/2016	1:13 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		65	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007

: ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

DATE/TIME

8/8/2016 8:00 AM

CERTIFIED CORRECT



AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

8/08/16

8:40 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : SANTA ROSA	MONTH : JULY	YEAR : 2016
DOH ACCREDITATION NO. : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BALIBAGO							
1	#1354 Facundo Compound	Distribution	7/18/2016	2:29 PM	-	ABSENCE	ABSENCE
2	5555 Water Pump Elevated, South Hampton	Source	7/25/2016	3:03 PM	<1	ABSENCE	ABSENCE
3	Block 1 Lot 5, South Hampton	Distribution	7/25/2016	3:10 PM	-	ABSENCE	ABSENCE
4	Block 11 Lot 2, JB Village, Sta. Rosa Tagaytay Road	Distribution	7/14/2016	2:05 PM	<1	ABSENCE	ABSENCE
5	Cistern Tank, Waltermart Sta. Rosa	Distribution	7/21/2016	6:08 PM	-	ABSENCE	ABSENCE
6	3rd Floor Faucet, Waltermart Sta. Rosa	Distribution	7/21/2016	5:56 PM	<1	ABSENCE	ABSENCE
BRGY. CAINGIN							
7	9002 Block 53, Phase 4, Southville	Source	7/12/2016	10:02 AM	<1	ABSENCE	ABSENCE
8	Block 52 Lot 23, Phase 1, Southville	Distribution	7/12/2016	10:09 AM	-	ABSENCE	ABSENCE
BRGY. DILA							
9	Phase 3E, Mabuhay Homes 2000	Source	7/12/2016	11:51 AM	13	ABSENCE	ABSENCE
10	Block 2 Lot 10, Mabuhay Homes 2000	Distribution	7/12/2016	12:02 PM	-	ABSENCE	ABSENCE
11	Block 12, Phase 2E, Mabuhay Homes 2000	Source	7/12/2016	10:54 AM	1	ABSENCE	ABSENCE
12	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	Distribution	7/21/2016	1:11 PM	-	ABSENCE	ABSENCE
13	Drinking Fountain, Dila Elementary School	Distribution	7/21/2016	1:43 PM	-	ABSENCE	ABSENCE
BRGY. DITA							
14	Block 24 Lot 2, New Santa Rosa Homes	Source	7/21/2016	12:49 PM	310	ABSENCE	ABSENCE
15	Block 19 Lot 11, New Santa Rosa Homes	Distribution	7/21/2016	1:02 PM	-	ABSENCE	ABSENCE
16	Block 4 Lot 32, San Lorenzo Royale	Source	7/25/2016	12:43 PM	28	ABSENCE	ABSENCE
17	Block 11 Lot 52, San Lorenzo Royale	Distribution	7/25/2016	12:53 PM	-	ABSENCE	ABSENCE
18	Water Tank, SolCar Ville Subdivision	Source	7/12/2016	12:45 PM	<1	ABSENCE	ABSENCE
19	Block 3 Lot 7, SolCar Ville Subdivision	Distribution	7/12/2016	12:54 PM	-	ABSENCE	ABSENCE
20	Water Tank, Villa Esmeralda	Source	7/25/2016	1:25 PM	1	ABSENCE	ABSENCE
21	Alabaster St., Villa Esmeralda	Distribution	7/25/2016	1:08 PM	-	ABSENCE	ABSENCE
22	#1780 National Road	Distribution	7/19/2016	1:26 PM	<1	ABSENCE	ABSENCE
23	Lima Express Ice Plant, Inc.	Distribution	7/21/2016	5:18 PM	<1	ABSENCE	ABSENCE
BRGY. DON JOSE							
24	Block 7 Lot 62, Phase 3, Laguna Bel-Air	Source	7/4/2016	10:46 AM	-	ABSENCE	ABSENCE
25	Science HighSchool, Phase 1, Laguna Bel-Air	Distribution	7/4/2016	12:20 PM	2	ABSENCE	ABSENCE
26	Block 34 Lot 14, Phase 1, Laguna Bel-Air	Source	7/4/2016	10:59 AM	-	ABSENCE	ABSENCE
27	Block 34 Lot 59, Phase 1, Laguna Bel-Air	Distribution	7/4/2016	11:07 AM	<1	ABSENCE	ABSENCE
28	Clubhouse, Block 62, Laguna Bel-Air	Distribution	7/4/2016	12:27 PM	-	ABSENCE	ABSENCE
29	Water Pump, Block 71, Phase 4, Laguna Bel-Air	Source	7/4/2016	12:39 PM	17	ABSENCE	ABSENCE
30	Block 71 Lot 4, Phase 2, Laguna Bel-Air	Distribution	7/4/2016	12:45 PM	-	ABSENCE	ABSENCE
31	Block 108, Phase 5, Laguna Bel-Air	Source	7/4/2016	1:07 PM	10	ABSENCE	ABSENCE
32	Church, Block 108, Phase 2, Laguna Bel-Air	Distribution	7/4/2016	1:14 PM	-	ABSENCE	ABSENCE
33	1NR Block 43, Laguna Bel-Air IV	Source	7/4/2016	10:23 AM	<1	ABSENCE	ABSENCE
34	Block 47 Lot 12 Laguna Bel-Air IV	Distribution	7/4/2016	10:31 AM	-	ABSENCE	ABSENCE
35	8001, Pump 1, Acacia St., Santa Rosa Village I	Source	7/4/2016	1:02 PM	-	ABSENCE	ABSENCE
36	Clubhouse., Santa Rosa Village I	Distribution	7/4/2016	1:13 PM	<1	ABSENCE	ABSENCE
37	Pump 9 & 10, Rembrandt St., Santa Rosa Estates I	Source	7/4/2016	9:58 AM	7	ABSENCE	ABSENCE
38	101 Elde France St., Phase 4A, Santa Rosa Village II	Distribution	7/4/2016	10:57 AM	<1	ABSENCE	ABSENCE
39	Clubhouse, Santa Rosa Estates I	Distribution	7/4/2016	10:07 AM	-	ABSENCE	ABSENCE
40	Reservoir, Hacienda Sta. Elena	Distribution	7/25/2016	11:58 AM	<1	ABSENCE	ABSENCE

BRGY. KANLURAN							
41	Malusak Bakery, #621 Rizal Boulevard	Distribution	7/19/2016	11:45 AM	-	ABSENCE	ABSENCE
BRGY. MACABLING							
42	Deepwell, Buena Rosa 9 Subdivision	Source	7/14/2016	9:24 AM	<1	ABSENCE	ABSENCE
43	Block 3 Lot 1, Phase 2, Buena Rosa 9 Subdivision	Distribution	7/14/2016	9:37 AM	-	ABSENCE	ABSENCE
44	Deepwell, Corinthian Subdivision	Source	7/14/2016	8:35 AM	<1	ABSENCE	ABSENCE
45	Guardhouse, Corinthian Subdivision	Distribution	7/14/2016	8:46 AM	-	ABSENCE	ABSENCE
46	Deepwell, Rosemont Subdivision	Source	7/14/2016	9:49 AM	150	ABSENCE	ABSENCE
47	Block 3 Lot 22, Rosemont Subdivision	Distribution	7/18/2016	2:05 PM	-	ABSENCE	ABSENCE
48	Block 4 Lot 3, Rosa Subdivision	Distribution	7/14/2016	8:07 AM	-	ABSENCE	ABSENCE
BRGY. MALITLIT							
49	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	Source	7/25/2016	1:52 PM	1	ABSENCE	ABSENCE
50	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	Distribution	7/25/2016	1:45 PM	-	ABSENCE	ABSENCE
51	Main Road, Phase 2, Terra Fortuna	Source	7/25/2016	2:38 PM	<1	ABSENCE	ABSENCE
52	Block 11 Lot 16, Terra Fortuna	Distribution	7/25/2016	2:49 PM	-	ABSENCE	ABSENCE
53	9999 W, Villa Las Casas	Source	7/25/2016	2:02 PM	<1	ABSENCE	ABSENCE
54	Block 1 Lot 17, Villa Las Casas	Distribution	7/25/2016	2:13 PM	-	ABSENCE	ABSENCE
BRGY. MALUSAK							
55	Drinking Fountain 1, Central 1 Elementary Sch.	Distribution	7/19/2016	11:12 AM	-	ABSENCE	ABSENCE
56	Drinking Fountain 2, Central 1 Elementary Sch.	Distribution	7/19/2016	11:26 AM	-	ABSENCE	ABSENCE
57	Drinking Fountain 3, Central 1 Elementary Sch.	Distribution	7/19/2016	11:20 AM	<1	ABSENCE	ABSENCE
BRGY. MARKET AREA							
58	Source, Market Area	Source	7/19/2016	10:18 AM	-	ABSENCE	ABSENCE
59	Block 9 Lot 2, Terry Town West	Distribution	7/19/2016	10:48 AM	<1	ABSENCE	ABSENCE
BRGY. POOC							
60	Deepwell, Alinsod	Source	7/12/2016	8:54 AM	<1	ABSENCE	ABSENCE
61	9999 Water Pump, Phase 5, Southville	Source	7/12/2016	9:38 AM	<1	ABSENCE	ABSENCE
62	Block 46 Lot 2, Phase 2, Southville	Distribution	7/12/2016	9:52 AM	-	ABSENCE	ABSENCE
BRGY. PULONG SANTA CRUZ							
63	Water Pump, Pulong Sta. Cruz	Source	7/21/2016	3:28 PM	<1	ABSENCE	ABSENCE
64	Block 7 Lot 3, Mercado Village	Distribution	7/25/2016	1:18 PM	-	ABSENCE	ABSENCE
65	Block 6 Lot 8, Buklod Diwa	Distribution	7/25/2016	12:23 PM	<1	ABSENCE	ABSENCE
BRGY. SINALHAN							
66	Block 6 Lot 8, Phase 3, Bayshore I	Distribution	7/21/2016	2:34 PM	-	ABSENCE	ABSENCE
67	Block 9 Lot 14, Bristol Bay St., Bayshore II	Distribution	7/19/2016	9:49 AM	10	ABSENCE	ABSENCE
68	4026, Sinalhan Road, Purok 2	Source	7/21/2016	2:10 PM	-	ABSENCE	ABSENCE
69	Amoranto Compound, Phase 2, Sinalhan	Distribution	7/21/2016	2:21 PM	-	ABSENCE	ABSENCE
BRGY. STO. DOMINGO							
70	Laguna Water Head Office, One Evotech Bldg.	Distribution	7/25/2016	4:00 PM	<1	ABSENCE	ABSENCE
71	Clubhouse Santa Rosa Estates II	Distribution	7/4/2016	10:21 AM	-	ABSENCE	ABSENCE
BRGY. TAGAPO							
72	Water Pump, Metrogate	Source	7/14/2016	1:25 PM	<1	ABSENCE	ABSENCE
73	Water Pump, Rosewood Homes I	Source	7/14/2016	11:46 AM	<1	ABSENCE	ABSENCE
74	Block 1 Lot 16, Rosewood Homes I	Distribution	7/14/2016	12:30 PM	-	ABSENCE	ABSENCE
75	Block 4 Lot 8, Rosewood Homes II	Distribution	7/14/2016	12:47 PM	1	ABSENCE	ABSENCE
76	#31 JP Rizal Boulevard	Distribution	7/14/2016	12:59 PM	-	ABSENCE	ABSENCE
77	Water Pump, Buena Rosa 1 Subdivision	Source	7/14/2016	10:52 AM	-	ABSENCE	ABSENCE
78	Guardhouse, Buena Rosa 1 Subdivision	Distribution	7/14/2016	11:06 AM	1	ABSENCE	ABSENCE
79	Cistern Tank, SM Sta. Rosa	Distribution	7/21/2016	4:40 PM	-	ABSENCE	ABSENCE
80	Crepes Delicious, SM Sta. Rosa	Distribution	7/21/2016	4:49 PM	<1	ABSENCE	ABSENCE
81	Cistern Tank, Robinson's Mall	Distribution	7/21/2016	4:09 PM	-	ABSENCE	ABSENCE
82	Chummie Shawarma, Robinson's Mall	Distribution	7/21/2016	4:18 PM	<1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		82	2007 PNSDW LIMIT ³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007

: ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

DATE/TIME

8/8/2016 8:00Am

CERTIFIED CORRECT



AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

8/08/16 8:40a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : CABUYAO	MONTH : JULY	YEAR : 2016
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BANAY-BANAY							
1	Water Pump, Block 63, Lakeside Nest Subdivision	Source	7/12/2016	12:12 PM	-	ABSENCE	ABSENCE
2	Block 12 Lot 15, Lakeside Nest Subdivision	Distribution	7/12/2016	12:29 PM	<1	ABSENCE	ABSENCE
BRGY. BIGAA							
3	#253 Elsol Subdivision	Distribution	7/21/2016	1:00 PM	<1	ABSENCE	ABSENCE
BRGY. CASILE							
4	Matang Tubig Spring	Source	7/26/2016	10:00 PM	<1	ABSENCE	ABSENCE
BRGY. GULOD							
5	Block 12, Noah St., Celestine Ville	Source	7/11/2016	1:53 PM	-	ABSENCE	ABSENCE
6	Guardhouse, Celestine Ville Ave., Celestine Ville	Distribution	7/11/2016	2:01 PM	27	ABSENCE	ABSENCE
BRGY. MAMATID							
7	Tank, Buena Rosario Subdivision	Source	7/11/2016	12:48 PM	-	ABSENCE	ABSENCE
8	Block 7 Lot 6, Buena Rosario Subdivision	Distribution	7/11/2016	12:58 PM	<1	ABSENCE	ABSENCE
9	Block 101 Samar st., Phase 2, Mabuhay City	Source	7/11/2016	1:27 PM	-	ABSENCE	ABSENCE
10	Block 95 Lot 57, Guimaras St., Phase 1, Mabuhay City	Distribution	7/11/2016	1:18 PM	9	ABSENCE	ABSENCE
11	Block 141, Carmona St., Phase 2, Mabuhay City	Source	7/11/2016	1:39 PM	-	ABSENCE	ABSENCE
12	Block 4 Lot 22, Phase 2, Mabuhay City	Distribution	7/11/2016	1:46 PM	<1	ABSENCE	ABSENCE
13	Block 198, Galacia St., Phase 2, Mabuhay City	Source	7/11/2016	12:19 PM	-	ABSENCE	ABSENCE
14	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	Distribution	7/11/2016	12:28 PM	<1	ABSENCE	ABSENCE
15	Panganig St., Phase 3 Cluster, Mabuhay City	Source	7/12/2016	10:50 AM	-	ABSENCE	ABSENCE
16	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	Distribution	7/12/2016	11:10 AM	<1	ABSENCE	ABSENCE
17	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	Source	7/12/2016	11:28 AM	-	ABSENCE	ABSENCE
18	Block 19 Lot 13, Malang St., Phase 3 Luxury, Mabuhay	Distribution	7/12/2016	11:43 AM	<1	ABSENCE	ABSENCE
19	Joshua St., Phase 5, Mabuhay City	Source	7/12/2016	9:57 AM	-	ABSENCE	ABSENCE
20	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	Distribution	7/12/2016	10:08 AM	10	ABSENCE	ABSENCE
BRGY. MARINIG							
21	Block 3 Lot 17, Phase 1, Celestine Homes	Source	7/19/2016	11:00 AM	-	ABSENCE	ABSENCE
22	Block 23, Lot 10, Phase 1, Celestine Homes	Distribution	7/19/2016	11:11 AM	6	ABSENCE	ABSENCE
23	Block 9, Carnation St., Phase 2, Celestine Homes	Source	7/19/2016	10:24 AM	-	ABSENCE	ABSENCE
24	Block 11 Lot 9, Phase 2, Celestine Homes	Distribution	7/19/2016	10:44 AM	<1	ABSENCE	ABSENCE
25	Block 25, Phase 3, Southville	Source	7/19/2016	11:25 AM	-	ABSENCE	ABSENCE
26	Block 19 Lot 33, Phase 3, Southville	Distribution	7/19/2016	11:36 AM	<1	ABSENCE	ABSENCE
BRGY. NIUGAN							
27	Water Pump, Niugan Elementary School Compound	Source	7/21/2016	12:25 PM	-	ABSENCE	ABSENCE
28	Patricia's Apartment, St. Francis 7	Distribution	7/21/2016	12:11 PM	<1	ABSENCE	ABSENCE
29	Block 45, Phase 8, Southville	Source	7/19/2016	12:16 PM	-	ABSENCE	ABSENCE
30	Block 43 Lot 99, Southville	Distribution	7/19/2016	11:57 AM	<1	ABSENCE	ABSENCE
31	Block 54, Phase 10, Southville	Source	7/12/2016	12:43 PM	-	ABSENCE	ABSENCE
32	Block 43 Lot 99, Phase 10, Southville	Distribution	7/12/2016	1:00 PM	6	ABSENCE	ABSENCE
BRGY. PULO							
33	Block 12 Lot 22, Cabuyao Central	Source	7/21/2016	10:35 AM	-	ABSENCE	ABSENCE
34	Clubhouse, Narra Avenue, Cabuyao Central	Distribution	7/21/2016	10:49 AM	2	ABSENCE	ABSENCE
35	Block 11, Willow Park Homes	Source	7/21/2016	11:16 AM	-	ABSENCE	ABSENCE
36	Guardhouse, Main St., Willow Park Homes	Distribution	7/21/2016	11:32 AM	<1	ABSENCE	ABSENCE
BRGY. SALA							

37	Guardhouse, Main St., Multiland III	Distribution	7/21/2016	11:55 AM	<1	ABSENCE	ABSENCE
BRGY. SAN ISIDRO							
38	Source, Multiland IV	Source	7/12/2016	9:25 AM	-	ABSENCE	ABSENCE
39	Block 3 Lot 33, Multiland IV	Distribution	7/12/2016	9:35 AM	16	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		39	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

CERTIFIED CORRECT



AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

8/8/2016 8:00 AM

DATE/TIME

8/08/16 8:40 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : CALAMBA	MONTH : JULY	YEAR : 2016
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BARANDAL							
1	Deepwell 1, Amaia Scapes Calamba	Source	7/27/2016	5:31 PM	<1	ABSENCE	ABSENCE
2	Block 39 Lot 1, Amaia Scapes Calamba	Distribution	7/27/2016	5:43 PM	-	ABSENCE	ABSENCE
3	Deepwell 3, Amaia Scapes Calamba	Source	7/27/2016	4:48 PM	<1	ABSENCE	ABSENCE
4	Guardhouse, Amaia Scapes Calamba	Distribution	7/27/2016	4:38 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		4	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES


TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

CERTIFIED CORRECT



AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

8/8/2016 8:00 AM

DATE/TIME

8/08/16 8:40 a.m.

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : ALAMINOS	MONTH : JULY	YEAR : 2016
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. SAN ANDRES							
1	Water Tank, Bellavita Homes	Source	7/27/2016	3:14 PM	<1	ABSENCE	ABSENCE
2	Block 8 Lot 1, Phase 1, BellaVita Homes	Distribution	7/27/2016	3:34 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED			2	2007 PNSDW LIMIT³	<500	ABSENCE	ABSENCE

NOTES
<p>TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)</p> <p>REFERENCES : ³Philippine National Standard for Drinking Water, 2007 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition</p>

PREPARED BY



CYRIL A. ERICA, RMT
Analyst (License No. 0054161)

DATE/TIME

8/3/2016 3:00 AM

CERTIFIED CORRECT



AMPARO C. CAÑAMO
Head of Laboratory

DATE/TIME

8/08/16 9:42 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026
Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007



LAGUNA AAAWATER CORPORATION
 OPERATIONS DEPARTMENT
 LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : SANTA CRUZ	MONTH : JULY	YEAR : 2016
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BUBUKAL							
1	Source after Filter, Laguna Sports Complex	Source	7/27/2016	1:13 PM	<1	ABSENCE	ABSENCE
2	Canteen No. 4 in front of Laguna University	Distribution	7/27/2016	1:33 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007
⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY

CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

DATE/TIME

8/8/2016 8:00 AM

CERTIFIED CORRECT

AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

8/08/16 8:42 a.m.