

CITY/MUNICIPALITY	BIÑAN	MONTH	FEBRUARY	YEAR	2017
DOH ACCREDITATION NO	04A-010-16-LW-2	VALIDITY	December 31, 2018	DOCUMENT NO	17WQM-02-BIN

NO	SAMPLE LOCATION		DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷ TOTAL <i>Escherichia coli</i>	
BRGY. BIÑAN											
1	Laguna Well Field 1	S	21-Feb	0.70	-	0.02	7.51	-	-	ABSENCE	ABSENCE
2	Pump 6, Santol St., Phase 4C, San Jose Village I	S	6-Feb	0.53	-	0.02	7.05	-	-	ABSENCE	ABSENCE
3	Clubhouse, Phase 4C, San Jose Village I	D	6-Feb	0.49	-	0.02	6.97	-	<1	ABSENCE	ABSENCE
4	Clubhouse, Phase 3B, San Jose Village I	D	6-Feb	0.45	-	0.02	7.06	-	2	ABSENCE	ABSENCE
5	Pump 11, Phase 5, San Jose Village II	S	6-Feb	< 0.20	-	0.02	6.90	-	-	ABSENCE	ABSENCE
6	Clubhouse, Phase 5, San Jose Village II	D	6-Feb	< 0.20	-	0.02	7.03	-	<1	ABSENCE	ABSENCE
7	Pump 7, San Jose Village III	S	6-Feb	0.35	-	0.13	6.89	-	-	ABSENCE	ABSENCE
8	Clubhouse, Phase 6, San Jose Village III	D	6-Feb	0.41	-	0.06	6.80	-	<1	ABSENCE	ABSENCE
BRGY. CANLALAY											
9	#132 A. Bonifacio St.	D	6-Feb	< 0.20	-	0.26	7.31	-	-	ABSENCE	ABSENCE
10	Golden City Canlalay Clubhouse	D	6-Feb	0.62	-	0.02	7.06	-	-	ABSENCE	ABSENCE
11	Canlalay Elementary School	D	6-Feb	0.66	-	0.08	7.00	-	-	ABSENCE	ABSENCE
BRGY. DELA PAZ											
12	Almeda	S	6-Feb	< 0.20	< 2	0.02	7.30	-	<1	ABSENCE	ABSENCE
13	Drinking Fountain, Dela Paz Elementary School	D	6-Feb	< 0.20	-	0.02	7.14	-	75	ABSENCE	ABSENCE
14	Barangay Hall	D	6-Feb	1.00	-	0.02	7.36	-	-	ABSENCE	ABSENCE
BRGY. GANADO											
15	Drinking Fountain, Ganado Elementary School	D	9-Feb	0.96	-	0.02	7.33	-	-	ABSENCE	ABSENCE
BRGY. HALANG											
16	9999 WP Metroville Complex	S	2-Feb	0.94	< 2	0.07	7.23	**unobjectionable	-	ABSENCE	ABSENCE
17	Clubhouse, Metroville Complex	D	2-Feb	0.66	-	0.10	7.21	-	<1	ABSENCE	ABSENCE
BRGY. LANGKIWA											
18	Southville Langkiwa	S	2-Feb	1.30	-	0.02	7.73	-	-	ABSENCE	ABSENCE
19	Block 3 Lot 19 Phase 2, Southville Langkiwa	D	2-Feb	1.36	-	0.02	7.29	-	-	ABSENCE	ABSENCE
20	Block 65 Lot 5 Phase 1, Southville Langkiwa	D	2-Feb	1.33	-	0.02	7.28	-	-	ABSENCE	ABSENCE
21	Block 20 Lot 7 Phase 3, Southville Langkiwa	D	2-Feb	1.36	-	0.02	7.38	-	-	ABSENCE	ABSENCE
22	Block 21 Lot 8 Phase 2, Southville Langkiwa	D	2-Feb	1.42	-	0.02	7.26	-	-	ABSENCE	ABSENCE

23	Block 18 Lot 11 Phase 4, Southville Langkiwa	D	2-Feb	1.01	-	0.02	7.15	-	-	ABSENCE	ABSENCE
24	Block 31 Lot 27, Phase 3, Southville Langkiwa	D	2-Feb	1.33	-	0.02	7.39	-	-	ABSENCE	ABSENCE
25	Drinking Fountain, Langkiwa Elementary School	D	2-Feb	1.39	-	0.04	7.21	-	-	ABSENCE	ABSENCE
BRGY. LOMA											
26	Water Pump, Celina Mansion Subdivision	S	2-Feb	0.21	-	0.02	7.39	-	-	ABSENCE	ABSENCE
27	Block 2 Lot 19, Celina Mansion Subdivision	D	20-Feb	0.92	-	0.02	7.15	-	-	ABSENCE	ABSENCE
28	Water Pump, Block 4 Lot 37, Celina Technopark	S	2-Feb	1.36	-	0.26	7.29	-	-	ABSENCE	ABSENCE
29	Block 13 Lot 13, Celina Technopark	D	2-Feb	1.29	-	0.06	7.23	-	-	ABSENCE	ABSENCE
30	Block 8, Laguna Bel-Air 3	S	7-Feb	0.97	-	0.02	7.36	-	-	ABSENCE	ABSENCE
31	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air 3	D	7-Feb	0.87	-	0.02	7.35	-	<1	ABSENCE	ABSENCE
32	Block 2, Phase 4, Laguna Bel-Air 3	S	6-Feb	0.91	-	0.02	7.39	-	-	ABSENCE	ABSENCE
33	Hilcrest Road, Block 2, Laguna Bel-Air 3	D	6-Feb	0.95	-	0.02	7.36	-	<1	ABSENCE	ABSENCE
34	Block 50, Phase 2, Laguna Bel-Air 3	S	6-Feb	1.00	-	0.02	7.13	-	-	ABSENCE	ABSENCE
35	Block 61 Lot 20, Laguna Bel-Air 3	D	6-Feb	0.96	-	0.02	7.41	-	<1	ABSENCE	ABSENCE
36	Drinking Fountain, Loma Elementary School	D	20-Feb	1.24	-	0.05	7.49	-	1	ABSENCE	ABSENCE
BRGY. MALAMIG											
37	Block 10 Lot 7	D	2-Feb	1.24	-	0.02	7.44	-	-	ABSENCE	ABSENCE
BRGY. MAMPLASAN											
38	Tank, Verdana Homes Subdivision	S	2-Feb	0.78	-	7.39	0.02	-	-	ABSENCE	ABSENCE
39	Clubhouse, Verdana Homes Subdivision	D	2-Feb	3.81	-	7.50	0.05	-	-	ABSENCE	ABSENCE
40	United Laboratories (UNILAB) Inc.	D	9-Feb	1.35	-	0.02	7.24	-	-	ABSENCE	ABSENCE
BRGY. POBLACION											
41	Brgy. Health Center	S	6-Feb	< 0.20	-	0.28	7.28	-	87	ABSENCE	ABSENCE
BRGY. PLATERO											
42	Drinking Fountain, St. Michael School of Biñan	D	14-Feb	0.89	-	0.05	7.05	-	56	ABSENCE	ABSENCE
43	Sea-oil, National Road	D	14-Feb	0.50	-	0.02	6.97	-	-	ABSENCE	ABSENCE
BRGY. SAN ANTONIO											
44	Biñan City Hall	S	9-Feb	0.30	-	0.02	7.54	-	-	ABSENCE	ABSENCE
45	Arena Sports Complex	D	9-Feb	0.42	-	0.37	7.44	-	-	ABSENCE	ABSENCE
46	9022 Water Pump (WP) Faraon Subdivision	S	6-Feb	0.73	< 2	0.02	7.44	**unobjectionable	-	ABSENCE	ABSENCE
47	Brgy. Heath Center, Faraon	D	6-Feb	0.92	-	0.02	7.42	-	3	ABSENCE	ABSENCE
48	Block 5 Lot 12, Margarita Homes Subdivision	D	6-Feb	0.97	-	0.08	7.45	-	-	ABSENCE	ABSENCE
49	Drinking Fountain 1, Faraon Elementary School	D	6-Feb	0.96	-	0.02	7.40	-	16	ABSENCE	ABSENCE
50	Drinking Fountain 2, Faraon Elementary School	D	6-Feb	1.02	-	0.02	7.44	-	-	ABSENCE	ABSENCE
51	Cistern Tank, Pavillion Mall	D	9-Feb	0.61	-	0.08	7.34	-	-	ABSENCE	ABSENCE
52	Jollibee, Pavillion Mall	D	9-Feb	0.59	-	0.11	7.43	-	-	ABSENCE	ABSENCE
BRGY. SANTO NIÑO											
53	Jollibee National Hi-Way	D	9-Feb	0.58	-	0.02	7.55	-	-	ABSENCE	ABSENCE
BRGY. SAN VICENTE											
54	407 San Vicente	S	6-Feb	0.74	-	0.02	7.51	-	-	ABSENCE	ABSENCE

55	B8 L6, Bayabas St., Olivarez 7	D	6-Feb	0.90	-	0.02	7.22	-	46	ABSENCE	ABSENCE
56	Cistern Tank, Central Mall	D	14-Feb	0.64	-	0.02	7.37	-	-	ABSENCE	ABSENCE
57	Drinking Fountain, San Vicente Elementary Sch.	D	9-Feb	< 0.20	-	0.02	7.12	-	-	ABSENCE	ABSENCE
BRGY. SANTO TOMAS											
58	Adelina	S	9-Feb	0.58	-	0.16	7.56	-	-	ABSENCE	ABSENCE
59	Gate Entrance, Adelina Complex III Subdivision	D	9-Feb	0.44	-	0.26	7.26	-	-	ABSENCE	ABSENCE
60	Block 1 Lot 26, Phase 3, Olivarez Homes South	D	6-Feb	1.02	-	0.02	6.98	-	-	ABSENCE	ABSENCE
61	5555 Block 1, Phase 4, Olivarez Homes South	S	2-Feb	0.58	-	0.02	7.05	-	<1	ABSENCE	ABSENCE
62	Block 1 Lot 16, Phase 4, Olivarez Homes South	D	2-Feb	0.54	-	0.25	7.16	-	-	ABSENCE	ABSENCE
63	Pump House, Kalibo St., South City Homes	S	9-Feb	0.22	-	0.14	7.67	-	-	ABSENCE	ABSENCE
64	Block 76 Lot 6, Tangub St., Pragmatic	D	9-Feb	< 0.20	-	0.15	7.78	-	-	ABSENCE	ABSENCE
65	Deepwell 1, South City Homes	S	7-Feb	0.45	-	0.05	7.57	-	-	ABSENCE	ABSENCE
66	Block 5 Lot 2, South City Homes	D	7-Feb	0.32	-	0.02	7.53	-	<1	ABSENCE	ABSENCE
67	Deepwell 3, Phase XI, South City Homes	S	7-Feb	0.37	-	0.10	7.57	-	-	ABSENCE	ABSENCE
68	Block 42 Lot 16, Phase XI, South City Homes	D	7-Feb	0.32	-	0.08	7.61	-	<1	ABSENCE	ABSENCE
69	Pump, South Plains II Subdivision	S	9-Feb	0.69	-	0.04	7.62	-	-	ABSENCE	ABSENCE
70	Block 11 Lot 2, South Plains II Subdivision	D	9-Feb	0.68	-	0.07	7.60	-	-	ABSENCE	ABSENCE
71	Pump, Amsterdam St., Phase 2, Town & Country	S	2-Feb	0.62	-	0.02	7.01	-	-	ABSENCE	ABSENCE
72	Block 35 Lot 21, Town & Country	D	2-Feb	0.68	-	0.10	7.10	-	-	ABSENCE	ABSENCE
73	Sotuhville, Town & Country - Pennsylvania	S	2-Feb	0.34	-	0.02	7.03	-	-	ABSENCE	ABSENCE
74	Block 2 Lot 5, Town & Country	D	2-Feb	1.45	-	0.02	7.28	-	-	ABSENCE	ABSENCE
BRGY. SORO - SORO											
75	9067 Soro-soro	S	2-Feb	0.82	< 2	0.02	7.33	**unobjectionable	-	ABSENCE	ABSENCE
76	#76 Soro-Soro	D	6-Feb	0.79	-	0.02	6.98	-	<1	ABSENCE	ABSENCE
BRGY. TUBIGAN											
77	#60 Florinda Compound	D	2-Feb	0.66	-	0.02	7.25	-	-	ABSENCE	ABSENCE
BRGY. ZAPOTE											
78	Water Pump, Althea	S	9-Feb	< 0.20	-	0.20	7.46	-	-	ABSENCE	ABSENCE
79	Block 6 Lot 4, Althea	D	9-Feb	< 0.20	-	0.16	7.51	-	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		79	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE


REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

ANALYZED BY:



ANNA KARLA S. GUTIERREZ
Microbiologist



JOVEN M. MARAVILLA
Chemist

CERTIFIED CORRECT:



CYRIL A. ERICA
Laboratory Services Manager

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : SANTA ROSA	MONTH : FEBRUARY	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-02-STR

NO	SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE	***Res. Chlorine ¹ mg/L		Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷		
										TOTAL	<i>Escherichia coli</i>	
BRGY. BALIBAGO												
1	#1354 Facundo Compound	D	7-Feb	0.61	-	0.02	7.33	-	<1	ABSENCE	ABSENCE	
2	5555 Water Pump Elevated, South Hampton	S	1-Feb	0.83	< 2	0.02	7.44	**unobjectionable	-	ABSENCE	ABSENCE	
3	Clubhouse, South Hampton	D	1-Feb	1.16	-	0.02	7.55	-	<1	ABSENCE	ABSENCE	
4	Block 11 Lot 2, JB Village, Sta. Rosa Tagaytay Road	D	7-Feb	0.74	-	0.02	7.03	-	-	ABSENCE	ABSENCE	
5	Cistern Tank, Waltermart Sta. Rosa	D	20-Feb	0.87	-	0.33	7.66	-	<1	ABSENCE	ABSENCE	
6	2nd Floor Faucet, Waltermart Sta. Rosa	D	22-Feb	< 0.20	-	0.13	7.63	-	-	ABSENCE	ABSENCE	
BRGY. CAINGIN												
7	Block 57, Phase 1, Southville	S	9-Feb	1.64	< 2	0.02	7.38	**unobjectionable	-	ABSENCE	ABSENCE	
8	Block 52 Lot 23, Phase 1, Southville	D	9-Feb	1.40	-	0.02	7.42	-	-	ABSENCE	ABSENCE	
9	Block 46 Lot 2, Phase 2, Southville	D	9-Feb	1.48	-	0.02	7.43	-	-			
10	Caingin Elementary School	D	9-Feb	< 0.20	-	0.02	6.92	-	-	ABSENCE	ABSENCE	
BRGY. DILA												
11	Phase 3E, Mabuhay Homes 2000	S	9-Feb	0.68	< 2	0.02	7.29	**unobjectionable	-	ABSENCE	ABSENCE	
12	Block 2 Lot 10, Mabuhay Homes 2000	D	9-Feb	0.68	-	0.02	7.14	-	-	ABSENCE	ABSENCE	
13	Block 12, Phase 2E, Mabuhay Homes 2000	S	9-Feb	1.33	-	0.02	7.47	-	-	ABSENCE	ABSENCE	
14	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	D	9-Feb	1.33	-	0.30	7.43	-	-	ABSENCE	ABSENCE	
15	Drinking Fountain, Dila Elementary School	D	14-Feb	0.65	-	0.02	7.16	-	<1	ABSENCE	ABSENCE	
BRGY. DITA												
16	Block 24 Lot 2, New Santa Rosa Homes	S	9-Feb	0.58	-	0.02	7.65	-	-	ABSENCE	ABSENCE	
17	Block 19 Lot 11, New Santa Rosa Homes	D	9-Feb	0.42	-	0.02	7.62	-	-	ABSENCE	ABSENCE	
18	Block 4 Lot 32, San Lorenzo Royale	S	1-Feb	< 0.20	-	0.02	7.65	-	<1	ABSENCE	ABSENCE	
19	Block 11 Lot 52, San Lorenzo Royale	D	1-Feb	< 0.20	-	0.87	7.47	-	<1	ABSENCE	ABSENCE	
20	Water Tank, SolCar Ville Subdivision	S	9-Feb	0.75	< 2	0.02	7.31	**unobjectionable	-	ABSENCE	ABSENCE	
21	Block 3 Lot 7, SolCar Ville Subdivision	D	9-Feb	0.59	-	0.02	7.38	-	-	ABSENCE	ABSENCE	
22	Water Tank, Villa Esmeralda	S	1-Feb	0.23	-	0.17	7.53	-	-	ABSENCE	ABSENCE	
23	Alabaster St., Villa Esmeralda	D	1-Feb	1.43	-	2.85	7.60	-	1	ABSENCE	ABSENCE	
24	#1780 National Road	D	13-Feb	0.56	-	0.02	7.05	-	-	ABSENCE	ABSENCE	
25	R & B Ice Plant, Inc.	D	7-Feb	0.53	-	0.02	6.89	-	<1	ABSENCE	ABSENCE	

BRGY. DON JOSE											
26	Block 7 Lot 62, Phase 3, Laguna Bel-Air	S	7-Feb	0.98	-	0.02	7.34	-	-	ABSENCE	ABSENCE
27	Science HighSchool, Phase 1, Laguna Bel-Air	D	7-Feb	1.10	-	0.02	7.42	-	<1	ABSENCE	ABSENCE
28	Block 34 Lot 14, Phase 1, Laguna Bel-Air	S	7-Feb	1.05	-	0.02	7.39	-	-	ABSENCE	ABSENCE
29	Block 34 Lot 59, Phase 1, Laguna Bel-Air	D	7-Feb	1.14	-	0.02	7.39	-	<1	ABSENCE	ABSENCE
30	Clubhouse, Block 62, Laguna Bel-Air	D	7-Feb	1.21	-	0.02	7.40	-	-	ABSENCE	ABSENCE
31	Water Pump, Block 71, Phase 4, Laguna Bel-Air	S	7-Feb	0.92	-	0.02	7.45	-	<1	ABSENCE	ABSENCE
32	Block 71 Lot 4, Phase 2, Laguna Bel-Air	D	7-Feb	0.82	-	0.02	7.19	-	-	ABSENCE	ABSENCE
33	Block 108, Phase 5, Laguna Bel-Air	S	7-Feb	< 0.20	-	0.02	7.51	-	<1	ABSENCE	ABSENCE
34	Church, Block 108, Phase 2, Laguna Bel-Air	D	7-Feb	< 0.20	-	0.02	7.52	-	-	ABSENCE	ABSENCE
35	1NR Block 43, Laguna Bel-Air IV	S	7-Feb	0.95	-	0.02	7.49	-	<1	ABSENCE	ABSENCE
36	Block 47 Lot 12 Laguna Bel-Air IV	D	7-Feb	0.87	-	0.02	7.50	-	-	ABSENCE	ABSENCE
37	8001, Pump 1, Acacia St., Santa Rosa Village I	S	6-Feb	0.31	-	0.02	6.90	-	-	ABSENCE	ABSENCE
38	Clubhouse., Santa Rosa Village I	D	6-Feb	0.22	-	0.02	7.03	-	1	ABSENCE	ABSENCE
39	Pump 9 & 10, Rembrandt St., Santa Rosa Estates I	S	6-Feb	0.75	-	0.15	7.10	-	-	ABSENCE	ABSENCE
40	Clubhouse, Santa Rosa Village II	D	6-Feb	0.72	-	0.02	7.13	-	<1	ABSENCE	ABSENCE
41	Clubhouse, Santa Rosa Estates I	D	6-Feb	0.72	-	0.02	7.08	-	<1	ABSENCE	ABSENCE
42	Reservoir, Hacienda Sta. Elena	D	28-Feb	1.26	-	0.02	7.14	-	-	ABSENCE	ABSENCE
BRGY. KANLURAN											
43	#621 Rizal Boulevard	D	13-Feb	0.77	-	0.02	7.31	-	-	ABSENCE	ABSENCE
BRGY. MACABLING											
44	Deepwell, Buena Rosa 9 Subdivision	S	7-Feb	1.50	< 2	0.02	7.35	**unobjectionable	-	ABSENCE	ABSENCE
45	Block 9 Lot 2, Phase 2, Buena Rosa 9 Subdivision	D	7-Feb	1.47	-	0.02	7.53	-	<1	ABSENCE	ABSENCE
46	Deepwell, Corinthian Subdivision	S	7-Feb	1.03	< 2	0.02	6.67	**unobjectionable	-	ABSENCE	ABSENCE
47	Block 11 Lot 19, Corinthian Subdivision	D	7-Feb	0.98	-	0.02	7.05	-	3	ABSENCE	ABSENCE
48	Deepwell, Rosemont Subdivision	S	7-Feb	1.89	< 2	0.02	7.49	**unobjectionable	-	ABSENCE	ABSENCE
49	Block 3 Lot 22, Rosemont Subdivision	D	7-Feb	1.90	-	0.02	7.51	-	<1	ABSENCE	ABSENCE
50	Water Pump, Metrogate	S	7-Feb	1.09	< 2	0.02	7.59	**unobjectionable	-	ABSENCE	ABSENCE
51	Clubhouse, Metrogate	D	7-Feb	2.14	-	0.02	7.50	-	<1	ABSENCE	ABSENCE
BRGY. MALITLIT											
52	Water Pump, Casan Residencia Subdivision	S	9-Feb	0.32	-	0.02	7.29	-	-	ABSENCE	ABSENCE
53	Block 1 Lot 1, Casan Residencia Subdivision	D	13-Feb	< 0.20	-	0.02	7.21	-	-	ABSENCE	ABSENCE
54	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	S	1-Feb	0.98	< 2	0.02	7.44	**unobjectionable	-	ABSENCE	ABSENCE
55	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	D	1-Feb	0.96	-	0.02	7.46	-	2	ABSENCE	ABSENCE
56	Main Road, Phase 2, Terra Fortuna	S	1-Feb	0.47	-	0.07	7.49	-	-	ABSENCE	ABSENCE
57	Block 11 Lot 16, Terra Fortuna	D	1-Feb	0.55	-	0.25	7.54	-	7	ABSENCE	ABSENCE
58	9999 W, Villa Las Casas	S	1-Feb	1.35	-	0.02	7.45	-	<1	ABSENCE	ABSENCE
59	Circle Entrance, Villa Las Casas	D	1-Feb	1.12	-	0.93	7.25	-	77	ABSENCE	ABSENCE
60	Malitlit Elementary School	D	14-Feb	0.69	-	0.05	7.33	-	-	ABSENCE	ABSENCE
BRGY. MALUSAK											
61	Drinking Fountain 1, Central 1 Elementary Sch.	D	7-Feb	0.89	-	0.02	7.55	-	<1	ABSENCE	ABSENCE
62	Drinking Fountain 2, Central 1 Elementary Sch.	D	7-Feb	1.07	-	0.02	7.67	-	-	ABSENCE	ABSENCE

63	Drinking Fountain 3 , Central 1 Elementary Sch.	D	7-Feb	1.14	-	0.02	7.67	-	<1	ABSENCE	ABSENCE
BRGY. MARKET AREA											
64	Source, Market Area	S	13-Feb	1.18	< 2	0.02	7.51	**unobjectionable	-	ABSENCE	ABSENCE
65	Block 2 Lot 9, Terry Town West	D	13-Feb	0.74	-	0.02	7.52	-	96	ABSENCE	ABSENCE
BRGY. POOC											
66	Deepwell, Alinsod	S	7-Feb	1.15	< 2	0.02	7.61	**unobjectionable	-	ABSENCE	ABSENCE
67	Tank, Villa Mercedes	S	13-Feb	0.52	< 2	0.02	7.30	**unobjectionable	-	ABSENCE	ABSENCE
68	Block 5 Lot 25, Villa Mercedes	D	13-Feb	0.90	-	0.02	7.44	-	<1	ABSENCE	ABSENCE
BRGY. PULONG SANTA CRUZ											
69	Water Pump, Pulong Sta. Cruz	S	1-Feb	1.03	< 2	0.02	7.14	**unobjectionable	-	ABSENCE	ABSENCE
70	Block 7 Lot 3 Mercado Village, Pulong Sta. Cruz	D	1-Feb	1.15	-	0.02	7.14	-	<1	ABSENCE	ABSENCE
71	Block 6 Lot 8, Buklod Diwa	D	28-Feb	1.02	-	0.14	7.19	-	-	ABSENCE	ABSENCE
BRGY. SINALHAN											
72	Block 5 Lot 7, Phase 1, Bayshore I	D	13-Feb	0.96	-	0.02	7.51	-	2	ABSENCE	ABSENCE
73	Block 6 Lot 10, Bayshore II	D	13-Feb	0.74	-	0.02	7.64	-	-	ABSENCE	ABSENCE
74	4026, Sinalhan Road, Purok 2	S	13-Feb	0.76	< 2	0.02	7.50	**unobjectionable	-	ABSENCE	ABSENCE
75	Amoranto Compound, Phase 2, Sinalhan	D	13-Feb	0.60	-	0.02	7.49	-	<1	ABSENCE	ABSENCE
BRGY. SANTO DOMINGO											
76	Clubhouse Santa Rosa Estates II	D	6-Feb	0.73	-	0.02	7.10	-	-	ABSENCE	ABSENCE
BRGY. TAGAPO											
77	Water Pump, Fairfield of Margana Subdivision	S	7-Feb	< 0.20	-	0.32	7.56	-	<1	ABSENCE	ABSENCE
78	Block 1 Lot 18, Fairfield of Margana Subdivision	D	7-Feb	< 0.20	-	0.17	7.53	-	-	ABSENCE	ABSENCE
79	Water Pump, Rosewood Homes I	S	7-Feb	1.24	< 2	0.02	7.44	**unobjectionable	-	ABSENCE	ABSENCE
80	Block 3 Lot 31, Rosewood Homes I	D	7-Feb	1.29	-	0.02	7.48	-	4	ABSENCE	ABSENCE
81	Block 4 Lot 1, Rosewood Homes II	D	7-Feb	1.41	-	0.02	7.62	-	-	ABSENCE	ABSENCE
82	#31 JP Rizal Boulevard	D	7-Feb	1.25	-	0.02	7.65	-	78	ABSENCE	ABSENCE
83	Water Pump, Buena Rosa 1 Subdivision	S	7-Feb	0.61	-	0.11	7.62	-	-	ABSENCE	ABSENCE
84	Clubhouse, Buena Rosa 1 Subdivision	D	7-Feb	< 0.20	-	0.45	7.69	-	390	ABSENCE	ABSENCE
85	Block 1 Lot 64, Buena Rosa 10 Subdivision	D	7-Feb	1.19	-	0.02	7.57	-	+	ABSENCE	ABSENCE
86	Cistern Tank, SM Sta. Rosa	D	14-Feb	0.47	-	0.08	7.53	-	<1	ABSENCE	ABSENCE
87	Crepes Delicious, SM Sta. Rosa	D	14-Feb	0.46	-	0.11	7.67	-	-	ABSENCE	ABSENCE
88	Cistern Tank, Robinson's Mall	D	14-Feb	< 0.20	-	0.02	7.65	-	3	ABSENCE	ABSENCE
89	Chummie Shawarma, Robinson's Mall	D	22-Feb	0.56	-	0.02	7.49	-	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		89	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE


REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU - Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

ANALYZED BY:



ANNA KARLA S. GUTIERREZ
Microbiologist



JOVEN M. MARAVILLA
Chemist

CERTIFIED CORRECT:



CYRIL A. ERICA
Laboratory Services Manager

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : CABUYAO	MONTH : FEBRUARY	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-02-CAB

NO	SAMPLE LOCATION		DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷ TOTAL <i>Escherichia coli</i>	
BRGY. BANAY-BANAY											
1	Water Pump, Block 63, Lakeside Nest Subdivision	S	14-Feb	1.07	< 2	0.02	7.25	**unobjectionable	-	ABSENCE	ABSENCE
2	Block 12 Lot 5, Lakeside Nest Subdivision	D	14-Feb	1.34	-	0.02	7.21	-	8	ABSENCE	ABSENCE
BRGY. BANLIC											
3	Water Pump, Gran Seville Subdivision	S	7-Feb	< 0.20	-	0.05	7.41	-	-	ABSENCE	ABSENCE
4	Guardhouse, Gran Seville Subdivision	D	7-Feb	< 0.20	-	0.22	7.39	-	<1	ABSENCE	ABSENCE
BRGY. BIGAA											
5	#253 Elsol Subdivision	D	14-Feb	< 0.20	-	0.20	7.28	-	5	ABSENCE	ABSENCE
BRGY. CASILE											
6	Matang Tubig Spring	S	28-Feb	< 0.20	-	0.02	7.18	-	-	ABSENCE	ABSENCE
BRGY. GULOD											
7	Block 12, Noah St., Celestine Ville	S	14-Feb	2.14	< 2	0.02	7.38	**unobjectionable	-	ABSENCE	ABSENCE
8	Guardhouse, Celestine Ville Ave., Celestine Ville	D	14-Feb	0.60	-	0.02	7.46	-	<1	ABSENCE	ABSENCE
BRGY. MAMATID											
9	Tank, Buena Rosario Subdivision	S	20-Feb	< 0.20	-	0.35	7.75	-	-	ABSENCE	ABSENCE
10	Block 7 Lot 6, Buena Rosario Subdivision	D	20-Feb	< 0.20	-	0.36	7.74	-	1	ABSENCE	ABSENCE
11	Block 101 Samar st., Phase 1, Mabuhay City	S	14-Feb	0.30	-	0.11	7.52	-	-	ABSENCE	ABSENCE
12	Block 95 Lot 57, Guimaras St., Phase 1, Mabuhay City	D	14-Feb	< 0.20	-	0.10	7.49	-	7	ABSENCE	ABSENCE
13	Block 141, Carmona St., Phase 2, Mabuhay City	S	14-Feb	0.34	-	0.31	7.54	-	-	ABSENCE	ABSENCE
14	Block 134 Lot 22, Phase 2, Mabuhay City	D	14-Feb	0.21	-	0.13	7.47	-	1	ABSENCE	ABSENCE
15	Block 198, Galacia St., Phase 2, Mabuhay City	S	14-Feb	< 0.20	-	0.06	7.50	-	-	ABSENCE	ABSENCE
16	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	D	14-Feb	< 0.20	-	0.09	7.52	-	<1	ABSENCE	ABSENCE
17	Panganig St., Phase 3 Cluster, Mabuhay City	S	20-Feb	< 0.20	-	0.64	6.54	-	-	ABSENCE	ABSENCE
18	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	D	20-Feb	0.22	-	1.53	7.13	-	<1	ABSENCE	ABSENCE
19	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	S	20-Feb	< 0.20	-	1.04	7.75	-	-	ABSENCE	ABSENCE
20	Block 19 Lot 13, Malang St., Phase 3 Luxury,	D	20-Feb	0.59	-	4.28	7.65	-	4	ABSENCE	ABSENCE
21	Joshua St., Phase 5, Mabuhay City	S	7-Feb	< 0.20	-	0.02	7.42	-	-	ABSENCE	ABSENCE
22	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	D	7-Feb	0.27	-	0.77	7.62	-	<1	ABSENCE	ABSENCE

BRGY. MARINIG											
23	Block 3 Lot 17, Phase 1, Celestine Homes	S	14-Feb	0.70	< 2	0.02	7.17	**unobjectionable	-	ABSENCE	ABSENCE
24	Block 23, Lot 10, Phase 1, Celestine Homes	D	14-Feb	1.07	-	0.06	7.51	-	3	ABSENCE	ABSENCE
25	Block 9, Carnation St., Phase 2, Celestine Homes	S	14-Feb	0.51	-	0.65	7.46	-	-	ABSENCE	ABSENCE
26	Block 11 Lot 9, Phase 2, Celestine Homes	D	14-Feb	0.25	-	1.02	7.36	-	<1	ABSENCE	ABSENCE
27	Block 25, Phase 3, Southville	S	14-Feb	1.08	< 2	0.02	7.47	**unobjectionable	-	ABSENCE	ABSENCE
28	Block 19 Lot 33, Phase 3, Southville	D	14-Feb	0.78	-	0.02	7.49	-	1	ABSENCE	ABSENCE
BRGY. NIUGAN											
29	Water Pump, Niugan Elementary School Compound	S	7-Feb	0.57	-	0.04	7.24	-	-	ABSENCE	ABSENCE
30	Block 2 Lot 6, St. Francis Homes 6	D	7-Feb	0.58	-	0.06	7.43	-	<1	ABSENCE	ABSENCE
31	Block 45, Phase 8, Southville	S	14-Feb	0.92	< 2	0.02	7.45	**unobjectionable	-	ABSENCE	ABSENCE
32	Block 40 Lot 132, Southville	D	22-Feb	0.71	-	0.02	7.42	-	290	ABSENCE	ABSENCE
33	Block 54, Phase 10, Southville	S	14-Feb	1.46	< 2	0.02	7.20	**unobjectionable	-	ABSENCE	ABSENCE
34	Block 47 Lot 101, Phase 10, Southville	D	14-Feb	1.43	-	0.02	7.06	-	<1	ABSENCE	ABSENCE
BRGY. PULO											
35	Water Pump, Block 12 Lot 22, Cabuyao Central	S	7-Feb	0.26	-	0.02	7.49	-	-	ABSENCE	ABSENCE
36	Clubhouse, Narra Avenue, Cabuyao Central	D	7-Feb	< 0.20	-	0.55	7.60	-	<1	ABSENCE	ABSENCE
37	Water Pump, Block 11, Willow Park Homes	S	7-Feb	1.69	< 2	0.02	7.34	**unobjectionable	-	ABSENCE	ABSENCE
38	Clubhouse, Willow Park Homes	D	7-Feb	1.50	-	0.27	7.22	-	<1	ABSENCE	ABSENCE
BRGY. SALA											
39	Guardhouse, Main St., Multiland III	D	14-Feb	0.63	-	0.02	7.04	-	-	ABSENCE	ABSENCE
BRGY. SAN ISIDRO											
40	Source, Multiland IV	S	7-Feb	1.02	-	0.02	7.24	-	-	ABSENCE	ABSENCE
41	Block 3 Lot 33, Multiland IV	D	7-Feb	0.86	-	0.69	7.38	-	<1	ABSENCE	ABSENCE
42	Water Pump, San Isidro Heights Subdivision	S	7-Feb	0.42	-	0.02	7.52	-	-	ABSENCE	ABSENCE
43	Block 3 Lot 1, San Isidro Heights Subdivision	D	7-Feb	0.47	-	0.02	7.45	-	4	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		43	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU - Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

ANALYZED BY:

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ
Microbiologist


JOVEN M. MARAVILLA
Chemist


CYRIL A. ERICA
Laboratory Services Manager

Page 2 of 2

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

Laguna AAWater Corporation | G/F One Evotech Bldg., Nuvali, Sta. Rosa City, Laguna | +63 49 544-4386 • +63 2 519-4429 | www.lagunawater.com.ph

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : CALAMBA	MONTH : FEBRUARY	YEAR : 2017
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-02-CAL

NO	SAMPLE LOCATION		DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY			
	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷		
		TOTAL	Escherichia coli									
BRGY. BARANDAL												
1	Deepwell 1, Amaia Scapes Calamba		21-Feb	0.69	-	0.02	7.51	-	-	ABSENCE	ABSENCE	
2	Block 1 Lot 2, Amaia Scapes Calamba		21-Feb	0.70	-	0.02	7.51	-	6	ABSENCE	ABSENCE	
3	Deepwell 2, Amaia Scapes Calamba		21-Feb	0.36	-	0.02	7.65	-	-	ABSENCE	ABSENCE	
4	Block 39 Lot 5, Amaia Scapes Calamba		21-Feb	0.23	-	0.02	7.51	-	14	ABSENCE	ABSENCE	
BRGY. PUTING LUPA												
5	Phase 1, Greenfields		21-Feb	0.88	-	0.02	7.63	-	-	ABSENCE	ABSENCE	
6	Block 11, Kanlaon St., Greenfields		21-Feb	0.92	-	0.02	7.50	-	18	ABSENCE	ABSENCE	
7	Clubhouse, Greenfields		21-Feb	0.48	-	0.02	7.66	-	-	ABSENCE	ABSENCE	
TOTAL SAMPLES ANALYZED			7	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L; Color = 2.5 ACU; Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

ANALYZED BY:

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ
Microbiologist


JOVEN M. MARAVILLA
Chemist


CYRIL A. ERICA
Laboratory Services Manager

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : ALAMINOS	MONTH : FEBRUARY	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-02-ALA

NO	SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE			***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷ TOTAL	<i>Escherichia coli</i>
BRGY. SAN ANDRES												
1	Water Tank, Bellavita Homes	S		21-Feb	0.54	< 2	0.02	7.42	**unobjectionable	-	ABSENCE	ABSENCE
2	Block 8 Lot 1, Phase 1, BellaVita Homes	D		21-Feb	0.55	-	0.02	7.15	-	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE	

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

ANALYZED BY:

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ
Microbiologist


JOVEN M. MARAVILLA
Chemist


CYRIL A. ERICA
Laboratory Services Manager

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY	SANTA CRUZ	MONTH	FEBRUARY	YEAR	2017
DOH ACCREDIATION NO	04A-010-16-LW-2	VALIDITY	December 31, 2018	DOCUMENT NO	17WQM-02-STC

NO	SAMPLE LOCATION		DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷ TOTAL	<i>Escherichia coli</i>
BRGY. BUBUKAL											
1	Source after Filter, Laguna Sports Complex	S	21-Feb	0.56	< 2	0.02	7.43	**unobjectionable	-	ABSENCE	ABSENCE
2	Canteen No. 4 in front of Laguna University	D	21-Feb	0.70	-	0.02	7.35	-	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Collert®-18)

ANALYZED BY:

CERTIFIED CORRECT:



ANNA KARLA S. GUTIERREZ
Microbiologist



JOVEN M. MARAVILLA
Chemist



CYRIL A. ERICA
Laboratory Services Manager

CITY/MUNICIPALITY : PAGSANJAN	MONTH : FEBRUARY	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-02-PAG

NO	SAMPLE LOCATION		DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY			
	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷		
		TOTAL	Escherichia coli									
BRGY. SABANG												
1	Purok 6, Moresco Ville 2	S	21-Feb	0.92	< 2	0.02	7.28	**unobjectionable	-	ABSENCE	ABSENCE	
2	Reservoir, Moresco Ville 2	S	21-Feb	2.72	-	0.02	7.47	-	< 1	ABSENCE	ABSENCE	
TOTAL SAMPLES ANALYZED		2	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE	

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2.5 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

ANALYZED BY:

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ
Microbiologist


JOVEN M. MARAVILLA
Chemist


CYRIL A. MERICA
Laboratory Services Manager