

Accreditations, Recognitions and Licenses:

DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : \$20-2495

DATE/TIME SUBMITTED : 04/16/2020 14:20

DATE/TIME COLLECTION : 04/16/2020 13:05

COLLECTED BY: Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : WATER PUMP, BELLA VITA SUBDIVISION, BRGY. SAN ANDRES, ALAMINOS, LAGUNA

SAMPLE

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate **CHARACTERISTICS**

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/16/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/16/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	04/16/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN Microbiology Unit Manager

ANNA KA FIERREZ, RMT Laboratory Services Manager License No(s) (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



Accreditations, Recognitions and Licenses:

DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

DATE/TIME COLLECTION : 04/16/2020 13:15 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : CLUBHOUSE, BELLA VITA SUBDIVISION, BRGY. SAN ANDRES, ALAMINOS, LAGUNA

SAMPLE

CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/16/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	04/16/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	04/16/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: <u>A</u> – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

ANNA KARLAS, GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis