

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 72

TOTAL PARAMETERS TESTED: 3


ANALYSIS DATE(S) : 04/02/2025-04/29/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
04/29/2025 09:30	S25-2724	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
04/11/2025 12:35	S25-2419	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	< 1
04/11/2025 12:26	S25-2420	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	< 1
04/11/2025 13:40	S25-2421	Pump 11, Phase 5, San Jose Village II	ABSENCE	ABSENCE	7
04/11/2025 13:51	S25-2422	Clubhouse, Phase 5, San Jose Village II	ABSENCE	ABSENCE	< 1
04/29/2025 13:25	S25-2741	Clubhouse, Phase 6, San Jose Village III	ABSENCE	ABSENCE	< 1
04/11/2025 02:45	S25-2424	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	< 1
04/29/2025 13:34	S25-2742	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY					
04/10/2025 11:57	S25-2345	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	< 1
04/10/2025 12:12	S25-2346	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	< 1
BRGY. HALANG					
04/10/2025 12:29	S25-2341	9999 Water Pump, Metroville Complex	ABSENCE	ABSENCE	1
04/10/2025 12:38	S25-2342	Block 30 Lot 17, Metroville Complex	ABSENCE	ABSENCE	< 1
BRGY. GANADO					
04/15/2025 11:29	S25-2491	Ganado Elementary School	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ					
04/10/2025 11:29	S25-2351	Water Pump, Almeda Subdivision	ABSENCE	ABSENCE	2


NOT VALID WITHOUT QR CODE



REVIEWED BY:


SHEENA MAB B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER9		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. LANGKIWA					
04/15/2025 09:50	S25-2506	Water Pump, Southville 5A	ABSENCE	ABSENCE	11
04/15/2025 09:31	S25-2503	Drinking Fountain, Southville 5A National High School	ABSENCE	ABSENCE	< 1
04/15/2025 09:42	S25-2504	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	< 1
04/15/2025 09:56	S25-2507	Community Center, Phase II, Southville	ABSENCE	ABSENCE	< 1
04/29/2025 13:16	S25-2747	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	< 1
BRGY. LOMA					
04/11/2025 14:43	S25-2426	Block 43 Lot 13, Celina Technopark	ABSENCE	ABSENCE	< 1
04/11/2025 09:00	S25-2413	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
04/11/2025 09:14	S25-2414	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	3
04/11/2025 14:29	S25-2428	Drinking Fountain, Loma Elementary	ABSENCE	ABSENCE	9
BRGY. MAMPLASAN					
04/11/2025 14:10	S25-2427	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	< 1
04/15/2025 11:06	S25-2492	Amherst Laboratory (UNILAB)	ABSENCE	ABSENCE	< 1
BRGY. POBLACION					
04/10/2025 11:07	S25-2352	Barangay Hall	ABSENCE	ABSENCE	16
BRGY. PLATERO					
04/02/2025 10:11	S25-2081	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	6
04/02/2025 12:10	S25-2083	Clubhouse, Prima Casa	ABSENCE	ABSENCE	15
04/02/2025 11:54	S25-2082	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	< 1
04/02/2025 12:23	S25-2084	Water Pump, Springtime	ABSENCE	ABSENCE	< 1
04/02/2025 12:39	S25-2085	Block 7 Lot 10, Springtime	ABSENCE	ABSENCE	< 1
04/15/2025 12:40	S25-2494	Sea-oil, National Road	ABSENCE	ABSENCE	1
03/12/2025 13:04	S25-2497	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	< 1
BRGY. SAN ANTONIO					
04/29/2025 09:40	S25-2737	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	< 1
04/29/2025 09:11	S25-2738	Alonte Stadium	ABSENCE	ABSENCE	2
04/15/2025 12:27	S25-2497	Block 1 Lot 13, Margarita Homes	ABSENCE	ABSENCE	< 1
04/10/2025 10:29	S25-2347	9022 Water Pump, Faraon Subdivision	ABSENCE	ABSENCE	< 1
04/10/2025 10:04	S25-2353	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	28
04/15/2025 11:47	S25-2498	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	< 1
04/15/2025 11:56	S25-2499	Reyes BBQ, Pavilion Mall	ABSENCE	ABSENCE	< 1
04/10/2025 10:59	S25-2348	Malaban Health Center	ABSENCE	ABSENCE	6

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:

 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
04/10/2025 13:10	S25-2349	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	14
04/10/2025 13:10	S25-2350	Wash Area 2, Malaban Elementary School	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO					
04/15/2025 12:19	S25-2500	Jollibee National Hi-Way	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE					
04/29/2025 12:37	S25-2766	407 Water Pump, San Vicente Subdivision	ABSENCE	ABSENCE	9
04/29/2025 10:28	S25-2749	Block 8 Lot 6 Bayabas St., Phase 7 Olivarez Homes	ABSENCE	ABSENCE	< 1
04/29/2025 12:56	S25-2748	Drinking Fountain, San Vicente Elementary School	ABSENCE	ABSENCE	< 1
04/29/2025 13:29	S25-2750	Cistern Tank, Central Mall	ABSENCE	ABSENCE	< 1
04/15/2025 12:48	S25-2495	Binan Doctor's Hospital	ABSENCE	ABSENCE	< 1
BRGY. SANTO TOMAS					
04/15/2025 10:21	S25-2493	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	< 1
04/29/2025 10:50	S25-2756	Block 1 Lot 5, Bais St., Pragmatic	ABSENCE	ABSENCE	2
04/15/2025 10:34	S25-2502	Block 5 Lot 1, Adelina Complex	ABSENCE	ABSENCE	2
04/29/2025 11:52	S25-2745	Tawi Tawi St. South City Homes	ABSENCE	ABSENCE	< 1
04/29/2025 11:20	S25-2743	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	2
04/29/2025 11:38	S25-2744	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
04/29/2025 09:10	S25-2751	Water Pump, Town & Country, Amsterdam St.	ABSENCE	ABSENCE	< 1
04/29/2025 09:22	S25-2752	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	1
04/29/2025 09:48	S25-2753	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	< 1
04/29/2025 10:12	S25-2754	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	18
04/29/2025 10:19	S25-2755	Blk 1 Lt 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO					
04/10/2025 13:10	S25-2343	#76 Manila S Road	ABSENCE	ABSENCE	4
04/10/2025 12:48	S25-2444	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO					
04/15/2025 09:09	S25-2505	Gate Entrance, San Antonio South	ABSENCE	ABSENCE	< 1
BRGY. ZAPOTE					
04/02/2025 10:29	S25-2077	Water Pump, Summer Breeze	ABSENCE	ABSENCE	40

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:

 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
04/02/2025 10:43	S25-2078	Clubhouse, Summer Breeze	ABSENCE	ABSENCE	4
04/02/2025 09:42	S25-2080	Clubhouse, Evergreen	ABSENCE	ABSENCE	< 1
04/02/2025 09:20	S25-2079	Elevated Water Tank, Evergreen	ABSENCE	ABSENCE	26
04/02/2025 13:15	S25-2086	Water Pump, Jubilation Village - West	ABSENCE	ABSENCE	6
04/29/2025 09:30	S25-2739	Clubhouse, Jubilation Home Village – West	ABSENCE	ABSENCE	2
04/02/2025 10:58	S25-2088	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	< 1
04/02/2025 11:14	S25-2089	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	3
04/15/2025 11:29	S25-2501	Clubhouse, Althea Residences	ABSENCE	ABSENCE	1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)