

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 76

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 07/12/2021 – 07/28/2021

| DATE/TIME COLLECTED | SAMPLE CODE | SAMPLE LOCATION | PARAMETER | | | | |
|-----------------------|-------------|---|---|---|--------------------------------|--|------------------------------|
| | | | pH/ Temperature ^A (- / °C) | RESIDUAL CHLORINE ^B (mg/L) | COLIFORM ^C | | HPC ^D (CFU/mL) |
| | | | | | TOTAL (Coliforms/ 100mL) | FECAL/ <i>E. coli</i> (Coliforms/ 100 mL) | |
| BRGY. BIÑAN | | | | | | | |
| 07/23/2021 11:40 | S21-5368 | Laguna Wellfield 1 | 7.51 / 28.6 | 0.88 | ABSENCE | ABSENCE | < 1 |
| 07/21/2021 13:28 | S21-5299 | Guardhouse Entrance, Phase 4C, San Jose Village I | 7.60 / 28.9 | 0.35 | ABSENCE | ABSENCE | < 1 |
| 07/21/2021 13:41 | S21-5300 | Clubhouse, Phase 3B, San Jose Village II | 7.65 / 29.0 | 0.29 | ABSENCE | ABSENCE | < 1 |
| 07/21/2021 12:55 | S21-5301 | Pump 11, Phase 5, San Jose Village II | 7.70 / 28.5 | 0.20 | ABSENCE | ABSENCE | < 1 |
| 07/21/2021 12:41 | S21-5302 | Clubhouse, Phase 5, San Jose Village II | 7.71 / 29.1 | 0.16 | ABSENCE | ABSENCE | < 1 |
| 07/21/2021 12:38 | S21-5303 | Clubhouse, Phase 6, San Jose Village III | 7.65 / 28.5 | 0.18 | ABSENCE | ABSENCE | < 1 |
| 07/21/2021 14:16 | S21-5304 | Main Gate, AVIDA Shophouse | 7.66 / 27.5 | 0.38 | ABSENCE | ABSENCE | < 1 |
| 07/21/2021 12:21 | S21-5305 | DLSU Science and Technology Complex, LTI Spine Road | 7.65 / 28.5 | 0.20 | ABSENCE | ABSENCE | < 1 |
| BRGY. CANLALAY | | | | | | | |
| 07/12/2021 14:08 | S21-4969 | Clubhouse, Golden City Subdivision | 7.40 / 30.6 | 0.51 | ABSENCE | ABSENCE | < 1 |
| 07/12/2021 14:26 | S21-4970 | Drinking Fountain, Canlalay Elementary School | 7.33 / 29.2 | 0.13 | ABSENCE | ABSENCE | < 1 |
| BRGY. DELA PAZ | | | | | | | |
| 07/12/2021 13:39 | S21-4975 | Water Pump, Almeda Subdivision | 7.53 / 29.3 | 0.13 | ABSENCE | ABSENCE | < 1 |
| BRGY. GANADO | | | | | | | |
| 07/13/2021 11:05 | S21-5081 | Ganado Elementary School | 7.53 / 30.1 | 0.21 | ABSENCE | ABSENCE | < 1 |
| BRGY. HALANG | | | | | | | |
| 07/12/2021 14:43 | S21-4965 | 9999 Water Pump Metroville Complex | 7.21 / 28.8 | 0.21 | ABSENCE | ABSENCE | < 1 |
| 07/12/2021 14:55 | S21-4966 | Block 30 Lot 17, Metroville Complex | 7.22 / 30.1 | 0.11 | ABSENCE | ABSENCE | < 1 |
| BRGY. LANGKIWA | | | | | | | |
| 07/15/2021 13:35 | S21-5167 | Reyes Residence, Phase II, Southville | 7.45 / 30.4 | 0.28 | ABSENCE | ABSENCE | 5 |

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

| DATE/TIME COLLECTED | SAMPLE CODE | SAMPLE LOCATION | PARAMETER | | | | |
|------------------------|-------------|---|---|---|--------------------------------|--|------------------------------|
| | | | pH/ Temperature ^A (- / °C) | RESIDUAL CHLORINE ^B (mg/L) | COLIFORM ^C | | HPC ^D (CFU/mL) |
| | | | | | TOTAL (Coliforms/ 100mL) | FECAL/ <i>E. coli</i> (Coliforms/ 100 mL) | |
| | | | MDL: NA LOQ: NA | MDL: 0.06 LOQ: 0.20 | | | |
| 07/21/2021 11:10 | S21-5309 | Drinking Fountain, Southville 5A National High School | 7.68 / 27.5 | 0.25 | ABSENCE | ABSENCE | 2 |
| 07/21/2021 10:40 | S21-5310 | Drinking Fountain, Langkiwa Elementary School | 7.66 / 28.9 | 0.16 | ABSENCE | ABSENCE | < 1 |
| BRGY. LOMA | | | | | | | |
| 07/21/2021 12:05 | S21-5306 | Block 43 Lot 13, Celina Technopark | 7.68 / 27.6 | 0.28 | ABSENCE | ABSENCE | < 1 |
| 07/22/2021 08:59 | S21-5350 | Brenna Model House, Laguna Bel-Air III | 7.61 / 29.7 | 0.28 | ABSENCE | ABSENCE | 3 |
| 07/22/2021 09:20 | S21-5351 | Hillcrest Road, Block 2 Laguna Bel-Air III | 7.55 / 28.6 | 0.23 | ABSENCE | ABSENCE | 5 |
| 07/22/2021 09:35 | S21-5352 | Clubhouse, Laguna Bel-Air III | 7.47 / 28.4 | 0.25 | ABSENCE | ABSENCE | 2 |
| 07/21/2021 11:26 | S21-5308 | Drinking Fountain, Loma Elementary | 7.65 / 27.6 | 0.31 | ABSENCE | ABSENCE | < 1 |
| BRGY. MAMPLASAN | | | | | | | |
| 07/21/2021 11:38 | S21-5307 | Clubhouse, Verdana Homes Subdivision | 7.67 / 28.9 | 0.30 | ABSENCE | ABSENCE | < 1 |
| 07/13/2021 11:22 | S21-5082 | United Laboratories (UNILAB) Inc. | 7.50 / 30.7 | 0.25 | ABSENCE | ABSENCE | 2 |
| BRGY. POBLACION | | | | | | | |
| 07/12/2021 13:19 | S21-4976 | Barangay Hall | 7.20 / 30.6 | 0.05 | ABSENCE | ABSENCE | < 1 |
| BRGY. PLATERO | | | | | | | |
| 07/19/2021 13:15 | S21-5260 | Elevated Water Tank, Mondo Bambini | 7.50 / 29.0 | 0.42 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 13:25 | S21-5261 | Clubhouse, Mondo Bambini | 7.50 / 29.7 | 0.30 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 14:25 | S21-5262 | Elevated Water Tank, Prima Casa | 7.78 / 30.0 | 0.38 | ABSENCE | ABSENCE | 1 |
| 07/19/2021 14:35 | S21-5263 | Clubhouse, Prima Casa | 7.74 / 30.0 | 0.27 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 14:49 | S21-5264 | Water Pump, Spring Time | 7.49 / 29.8 | 0.16 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 15:09 | S21-5265 | Block 7 Lot 10, Spring Time | 7.59 / 29.9 | 0.13 | ABSENCE | ABSENCE | < 1 |
| 07/13/2021 08:20 | S21-5084 | Sea-oil, National Road | 7.62 / 30.4 | 0.30 | ABSENCE | ABSENCE | < 1 |
| 07/13/2021 09:04 | S21-5086 | Drinking Fountain, St. Michael School | 7.40 / 30.7 | 0.12 | ABSENCE | ABSENCE | 90 |
| 07/19/2021 15:22 | S21-5266 | Tank 2, Jubilation Village - West | 7.66 / 28.0 | 0.13 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 15:32 | S21-5267 | Clubhouse, Jubilation Village - West | 7.63 / 30.0 | 0.09 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 14:03 | S21-5270 | Water Pump, Jubilation Village - East | 7.67 / 29.4 | 0.15 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 14:13 | S21-5271 | Clubhouse, Jubilation Village - East | 7.60 / 30.7 | 0.09 | ABSENCE | ABSENCE | < 1 |

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

| DATE/TIME COLLECTED | SAMPLE CODE | SAMPLE LOCATION | PARAMETER | | | | |
|--------------------------|-------------|--|---|---|--------------------------------|--|------------------------------|
| | | | pH/ Temperature ^A (- / °C) | RESIDUAL CHLORINE ^B (mg/L) | COLIFORM ^C | | HPC ^D (CFU/mL) |
| | | | | | TOTAL (Coliforms/ 100mL) | FECAL/ <i>E. coli</i> (Coliforms/ 100 mL) | |
| | | | MDL: NA LOQ: NA | MDL: 0.06 LOQ: 0.20 | | | |
| BRGY. SAN ANTONIO | | | | | | | |
| 07/13/2021 12:17 | S21-5092 | Water Pump, Biñan City Hall | 7.35 / 30.2 | 0.60 | ABSENCE | ABSENCE | < 1 |
| 07/13/2021 12:03 | S21-5093 | Alonte Stadium | 7.55 / 30.3 | 0.53 | ABSENCE | ABSENCE | 3 |
| 07/13/2021 09:31 | S21-5087 | Water Pump, Margarita Homes Subdivision | 7.37 / 30.1 | 0.32 | ABSENCE | ABSENCE | < 1 |
| 07/13/2021 09:47 | S21-5088 | Ibanez Residence, Margarita Homes | 7.40 / 30.3 | 0.30 | ABSENCE | ABSENCE | < 1 |
| 07/12/2021 12:10 | S21-4971 | 9022 Water Pump, Faraon Subdivision | 7.64 / 30.0 | 0.52 | ABSENCE | ABSENCE | < 1 |
| 07/12/2021 11:48 | S21-4977 | Drinking Fountain, Jacobo Gonzales Memorial National High School | 7.27 / 31.1 | 0.05 | ABSENCE | ABSENCE | 10 |
| 07/13/2021 10:16 | S21-5089 | Cistern Tank, Pavilion Mall | 7.37 / 29.9 | 0.25 | ABSENCE | ABSENCE | < 1 |
| 07/13/2021 10:34 | S21-5090 | Reyes Barbecue, Pavilion Mall | 7.52 / 30.1 | 0.19 | ABSENCE | ABSENCE | 50 |
| 07/12/2021 12:26 | S21-4972 | Malaban Health Center | 7.64 / 30.6 | 0.54 | ABSENCE | ABSENCE | < 1 |
| 07/12/2021 12:56 | S21-4973 | Drinking Fountain 1, Malaban Elementary School | 7.59 / 31.6 | 0.50 | ABSENCE | ABSENCE | 2 |
| 07/12/2021 13:02 | S21-4974 | Drinking Fountain 2, Malaban Elementary School | 7.61 / 30.4 | 0.69 | ABSENCE | ABSENCE | 4 |
| BRGY. SANTO NIÑO | | | | | | | |
| 07/13/2021 11:49 | S21-5091 | Jollibee National Hi-Way | 7.61 / 30.6 | 0.32 | ABSENCE | ABSENCE | < 1 |
| BRGY. SAN VICENTE | | | | | | | |
| 07/13/2021 12:39 | S21-5094 | 407 Water Pump, San Vicente Subdivision | 7.47 / 30.7 | 0.14 | ABSENCE | ABSENCE | < 1 |
| 07/15/2021 10:15 | S21-5168 | Drinking Fountain, San Vicente Elementary School | 7.61 / 30.1 | 0.13 | ABSENCE | ABSENCE | < 1 |
| 07/15/2021 10:36 | S21-5169 | Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes | 7.60 / 29.7 | 0.27 | ABSENCE | ABSENCE | 2 |
| 07/15/2021 11:01 | S21-5170 | Cistern Tank, Central Mall | 7.55 / 30.1 | 0.30 | ABSENCE | ABSENCE | < 1 |
| 07/13/2021 08:47 | S21-5085 | Biñan Doctor's Hospital | 7.47 / 30.1 | 0.18 | ABSENCE | ABSENCE | < 1 |
| BRGY. SANTO TOMAS | | | | | | | |
| 07/13/2021 13:20 | S21-5083 | Water Pump, Adelina Complex 3 | 7.61 / 30.3 | 0.17 | ABSENCE | ABSENCE | 3 |
| 07/13/2021 13:59 | S21-5094 | HOA Office, Adelina Complex | 7.41 / 30.3 | 0.16 | ABSENCE | ABSENCE | < 1 |
| 07/15/2021 11:59 | S21-5176 | Water Pump, Pragmatic Subdivision | 7.40 / 29.8 | 0.10 | ABSENCE | ABSENCE | 2 |
| 07/15/2021 12:09 | S21-5177 | Trinidad Residence, Bais St., Pragmatic | 7.55 / 30.7 | 0.07 | ABSENCE | ABSENCE | 1 |
| 07/15/2021 13:15 | S21-5165 | Tawi Tawi St., Phase 6, South City Homes | 7.61 / 30.1 | 0.27 | ABSENCE | ABSENCE | 4 |
| 07/15/2021 12:18 | S21-5163 | Water Pump, South Plains II Subdivision | 7.37 / 29.8 | 0.30 | ABSENCE | ABSENCE | 3 |
| 07/15/2021 12:44 | S21-5164 | Block 11 Lot 2, South Plains II Subdivision | 7.47 / 29.7 | 0.25 | ABSENCE | ABSENCE | < 1 |

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

| DATE/TIME COLLECTED | SAMPLE CODE | SAMPLE LOCATION | PARAMETER | | | | |
|--------------------------|-------------|--|---|---|--------------------------------|--|------------------------------|
| | | | pH/ Temperature ^A (- / °C) | RESIDUAL CHLORINE ^B (mg/L) | COLIFORM ^C | | HPC ^D (CFU/mL) |
| | | | | | TOTAL (Coliforms/ 100mL) | FECAL/ <i>E. coli</i> (Coliforms/ 100 mL) | |
| | | | MDL: NA LOQ: NA | MDL: 0.06 LOQ: 0.20 | | | |
| 07/15/2021 14:12 | S21-5171 | Water Pump, Town & Country, Amsterdam | 7.61 / 29.7 | 0.29 | ABSENCE | ABSENCE | 2 |
| 07/15/2021 14:25 | S21-5172 | Blk 35 Lt 21, Southville Town & Country | 7.55 / 30.1 | 0.23 | ABSENCE | ABSENCE | < 1 |
| 07/15/2021 14:40 | S21-5173 | Blk 2 Lt 5, Town & Country, Pennsylvania | 7.61 / 29.9 | 0.35 | ABSENCE | ABSENCE | < 1 |
| 07/15/2021 15:06 | S21-5174 | Water Pump, Phase 4, Olivarez Homes South | 7.55 / 30.7 | 0.22 | ABSENCE | ABSENCE | < 1 |
| 07/15/2021 15:20 | S21-5175 | Blk 1 Lt 16, Phase 4, Olivarez Homes South | 7.47 / 29.8 | 0.19 | ABSENCE | ABSENCE | 1 |
| BRGY. SORO – SORO | | | | | | | |
| 07/12/2021 15:33 | S21-4967 | Water Pump, 9067 Manila S Road | 7.24 / 29.3 | 0.76 | ABSENCE | ABSENCE | < 1 |
| 07/12/2021 15:25 | S21-4968 | #76 Manila S Road | 7.21 / 30.0 | 0.69 | ABSENCE | ABSENCE | < 1 |
| BRGY. TIMBAO | | | | | | | |
| 07/21/2021 10:15 | S21-5311 | Water Pump, San Antonio South | 7.60 / 27.5 | 0.21 | ABSENCE | ABSENCE | < 1 |
| 07/21/2021 10:19 | S21-5312 | Block 3 Lot 23, San Antonio South | 7.61 / 28.9 | 0.18 | ABSENCE | ABSENCE | < 1 |
| BRGY. TUBIGAN | | | | | | | |
| 07/15/2021 11:33 | S21-5166 | #60 Florinda Compound | 7.55 / 30.3 | 0.18 | ABSENCE | ABSENCE | < 1 |
| BRGY. ZAPOTE | | | | | | | |
| 07/19/2021 12:29 | S21-5256 | Water Pump, Summer Breeze | 7.38 / 29.1 | 0.45 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 12:35 | S21-5257 | Clubhouse, Summer Breeze | 7.31 / 30.9 | 0.46 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 12:51 | S21-5258 | Elevated Water Tank, Evergreen | 7.52 / 29.1 | 0.98 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 13:01 | S21-5259 | Clubhouse, Evergreen | 7.33 / 28.7 | 0.38 | ABSENCE | ABSENCE | < 1 |
| 07/26/2021 16:05 | S21-5386 | Clubhouse, Althea Residences | 7.28 / 28.2 | 0.08 | ABSENCE | ABSENCE | 66 |
| 07/19/2021 13:42 | S21-5268 | Water Pump, Jubilation Village - South | 7.50 / 28.9 | 0.41 | ABSENCE | ABSENCE | < 1 |
| 07/19/2021 13:51 | S21-5269 | Clubhouse, Jubilation Village - South | 7.60 / 31.5 | 0.18 | ABSENCE | ABSENCE | < 1 |

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.