

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 78

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 06/03/2021 – 06/30/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. BIÑAN							
06/03/2021 11:12	S21-4104	Laguna Wellfield 1	-	0.48	ABSENCE	ABSENCE	< 1
06/03/2021 16:59	S21-4142	Guardhouse Entrance, Phase 4C, San Jose Village I	7.49 / 27.5	0.36	ABSENCE	ABSENCE	< 1
06/03/2021 17:11	S21-4143	Clubhouse, Phase 3B, San Jose Village II	7.55 / 28.6	0.28	ABSENCE	ABSENCE	< 1
06/03/2021 16:28	S21-4144	Pump 11, Phase 5, San Jose Village II	7.56 / 27.5	0.32	ABSENCE	ABSENCE	< 1
06/03/2021 16:36	S21-4145	Clubhouse, Phase 5, San Jose Village II	7.55 / 28.5	0.34	ABSENCE	ABSENCE	< 1
06/03/2021 16:48	S21-4146	Clubhouse, Phase 6, San Jose Village III	7.55 / 27.1	0.38	ABSENCE	ABSENCE	< 1
06/03/2021 17:16	S21-4147	Main Gate, AVIDA Shophouse	7.59 / 28.1	0.40	ABSENCE	ABSENCE	< 1
06/03/2021 16:00	S21-4148	DLSU Science and Technology Complex, LTI Spine Road	7.65 / 27.1	0.32	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY							
06/03/2021 14:50	S21-4170	Clubhouse, Golden City Subdivision	-	0.61	ABSENCE	ABSENCE	10
06/03/2021 14:36	S21-4171	Drinking Fountain, Canlalay Elementary School	-	0.41	ABSENCE	ABSENCE	30
BRGY. DELA PAZ							
06/03/2021 15:11	S21-4174	Water Pump, Almada Subdivision	-	0.09	ABSENCE	ABSENCE	< 1
BRGY. GANADO							
06/03/2021 11:01	S21-4127	Ganado Elementary School	7.47 / 30.7	0.12	ABSENCE	ABSENCE	< 1
BRGY. HALANG							
06/03/2021 14:11	S21-4166	9999 Water Pump Metroville Complex	-	0.36	ABSENCE	ABSENCE	< 1
06/03/2021 14:17	S21-4167	Block 30 Lot 17, Metroville Complex	-	0.13	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
06/09/2021 10:21	S21-4301	Reyes Residence, Phase II, Southville	7.61 / 30.4	0.30	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE S. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
06/03/2021 14:39	S21-4152	Drinking Fountain, Southville 5A National High School	7.52 / 27.5	0.25	ABSENCE	ABSENCE	< 1
06/03/2021 14:28	S21-4153	Drinking Fountain, Langkiwa Elementary School	7.69 / 28.9	0.31	ABSENCE	ABSENCE	< 1
BRGY. LOMA							
06/03/2021 15:45	S21-4149	Block 43 Lot 13, Celina Technopark	7.60 / 27.1	0.29	ABSENCE	ABSENCE	< 1
06/29/2021 12:30	S21-4656	Brenna Model House, Laguna Bel-Air III	7.64 / 29.7	0.35	ABSENCE	ABSENCE	-
06/29/2021 13:00	S21-4657	Hillcrest Road, Block 2 Laguna Bel-Air III	7.65 / 29.5	0.27	ABSENCE	ABSENCE	-
06/29/2021 13:15	S21-4658	Clubhouse, Laguna Bel-Air III	7.55 / 29.7	0.25	ABSENCE	ABSENCE	-
06/05/2021 15:47	S21-4189	Drinking Fountain, Loma Elementary	7.57 / 30.6	0.30	ABSENCE	ABSENCE	5
BRGY. MAMPLASAN							
06/03/2021 15:25	S21-4150	Clubhouse, Verdana Homes Subdivision	7.48 / 27.8	0.40	ABSENCE	ABSENCE	< 1
06/03/2021 11:16	S21-4128	United Laboratories (UNILAB) Inc.	7.55 / 29.7	0.15	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
06/12/2021 15:02	S21-4354	Water Pump	-	0.03	ABSENCE	ABSENCE	-
06/03/2021 15:27	S21-4175	Barangay Hall	-	0.06	ABSENCE	ABSENCE	< 1
BRGY. PLATERO							
06/09/2021 10:19	S21-4316	Elevated Water Tank, Mondo Bambini	-	0.41	ABSENCE	ABSENCE	< 1
06/09/2021 10:27	S21-4317	Clubhouse, Mondo Bambini	-	0.17	ABSENCE	ABSENCE	10
06/09/2021 11:47	S21-4318	Elevated Water Tank, Prima Casa	-	0.19	ABSENCE	ABSENCE	100
06/09/2021 11:56	S21-4319	Clubhouse, Prima Casa	-	0.22	ABSENCE	ABSENCE	< 1
06/09/2021 12:09	S21-4320	Water Pump, Spring Time	-	0.12	ABSENCE	ABSENCE	< 1
06/09/2021 12:24	S21-4321	Block 7 Lot 10, Spring Time	-	0.08	ABSENCE	ABSENCE	< 1
06/03/2021 11:28	S21-4130	Sea-oil, National Road	7.35 / 29.7	0.25	ABSENCE	ABSENCE	< 1
06/03/2021 11:59	S21-4132	Drinking Fountain, St. Michael School	7.45 / 29.8	0.10	ABSENCE	ABSENCE	< 1
06/12/2021 15:20	S21-4352	Tank, Jubilation Village - West	-	0.12	ABSENCE	ABSENCE	-
06/12/2021 15:31	S21-4353	Clubhouse, Jubilation Village - West	-	0.07	ABSENCE	ABSENCE	-
06/09/2021 11:28	S21-4324	Water Pump, Jubilation Village - East	-	0.15	ABSENCE	ABSENCE	< 1
06/09/2021 11:36	S21-4325	Clubhouse, Jubilation Village - East	-	0.10	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. SAN ANTONIO							
06/03/2021 14:17	S21-4138	Water Pump, Biñan City Hall	7.41 / 29.6	0.20	ABSENCE	ABSENCE	< 1
06/03/2021 14:28	S21-4139	Alonte Stadium	7.64 / 30.7	0.30	ABSENCE	ABSENCE	< 1
06/03/2021 12:16	S21-4133	Water Pump, Margarita Homes Subdivision	7.61 / 30.7	0.30	ABSENCE	ABSENCE	< 1
06/03/2021 12:32	S21-4134	Ibanez Residence, Margarita Homes	7.55 / 29.7	0.32	ABSENCE	ABSENCE	< 1
06/03/2021 15:55	S21-4172	9022 Water Pump, Faraon Subdivision	-	1.67	ABSENCE	ABSENCE	< 1
06/05/2021 14:35	S21-4191	Drinking Fountain, Jacobo Gonzales Memorial National High School	-	0.50	ABSENCE	ABSENCE	2
06/03/2021 12:59	S21-4135	Cistern Tank, Pavilion Mall	7.61 / 30.7	0.65	ABSENCE	ABSENCE	< 1
06/03/2021 13:14	S21-4136	Reyes Barbecue, Pavilion Mall	7.35 / 29.3	0.50	ABSENCE	ABSENCE	2
06/03/2021 15:44	S21-4173	Malaban Health Center	-	0.81	ABSENCE	ABSENCE	2
BRGY. SANTO NIÑO							
06/03/2021 13:26	S21-4137	Jollibee National Hi-Way	7.55 / 30.7	0.25	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
06/03/2021 13:50	S21-4140	407 Water Pump, San Vicente Subdivision	7.41 / 30.7	0.10	ABSENCE	ABSENCE	< 1
06/09/2021 13:52	S21-4302	Drinking Fountain, San Vicente Elementary School	7.46 / 30.7	0.20	ABSENCE	ABSENCE	< 1
06/09/2021 12:02	S21-4303	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.61 / 29.8	0.21	ABSENCE	ABSENCE	< 1
06/09/2021 15:02	S21-4304	Cistern Tank, Central Mall	7.55 / 30.3	0.18	ABSENCE	ABSENCE	< 1
06/03/2021 11:42	S21-4131	Biñan Doctor's Hospital	7.61 / 30.8	0.14	ABSENCE	ABSENCE	6
BRGY. SANTO TOMAS							
06/03/2021 14:45	S21-4129	Water Pump, Adelina Complex 3	7.60 / 30.7	0.18	ABSENCE	ABSENCE	< 1
06/03/2021 14:41	S21-4141	HOA Office, Adelina Complex	7.55 / 30.6	0.12	ABSENCE	ABSENCE	< 1
06/09/2021 12:29	S21-4310	Water Pump, Pragmatic Subdivision	7.47 / 30.6	0.08	ABSENCE	ABSENCE	< 1
06/09/2021 12:36	S21-4311	Block 1 Lot 5, Bais St., Pragmatic	7.45 / 30.5	0.06	ABSENCE	ABSENCE	< 1
06/09/2021 12:59	S21-4299	Tawi Tawi St., Phase 6, South City Homes	7.41 / 30.3	0.27	ABSENCE	ABSENCE	< 1
06/09/2021 13:18	S21-4297	Water Pump, South Plains II Subdivision	7.61 / 30.7	0.35	ABSENCE	ABSENCE	< 1
06/09/2021 13:35	S21-4298	Block 11 Lot 2, South Plains II Subdivision	7.55 / 30.4	0.32	ABSENCE	ABSENCE	< 1
06/09/2021 10:42	S21-4305	Water Pump, Town & Country, Amsterdam	7.55 / 29.8	0.37	ABSENCE	ABSENCE	1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20						
06/09/2021 10:59	S21-4306	Blk 35 Lt 21, Southville Town & Country	7.51 / 30.4	0.35	ABSENCE	ABSENCE	< 1
06/09/2021 11:12	S21-4307	Blk 2 Lt 5, Town & Country, Pennsylvania	7.66 / 29.7	0.25	ABSENCE	ABSENCE	< 1
06/09/2021 11:28	S21-4308	Water Pump, Phase 4, Olivarez Homes South	7.45 / 30.1	0.30	ABSENCE	ABSENCE	< 1
06/09/2021 11:43	S21-4309	Blk 1 Lt 16, Phase 4, Olivarez Homes South	7.55 / 30.7	0.27	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO							
06/03/2021 13:49	S21-4168	Water Pump, 9067 Manila S Road	-	1.75	ABSENCE	ABSENCE	< 1
06/03/2021 13:55	S21-4169	#76 Manila S Road	-	1.73	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO							
06/03/2021 14:10	S21-4154	Water Pump, San Antonio South	7.60 / 27.3	0.18	ABSENCE	ABSENCE	< 1
06/03/2021 14:01	S21-4155	Block 3 Lot 23, San Antonio South	7.65 / 28.0	0.28	ABSENCE	ABSENCE	< 1
BRGY. TUBIGAN							
06/09/2021 14:20	S21-4300	#60 Florinda Compound	7.55 / 30.4	0.19	ABSENCE	ABSENCE	< 1
BRGY. ZAPOTE							
06/14/2021 08:50	S21-4356	Water Pump, Summer Breeze	-	0.47	ABSENCE	ABSENCE	3
06/09/2021 09:45	S21-4313	Clubhouse, Summer Breeze	-	0.40	ABSENCE	ABSENCE	< 1
06/09/2021 09:59	S21-4314	Elevated Water Tank, Evergreen	-	0.86	ABSENCE	ABSENCE	< 1
06/09/2021 10:07	S21-4315	Clubhouse, Evergreen	-	0.44	ABSENCE	ABSENCE	< 1
06/12/2021 14:10	S21-4350	Water Pump, Althea Residences	-	0.27	ABSENCE	ABSENCE	-
06/12/2021 14:25	S21-4351	Clubhouse, Althea Residences	-	0.56	ABSENCE	ABSENCE	-
06/12/2021 14:34	S21-4355	Water Pump, Jubilation Village - South	-	0.21	ABSENCE	ABSENCE	3
06/09/2021 11:11	S21-4323	Clubhouse, Jubilation Village - South	-	0.30	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.