

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 78

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 05/03/2021 – 05/24/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
		TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)				
BRGY. BIÑAN							
05/03/2021 16:00	S21-3223	Laguna Wellfield 1	7.51 / 27.8	0.67	ABSENCE	ABSENCE	< 1
05/20/2021 13:59	S21-3857	Guardhouse Entrance, Phase 4C, San Jose Village I	7.44 / 27.6	0.37	ABSENCE	ABSENCE	-
05/20/2021 14:11	S21-3858	Clubhouse, Phase 3B, San Jose Village II	7.48 / 28.9	0.36	ABSENCE	ABSENCE	-
05/20/2021 13:48	S21-3859	Pump 11, Phase 5, San Jose Village II	7.46 / 27.5	0.41	ABSENCE	ABSENCE	-
05/20/2021 13:18	S21-3860	Clubhouse, Phase 5, San Jose Village II	7.50 / 27.7	0.34	ABSENCE	ABSENCE	-
05/20/2021 13:31	S21-3861	Clubhouse, Phase 6, San Jose Village III	7.51 / 28.1	0.38	ABSENCE	ABSENCE	-
05/20/2021 14:28	S21-3862	Main Gate, AVIDA Shophouse	7.48 / 27.1	0.41	ABSENCE	ABSENCE	-
05/20/2021 12:39	S21-3863	DLSU Science and Technology Complex, LTI Spine Road	7.30 / 27.5	0.38	ABSENCE	ABSENCE	-
BRGY. CANLALAY							
05/17/2021 13:04	S21-3678	Clubhouse, Golden City Canlalay	-	0.31	ABSENCE	ABSENCE	200
05/17/2021 13:27	S21-3679	Drinking Fountain, Canlalay Elementary School	-	0.11	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ							
05/17/2021 12:58	S21-3682	Water Pump, Almeda Subdivision	-	0.10	ABSENCE	ABSENCE	< 1
BRGY. GANADO							
05/19/2021 16:17	S21-3814	Ganado Elementary School	7.55 / 30.7	0.22	ABSENCE	ABSENCE	< 1
BRGY. HALANG							
05/17/2021 13:57	S21-3674	9999 Water Pump Metroville Complex	-	0.23	ABSENCE	ABSENCE	< 1
05/17/2021 14:05	S21-3675	Block 30 Lot 17, Metroville Complex	-	0.144	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
05/18/2021 09:10	S21-3743	Block 3 Lot 9, Phase II, Southville	7.62 / 30.7	0.22	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20						
05/20/2021 11:12	S21-3867	Drinking Fountain, Southville 5A National High School	7.51 / 28.5	0.44	ABSENCE	ABSENCE	-
05/20/2021 11:20	S21-3868	Drinking Fountain, Langkiwa Elementary School	7.54 / 28.5	0.30	ABSENCE	ABSENCE	-
BRGY. LOMA							
05/20/2021 12:18	S21-3864	Block 43 Lot 13, Celina Technopark	7.31 / 27.6	0.29	ABSENCE	ABSENCE	-
05/20/2021 11:49	S21-3880	Brenna Model House, Laguna Bel-Air III	7.55 / 29.6	0.27	ABSENCE	ABSENCE	-
05/20/2021 13:13	S21-3881	Hillcrest Road, Block 2 Laguna Bel-Air III	7.55 / 29.7	0.30	ABSENCE	ABSENCE	-
05/20/2021 14:10	S21-3882	Clubhouse, Laguna Bel-Air III	7.50 / 30.7	0.35	ABSENCE	ABSENCE	-
05/20/2021 11:59	S21-3866	Drinking Fountain, Loma Elementary	7.50 / 28.1	0.29	ABSENCE	ABSENCE	-
BRGY. MAMPLASAN							
05/20/2021 11:40	S21-3865	Clubhouse, Verdana Homes Subdivision	7.46 / 27.5	0.36	ABSENCE	ABSENCE	-
05/19/2021 16:35	S21-3815	United Laboratories (UNILAB) Inc.	7.61 / 30.3	0.17	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
05/23/2021 13:01	S21-3887	Water Pump	-	0.07	ABSENCE	ABSENCE	-
05/17/2021 12:40	S21-3683	Barangay Hall	-	0.07	ABSENCE	ABSENCE	< 1
BRGY. PLATERO							
05/06/2021 12:02	S21-3337	Elevated Water Tank, Mondo Bambini	-	0.51	ABSENCE	ABSENCE	-
05/06/2021 12:10	S21-3338	Clubhouse, Mondo Bambini	-	0.14	ABSENCE	ABSENCE	-
05/06/2021 13:01	S21-3339	Elevated Water Tank, Prima Casa	-	0.22	ABSENCE	ABSENCE	-
05/06/2021 13:08	S21-3340	Clubhouse, Prima Casa	-	0.18	ABSENCE	ABSENCE	-
05/06/2021 13:22	S21-3341	Water Pump, Spring Time	-	0.22	ABSENCE	ABSENCE	-
05/06/2021 13:29	S21-3342	Block 7 Lot 10, Spring Time	-	0.11	ABSENCE	ABSENCE	-
05/19/2021 16:49	S21-3817	Sea-oil, National Road	7.47 / 29.7	0.27	ABSENCE	ABSENCE	< 1
05/19/2021 17:10	S21-3819	Drinking Fountain, St. Michael School	7.53 / 30.7	0.15	ABSENCE	ABSENCE	< 1
05/06/2021 14:16	S21-3345	Water Pump, Jubilation Village - South	-	0.26	ABSENCE	ABSENCE	-
05/06/2021 14:27	S21-3346	Clubhouse, Jubilation Village - South	-	0.16	ABSENCE	ABSENCE	-
05/06/2021 13:54	S21-3343	Tank 2, Jubilation Village - West	-	0.15	ABSENCE	ABSENCE	-
05/06/2021 14:03	S21-3344	Clubhouse, Jubilation Village - West	-	0.07	ABSENCE	ABSENCE	-
05/06/2021 12:40	S21-3347	Water Pump, Jubilation Village - East	-	0.15	ABSENCE	ABSENCE	-
05/06/2021 12:48	S21-3348	Clubhouse, Jubilation Village - East	-	0.16	ABSENCE	ABSENCE	-

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. SAN ANTONIO							
05/19/2021 15:17	S21-3825	Water Pump, Bifian City Hall	7.65 / 30.6	0.10	ABSENCE	ABSENCE	< 1
05/19/2021 15:31	S21-3826	Alonte Stadium	7.51 / 30.7	0.12	ABSENCE	ABSENCE	< 1
05/19/2021 17:33	S21-3820	Water Pump, Margarita Homes Subdivision	7.63 / 30.7	0.30	ABSENCE	ABSENCE	3
05/19/2021 17:20	S21-3821	Ibanez Residence, Margarita Homes	7.61 / 29.8	0.28	ABSENCE	ABSENCE	380
05/17/2021 12:24	S21-3680	9022 Water Pump, Faraon Subdivision	-	0.34	ABSENCE	ABSENCE	< 1
05/17/2021 12:11	S21-3684	Wellness Park, Jacobo Gonzales Memorial National High School	-	0.17	ABSENCE	ABSENCE	< 1
05/19/2021 14:27	S21-3822	Cistern Tank, Pavilion Mall	7.52 / 29.7	0.20	ABSENCE	ABSENCE	10
05/19/2021 14:39	S21-3823	Bonchon, Pavilion Mall	7.61 / 30.7	0.15	ABSENCE	ABSENCE	< 1
05/17/2021 12:07	S21-3681	Malaban Health Center	-	0.47	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO							
05/19/2021 14:59	S21-3824	Jollibee National Hi-Way	7.66 / 30.7	0.25	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
05/19/2021 15:48	S21-3829	407 Water Pump, San Vicente Subdivision	7.61 / 29.8	0.08	ABSENCE	ABSENCE	< 1
05/18/2021 12:18	S21-3744	Drinking Fountain, San Vicente Elementary School	7.66 / 30.7	0.10	ABSENCE	ABSENCE	1
05/18/2021 12:42	S21-3745	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.55 / 29.6	0.17	ABSENCE	ABSENCE	< 1
05/18/2021 14:45	S21-3746	Cistern Tank, Central Mall	7.55 / 29.6	0.12	ABSENCE	ABSENCE	< 1
05/19/2021 16:55	S21-3818	Biñan Doctor's Hospital	7.51 / 30.6	0.20	ABSENCE	ABSENCE	< 1
BRGY. SANTO TOMAS							
05/19/2021 10:10	S21-3816	Water Pump, Adelina Complex 3	7.59 / 30.8	0.20	ABSENCE	ABSENCE	< 1
05/19/2021 09:10	S21-3828	HOA Office, Adelina Complex	7.60 / 30.6	0.10	ABSENCE	ABSENCE	< 1
05/18/2021 13:16	S21-3752	Water Pump, Pragmatic Subdivision	7.51 / 30.7	0.08	ABSENCE	ABSENCE	< 1
05/18/2021 13:37	S21-3753	Gomez Residence, Bais St., Pragmatic	7.61 / 30.6	0.04	ABSENCE	ABSENCE	< 1
05/18/2021 11:58	S21-3741	Tawi Tawi St., Phase 6, South City Homes	7.55 / 30.7	0.20	ABSENCE	ABSENCE	< 1
05/18/2021 11:01	S21-3739	Water Pump, South Plains II Subdivision	7.61 / 30.1	0.30	ABSENCE	ABSENCE	3
05/18/2021 11:15	S21-3740	Block 11 Lot 2, South Plains II Subdivision	7.60 / 30.4	0.27	ABSENCE	ABSENCE	< 1
05/18/2021 10:17	S21-3747	Water Pump, Town & Country, Amsterdam	7.66 / 30.7	0.35	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20						
05/18/2021 10:39	S21-3748	Blk 35 Lt 21, Southville Town & Country	7.55 / 29.7	0.31	ABSENCE	ABSENCE	< 1
05/18/2021 10:25	S21-3749	Blk 2 Lt 5, Town & Country, Pennsylvania	7.55 / 30.8	0.25	ABSENCE	ABSENCE	< 1
05/18/2021 09:32	S21-3750	Water Pump, Phase 4, Olivarez Homes South	7.60 / 30.5	0.18	ABSENCE	ABSENCE	< 1
05/18/2021 09:57	S21-3751	Blk 1 Lt 16, Phase 4, Olivarez Homes South	7.55 / 30.5	0.15	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO							
05/17/2021 14:46	S21-3676	Water Pump, 9067 Manila S Road	-	1.18	ABSENCE	ABSENCE	< 1
05/17/2021 14:37	S21-3677	#76 Manila S Road	-	1.11	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO							
05/20/2021 10:55	S21-3869	Water Pump, San Antonio South	7.48 / 27.6	0.14	ABSENCE	ABSENCE	-
05/20/2021 10:41	S21-3870	Block 21 Lot 29, San Antonio South	7.44 / 27.6	0.12	ABSENCE	ABSENCE	-
BRGY. TUBIGAN							
05/18/2021 14:04	S21-3742	#60 Florinda Compound	7.50 / 29.8	0.18	ABSENCE	ABSENCE	< 1
BRGY. ZAPOTE							
05/06/2021 12:21	S21-3333	Water Pump, Summer Breeze	-	0.65	ABSENCE	ABSENCE	-
05/06/2021 12:27	S21-3334	Clubhouse, Summer Breeze	-	0.59	ABSENCE	ABSENCE	-
05/06/2021 11:42	S21-3335	Elevated Water Tank, Evergreen	-	0.37	ABSENCE	ABSENCE	-
05/06/2021 11:50	S21-3336	Clubhouse, Evergreen	-	0.44	ABSENCE	ABSENCE	-
05/23/2021 13:37	S21-3888	Water Pump, Althea Residences	-	2.63	ABSENCE	ABSENCE	-
05/23/2021 13:48	S21-3889	Clubhouse, Althea Residences	-	2.94	ABSENCE	ABSENCE	-

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.