

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 75

TOTAL PARAMETERS TESTED: 3


ANALYSIS DATE(S) : 05/04/2022 – 05/13/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
05/11/2022 08:08	S22-2386	Laguna Wellfield 1	ABSENCE	ABSENCE	4
05/04/2022 12:19	S22-2238	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	100
05/04/2022 12:10	S22-2239	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	18
05/04/2022 11:29	S22-2240	Pump 11, Phase 5, San Jose Village II	ABSENCE	ABSENCE	10
05/04/2022 10:49	S22-2241	Clubhouse, Phase 5, San Jose Village II	ABSENCE	ABSENCE	13
05/04/2022 11:10	S22-2242	Clubhouse, Phase 6, San Jose Village III	ABSENCE	ABSENCE	< 1
05/04/2022 12:39	S22-2243	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	< 1
05/04/2022 10:31	S22-2244	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY					
05/06/2022 12:13	S22-2315	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	-
05/06/2022 12:26	S22-2316	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	-
BRGY. DELA PAZ					
05/06/2022 11:36	S22-2321	Water Pump, Almeda Subdivision	ABSENCE	ABSENCE	-
BRGY. GANADO					
05/04/2022 13:21	S22-2223	Ganado Elementary School	ABSENCE	ABSENCE	< 1
BRGY. HALANG					
05/06/2022 12:38	S22-2311	9999 Water Pump Metroville Complex	ABSENCE	ABSENCE	-
05/06/2022 12:47	S22-2312	Block 30 Lot 17, Metroville Complex	ABSENCE	ABSENCE	-
BRGY. LANGKIWA					
05/05/2022 11:28	S22-2279	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
05/04/2022 08:48	S22-2248	Drinking Fountain, Southville 5A National High School	ABSENCE	ABSENCE	< 1
05/06/2022 13:00	S22-2308	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	-
BRGY. LOMA					
05/04/2022 10:10	S22-2245	Block 43 Lot 13, Celina Technopark	ABSENCE	ABSENCE	< 1
05/05/2022 08:34	S22-2269	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
05/05/2022 08:54	S22-2270	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	10
05/04/2022 09:38	S22-2242	Drinking Fountain, Loma Elementary	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN					
05/04/2022 09:50	S22-2246	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	< 1
05/04/2022 12:36	S22-2224	United Laboratories (UNILAB) Inc.	ABSENCE	ABSENCE	< 1
BRGY. POBLACION					
05/17/2022 09:44	S22-2505	Barangay Hall	ABSENCE	ABSENCE	1
BRGY. PLATERO					
05/06/2022 09:10	S22-2297	Elevated Water Tank, Mondo Bambini	ABSENCE	ABSENCE	-
05/06/2022 09:18	S22-2298	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	-
05/06/2022 10:45	S22-2299	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	-
05/06/2022 10:59	S22-2300	Clubhouse, Prima Casa	ABSENCE	ABSENCE	-
05/06/2022 11:11	S22-2301	Water Pump, Spring Time	ABSENCE	ABSENCE	-
05/06/2022 11:16	S22-2302	Block 7 Lot 10, Spring Time	ABSENCE	ABSENCE	-
05/04/2022 09:18	S22-2226	Sea-oil, National Road	ABSENCE	ABSENCE	1
05/04/2022 09:36	S22-2228	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	< 1
05/06/2022 10:14	S22-2306	Water Pump, Jubilation Village - East	ABSENCE	ABSENCE	-
05/06/2022 10:22	S22-2307	Clubhouse, Jubilation Village - East	ABSENCE	ABSENCE	-


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE U. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SAN ANTONIO					
05/04/2022 10:43	S22-2234	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	< 1
05/04/2022 11:15	S22-2235	Alonte Stadium	ABSENCE	ABSENCE	< 1
05/04/2022 08:57	S22-2229	Water Pump, Margarita Homes Subdivision	ABSENCE	ABSENCE	< 1
05/04/2022 09:02	S22-2230	Block 1 Lot 12, Margarita Homes	ABSENCE	ABSENCE	< 1
05/06/2022 09:45	S22-2317	9022 Water Pump, Faraon Subdivision	ABSENCE	ABSENCE	-
05/06/2022 09:30	S22-2322	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	-
05/04/2022 10:18	S22-2231	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	< 1
05/04/2022 10:29	S22-2232	Pan de Manila, Pavilion Mall	ABSENCE	ABSENCE	< 1
05/06/2022 10:28	S22-2318	Malaban Health Center	ABSENCE	ABSENCE	-
05/06/2022 10:21	S22-2319	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	-
05/06/2022 10:14	S22-2320	Wash Area 2, Malaban Elementary School	ABSENCE	ABSENCE	-
BRGY. SANTO NIÑO					
05/04/2022 09:42	S22-2233	Jollibee National Hi-Way	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE					
05/05/2022 11:16	S22-2278	407 Water Pump, San Vicente Subdivision	ABSENCE	ABSENCE	< 1
05/05/2022 11:50	S22-2280	Drinking Fountain, San Vicente Elementary School	ABSENCE	ABSENCE	< 1
05/05/2022 12:18	S22-2281	Andom Merchandise, Bayabas St., Phase 7 Olivarez Homes	ABSENCE	ABSENCE	< 1
05/05/2022 12:31	S22-2282	Cistern Tank, Central Mall	ABSENCE	ABSENCE	18
05/04/2022 09:27	S22-2227	Biñan Doctor's Hospital	ABSENCE	ABSENCE	< 1
BRGY. SANTO TOMAS					
05/04/2022 11:40	S22-2225	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	1
05/04/2022 11:49	S22-2237	HOA Office, Adelina Complex	ABSENCE	ABSENCE	< 1
05/05/2022 09:39	S22-2288	Water Pump, Pragmatic Subdivision	ABSENCE	ABSENCE	< 1
05/05/2022 10:01	S22-2289	Block 1 Lot 5, Bais St., Pragmatic	ABSENCE	ABSENCE	< 1
05/05/2022 11:01	S22-2277	Tawi Tawi St., Phase 6, South City Homes	ABSENCE	ABSENCE	< 1
05/05/2022 10:29	S22-2275	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	< 1
05/05/2022 10:45	S22-2276	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE Q. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
05/05/2022 08:21	S22-2283	Water Pump, Town & Country, Amsterdam St.	ABSENCE	ABSENCE	< 1
05/05/2022 08:38	S22-2284	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	< 1
05/05/2022 08:59	S22-2285	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	< 1
05/05/2022 09:16	S22-2286	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
05/05/2022 09:24	S22-2287	Blk 1 Lt 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO					
05/06/2022 13:39	S22-2313	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	-
05/06/2022 13:26	S22-2314	#76 Manila S Road	ABSENCE	ABSENCE	-
BRGY. TIMBAO					
05/04/2022 09:10	S22-2250	Water Pump, San Antonio South	ABSENCE	ABSENCE	2
05/04/2022 09:16	S22-2251	Block 3 Lot 23, San Antonio South	ABSENCE	ABSENCE	< 1
BRGY. ZAPOTE					
05/06/2022 08:40	S22-2293	Water Pump, Summer Breeze	ABSENCE	ABSENCE	-
05/06/2022 08:51	S22-2294	Clubhouse, Summer Breeze	ABSENCE	ABSENCE	-
05/06/2022 09:30	S22-2295	Elevated Water Tank, Evergreen	ABSENCE	ABSENCE	-
05/06/2022 09:41	S22-2296	Clubhouse, Evergreen	ABSENCE	ABSENCE	-
05/06/2022 09:50	S22-2304	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	-
05/06/2022 10:04	S22-2305	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	-
05/06/2022 11:40	S22-2303	Clubhouse, Jubilation Village - West	ABSENCE	ABSENCE	-
05/04/2022 11:15	S22-2236	Clubhouse, Althea Residences	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** - Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.