

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 77

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 11/02/2021 – 11/17/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
11/04/2021 12:29	S21-7520	Laguna Wellfield 1	7.78 / 27.8	0.37	ABSENCE	ABSENCE	< 1
11/11/2021 11:23	S21-7610	Guardhouse Entrance, Phase 4C, San Jose Village I	7.48 / 29.5	0.36	ABSENCE	ABSENCE	< 1
11/11/2021 11:16	S21-7611	Clubhouse, Phase 3B, San Jose Village II	7.36 / 27.0	0.30	ABSENCE	ABSENCE	< 1
11/11/2021 11:00	S21-7612	Pump 11, Phase 5, San Jose Village II	7.38 / 29.1	0.29	ABSENCE	ABSENCE	< 1
11/11/2021 10:25	S21-7613	Clubhouse, Phase 5, San Jose Village II	7.50 / 27.6	0.18	ABSENCE	ABSENCE	< 1
11/11/2021 10:41	S21-7614	Clubhouse, Phase 6, San Jose Village III	7.41 / 29.0	0.17	ABSENCE	ABSENCE	1
11/11/2021 13:05	S21-7615	Main Gate, AVIDA Shophouse	7.45 / 28.6	0.40	ABSENCE	ABSENCE	< 1
11/11/2021 12:48	S21-7616	DLSU Science and Technology Complex, LTI Spine Road	7.40 / 27.6	0.35	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY							
11/02/2021 16:46	S21-7447	Clubhouse, Golden City Subdivision	-	0.19	ABSENCE	ABSENCE	6
11/02/2021 16:27	S21-7448	Drinking Fountain, Canlalay Elementary School	-	0.27	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ							
11/02/2021 16:01	S21-7453	Water Pump, Almeda Subdivision	-	0.16	ABSENCE	ABSENCE	< 1
BRGY. GANADO							
11/03/2021 12:48	S21-7459	Ganado Elementary School	7.60 / 27.2	0.36	ABSENCE	ABSENCE	< 1
BRGY. HALANG							
11/02/2021 17:04	S21-7443	9999 Water Pump Metroville Complex	-	0.18	ABSENCE	ABSENCE	< 1
11/02/2021 17:16	S21-7444	Clubhouse, Metroville Complex	-	0.13	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
11/12/2021 11:30	S21-7674	Block 65 Lot 3, Phase II, Southville	7.30 / 29.2	0.18	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:



[Signature]
ALYSSA MARI C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
11/11/2021 09:30	S21-7620	Drinking Fountain, Southville 5A National High School	7.67 / 29.1	0.29	ABSENCE	ABSENCE	< 1
11/11/2021 09:41	S21-7621	Drinking Fountain, Langkiwa Elementary School	7.50 / 28.2	0.27	ABSENCE	ABSENCE	< 1
BRGY. LOMA							
11/11/2021 11:59	S21-7617	Block 43 Lot 13, Celina Technopark	7.50 / 28.6	0.31	ABSENCE	ABSENCE	< 1
11/11/2021 14:58	S21-7633	Brenna Model House, Laguna Bel-Air III	7.58 / 29.8	0.24	ABSENCE	ABSENCE	< 1
11/11/2021 15:10	S21-7634	Hilcrest Road, Block 2 Laguna Bel-Air III	7.48 / 28.6	0.28	ABSENCE	ABSENCE	< 1
11/11/2021 15:21	S21-7635	Clubhouse, Laguna Bel-Air III	7.40 / 27.7	0.26	ABSENCE	ABSENCE	< 1
11/11/2021 11:40	S21-7619	Drinking Fountain, Loma Elementary	7.61 / 29.0	0.28	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN							
11/11/2021 12:25	S21-7618	Clubhouse, Verdana Homes Subdivision	7.59 / 27.6	0.36	ABSENCE	ABSENCE	< 1
11/03/2021 12:59	S21-7460	United Laboratories (UNILAB) Inc.	7.40 / 28.1	0.40	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
11/02/2021 15:38	S21-7454	Barangay Hall	-	0.09	ABSENCE	ABSENCE	1
BRGY. PLATERO							
11/15/2021 16:04	S21-7711	Elevated Water Tank, Mondo Bambini	7.73 / 29.0	0.14	ABSENCE	ABSENCE	< 1
11/15/2021 16:15	S21-7712	Clubhouse, Mondo Bambini	7.74 / 31.5	0.20	ABSENCE	ABSENCE	30
11/15/2021 17:18	S21-7713	Elevated Water Tank, Prima Casa	8.03 / 30.0	0.79	ABSENCE	ABSENCE	< 1
11/15/2021 17:27	S21-7714	Clubhouse, Prima Casa	7.99 / 31.0	0.50	ABSENCE	ABSENCE	< 1
11/15/2021 17:40	S21-7715	Water Pump, Spring Time	7.79 / 29.0	0.44	ABSENCE	ABSENCE	< 1
11/15/2021 17:52	S21-7716	Block 10 Lot 7, Spring Time	7.82 / 29.2	0.40	ABSENCE	ABSENCE	< 1
11/03/2021 13:48	S21-7462	Sea-oil, National Road	7.45 / 28.6	0.30	ABSENCE	ABSENCE	< 1
11/03/2021 13:59	S21-7464	Drinking Fountain, St. Michael School	7.68 / 27.5	0.18	ABSENCE	ABSENCE	< 1
11/15/2021 18:28	S21-7717	Clubhouse, Jubilation Village - West	7.61 / 29.5	0.28	ABSENCE	ABSENCE	< 1
11/15/2021 17:00	S21-7720	Water Pump, Jubilation Village - East	7.91 / 29.5	0.21	ABSENCE	ABSENCE	< 1
11/15/2021 17:07	S21-7721	Clubhouse, Jubilation Village - East	7.84 / 29.8	0.17	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. SAN ANTONIO							
11/03/2021 11:59	S21-7470	Water Pump, Biñan City Hall	7.65 / 27.5	0.48	ABSENCE	ABSENCE	< 1
11/03/2021 11:38	S21-7471	Alonte Stadium	7.63 / 28.1	0.45	ABSENCE	ABSENCE	< 1
11/03/2021 13:10	S21-7465	Water Pump, Margarita Homes Subdivision	7.70 / 27.5	0.48	ABSENCE	ABSENCE	< 1
11/03/2021 13:16	S21-7466	Block 5 Lot 12, Margarita Homes	7.71 / 29.1	0.58	ABSENCE	ABSENCE	< 1
11/02/2021 14:40	S21-7449	9022 Water Pump, Faraon Subdivision	-	0.55	ABSENCE	ABSENCE	< 1
11/02/2021 14:18	S21-7455	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	-	0.21	ABSENCE	ABSENCE	< 1
11/03/2021 14:18	S21-7467	Cistern Tank, Pavilion Mall	7.57 / 29.0	0.30	ABSENCE	ABSENCE	< 1
11/03/2021 14:28	S21-7468	Jollibee, Pavilion Mall	7.50 / 28.1	0.28	ABSENCE	ABSENCE	< 1
11/02/2021 15:15	S21-7450	Malaban Health Center	-	0.54	ABSENCE	ABSENCE	< 1
11/02/2021 14:56	S21-7451	Drinking Fountain 1, Malaban Elementary School	-	0.43	ABSENCE	ABSENCE	< 1
11/02/2021 15:01	S21-7452	Drinking Fountain 2, Malaban Elementary School	-	0.55	ABSENCE	ABSENCE	2
BRGY. SANTO NIÑO							
11/03/2021 14:50	S21-7469	Jollibee National Hi-Way	7.70 / 29.8	0.36	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
11/03/2021 11:20	S21-7472	407 Water Pump, San Vicente Subdivision	7.65 / 28.1	0.29	ABSENCE	ABSENCE	< 1
11/12/2021 14:56	S21-7675	Drinking Fountain, San Vicente Elementary School	7.23 / 27.9	0.19	ABSENCE	ABSENCE	72
11/12/2021 14:43	S21-7676	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.22 / 29.7	0.23	ABSENCE	ABSENCE	5
11/12/2021 15:36	S21-7677	Cistern Tank, Central Mall	7.53 / 29.0	0.25	ABSENCE	ABSENCE	90
11/03/2021 13:47	S21-7463	Biñan Doctor's Hospital	7.26 / 29.0	0.22	ABSENCE	ABSENCE	1
BRGY. SANTO TOMAS							
11/03/2021 15:20	S21-7461	Water Pump, Adelina Complex 3	7.41 / 27.6	0.28	ABSENCE	ABSENCE	< 1
11/03/2021 11:26	S21-7473	HOA Office, Adelina Complex	7.68 / 28.5	0.26	ABSENCE	ABSENCE	< 1
11/12/2021 14:14	S21-7683	Water Pump, Pragmatic Subdivision	7.72 / 29.4	0.08	ABSENCE	ABSENCE	< 1
11/12/2021 14:24	S21-7684	Block 1 Lot 5, Bais St., Pragmatic	7.64 / 29.6	0.06	ABSENCE	ABSENCE	< 1
11/12/2021 13:22	S21-7672	Tawi Tawi St., Phase 6, South City Homes	7.32 / 29.0	0.15	ABSENCE	ABSENCE	2
11/12/2021 13:40	S21-7670	Water Pump, South Plains II Subdivision	7.41 / 28.7	0.32	ABSENCE	ABSENCE	2
11/12/2021 13:45	S21-7671	Block 11 Lot 2, South Plains II Subdivision	7.41 / 29.1	0.29	ABSENCE	ABSENCE	1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
11/12/2021 11:58	S21-7678	Water Pump, Town & Country, Amsterdam	7.40 / 30.1	0.26	ABSENCE	ABSENCE	< 1
11/12/2021 11:42	S21-7679	Blk 35 Lot 21, Southville Town & Country	7.26 / 29.4	0.21	ABSENCE	ABSENCE	< 1
11/12/2021 12:10	S21-7680	Blk 2 Lot 5, Town & Country, Pennsylvania	7.27 / 29.5	0.11	ABSENCE	ABSENCE	< 1
11/12/2021 12:34	S21-7681	Water Pump, Phase 4, Olivarez Homes South	7.30 / 29.7	0.14	ABSENCE	ABSENCE	10
11/12/2021 12:43	S21-7682	Blk 1 Lt 16, Phase 4, Olivarez Homes South	7.24 / 28.5	0.16	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO							
11/02/2021 18:02	S21-7445	Water Pump, 9067 Manila S Road	-	0.32	ABSENCE	ABSENCE	< 1
11/02/2021 17:49	S21-7446	#76 Manila S Road	-	0.24	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO							
11/11/2021 10:00	S21-7622	Water Pump, San Antonio South	7.45 / 27.2	0.34	ABSENCE	ABSENCE	< 1
11/11/2021 10:11	S21-7623	Block 3 Lot 23, San Antonio South	7.56 / 27.0	0.26	ABSENCE	ABSENCE	< 1
BRGY. TUBIGAN							
11/12/2021 15:21	S21-7673	#60 Florinda Compound	7.26 / 28.6	0.32	ABSENCE	ABSENCE	63
BRGY. ZAPOTE							
11/15/2021 15:19	S21-7707	Water Pump, Summer Breeze	7.55 / 28.9	0.62	ABSENCE	ABSENCE	< 1
11/15/2021 15:26	S21-7708	Clubhouse, Summer Breeze	7.61 / 29.4	0.58	ABSENCE	ABSENCE	< 1
11/15/2021 15:40	S21-7709	Elevated Water Tank, Evergreen	7.79 / 29.4	0.74	ABSENCE	ABSENCE	< 1
11/15/2021 15:50	S21-7710	Clubhouse, Evergreen	7.69 / 29.5	0.91	ABSENCE	ABSENCE	< 1
11/15/2021 16:30	S21-7718	Water Pump, Jubilation Village - South	7.75 / 29.5	0.51	ABSENCE	ABSENCE	< 1
11/15/2021 16:38	S21-7719	Clubhouse, Jubilation Village - South	7.91 / 30.9	0.30	ABSENCE	ABSENCE	< 1
11/12/2021 13:59	S21-7685	Clubhouse, Althea Residences	7.34 / 29.6	0.23	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable


DEVIATIONS: No deviation noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.