

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME : LAGUNA AAAWATER CORPORATION**

**ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna**

**ATTENTION : BIÑAN CITY HEALTH OFFICE**

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES : 76**

**TOTAL PARAMETERS TESTED: 3**

**ANALYSIS DATE(S) : 10/03/2022 – 10/26/2022**

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. BIÑAN</b>					
10/06/2022 09:47	S22-5020	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
10/13/2022 10:30	S22-5222	Guardhouse Entrance, Phase 4C, San Jose Village I	ABSENCE	ABSENCE	< 1
10/13/2022 10:40	S22-5223	Clubhouse, Phase 3B, San Jose Village II	ABSENCE	ABSENCE	< 1
10/13/2022 11:16	S22-5224	Pump 11, Phase 5, San Jose Village II	ABSENCE	ABSENCE	< 1
10/26/2022 16:01	S22-5431	Clubhouse, Phase 5, San Jose Village II	ABSENCE	ABSENCE	8
10/13/2022 11:10	S22-5226	Clubhouse, Phase 6, San Jose Village III	ABSENCE	ABSENCE	< 1
10/13/2022 15:10	S22-5227	Main Gate, AVIDA Shophouse	ABSENCE	ABSENCE	< 1
10/13/2022 10:15	S22-5228	DLSU Science and Technology Complex, LTI Spine Road	ABSENCE	ABSENCE	< 1
<b>BRGY. CANLALAY</b>					
10/03/2022 11:58	S22-4946	Clubhouse, Golden City Subdivision	ABSENCE	ABSENCE	< 1
10/03/2022 12:17	S22-4947	Drinking Fountain, Canlalay Elementary School	ABSENCE	ABSENCE	< 1
<b>BRGY. DELA PAZ</b>					
10/03/2022 11:46	S22-4952	Water Pump, Almeda Subdivision	ABSENCE	ABSENCE	< 1
<b>BRGY. GANADO</b>					
10/19/2022 12:12	S22-5354	Ganado Elementary School	ABSENCE	ABSENCE	3
<b>BRGY. HALANG</b>					
10/03/2022 12:43	S22-4942	9999 Water Pump Metroville Complex	ABSENCE	ABSENCE	< 1
10/03/2022 12:56	S22-4943	Block 31 Lot 19, Metroville Complex	ABSENCE	ABSENCE	< 1
<b>BRGY. LANGKIWA</b>					
10/11/2022 13:30	S22-5166	Block 3 Lot 9, Phase II, Southville	ABSENCE	ABSENCE	3

**NOT VALID WITHOUT QR CODE**



**REVIEWED BY:**

*[Signature]*  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0090336)

**CERTIFIED CORRECT BY:**

*[Signature]*  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
10/13/2022 15:21	S22-5232	Drinking Fountain, Southville 5A National High School	ABSENCE	ABSENCE	< 1
10/13/2022 15:29	S22-5233	Drinking Fountain, Langkiwa Elementary School	ABSENCE	ABSENCE	< 1
<b>BRGY. LOMA</b>					
10/13/2022 10:10	S22-5229	Block 43 Lot 13, Celina Technopark	ABSENCE	ABSENCE	< 1
10/06/2022 13:33	S22-5057	Block 10 Lot 24, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
10/06/2022 13:43	S22-5058	Clubhouse, Laguna Bel-Air III	ABSENCE	ABSENCE	< 1
10/13/2022 09:21	S22-5231	Drinking Fountain, Loma Elementary	ABSENCE	ABSENCE	< 1
<b>BRGY. MAMPLASAN</b>					
10/13/2022 09:41	S22-5230	Clubhouse, Verdana Homes Subdivision	ABSENCE	ABSENCE	< 1
10/19/2022 11:52	S22-5355	Amherst Laboratories, (UNILAB) Inc.	ABSENCE	ABSENCE	< 1
<b>BRGY. POBLACION</b>					
10/03/2022 11:31	S22-4953	Barangay Hall	ABSENCE	ABSENCE	< 1
<b>BRGY. PLATERO</b>					
10/19/2022 09:00	S22-5335	Elevated Water Tank, Mondo Bambini	ABSENCE	ABSENCE	5
10/19/2022 09:09	S22-5336	Clubhouse, Mondo Bambini	ABSENCE	ABSENCE	10
10/19/2022 10:17	S22-5337	Elevated Water Tank, Prima Casa	ABSENCE	ABSENCE	74
10/19/2022 10:26	S22-5338	Clubhouse, Prima Casa	ABSENCE	ABSENCE	60
10/19/2022 10:50	S22-5339	Water Pump, Springtime	ABSENCE	ABSENCE	94
10/19/2022 11:00	S22-5340	Block 7 Lot 10, Springtime	ABSENCE	ABSENCE	15
10/19/2022 10:35	S22-5346	Sea-oil, National Road	ABSENCE	ABSENCE	180
10/19/2022 12:18	S22-5348	Drinking Fountain, St. Michael School	ABSENCE	ABSENCE	4
10/19/2022 10:00	S22-5345	Water Pump, Jubilation Village - East	ABSENCE	ABSENCE	2
10/19/2022 09:51	S22-5344	Clubhouse, Jubilation Village - East	ABSENCE	ABSENCE	1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. SAN ANTONIO</b>					
10/19/2022 12:46	S22-5357	Water Pump, Biñan City Hall	ABSENCE	ABSENCE	41
10/19/2022 12:36	S22-5358	Alonte Stadium	ABSENCE	ABSENCE	6
10/19/2022 10:51	S22-5349	Water Pump, Margarita Homes Subdivision	ABSENCE	ABSENCE	2
10/19/2022 11:04	S22-5350	Block 1 Lot 12, Margarita Homes	ABSENCE	ABSENCE	1
10/03/2022 10:45	S22-4948	9022 Water Pump, Faraon Subdivision	ABSENCE	ABSENCE	< 1
10/03/2022 10:24	S22-4954	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	ABSENCE	ABSENCE	< 1
10/19/2022 11:21	S22-5351	Cistern Tank, Pavilion Mall	ABSENCE	ABSENCE	2
10/19/2022 11:39	S22-5352	Pande Manila, Pavilion Mall	ABSENCE	ABSENCE	< 1
10/03/2022 11:20	S22-4949	Malaban Health Center	ABSENCE	ABSENCE	< 1
10/03/2022 11:02	S22-4950	Wash Area 1, Malaban Elementary School	ABSENCE	ABSENCE	< 1
10/03/2022 11:08	S22-4951	Drinking Fountain, Malaban Elementary School	ABSENCE	ABSENCE	< 1
<b>BRGY. SANTO NIÑO</b>					
10/19/2022 11:58	S22-5353	Jollibee National Hi-Way	ABSENCE	ABSENCE	< 1
<b>BRGY. SAN VICENTE</b>					
10/26/2022 15:16	S22-5429	407 Water Pump, San Vicente Subdivision	ABSENCE	ABSENCE	4
10/11/2022 14:21	S22-5167	Drinking Fountain, San Vicente Elementary School	ABSENCE	ABSENCE	2
10/11/2022 15:01	S22-5168	Block 8 Lot 6 Bayabas St., Phase 7 Olivarez Homes	ABSENCE	ABSENCE	1
10/26/2022 15:30	S22-5430	Cistern Tank, Central Mall	ABSENCE	ABSENCE	10
10/19/2022 12:33	S22-5347	Biñan Doctor's Hospital	ABSENCE	ABSENCE	1
<b>BRGY. SANTO TOMAS</b>					
10/19/2022 13:20	S22-5356	Water Pump, Adelina Complex 3	ABSENCE	ABSENCE	< 1
10/11/2022 13:10	S22-5175	Water Pump, Pragmatic Subdivision	ABSENCE	ABSENCE	14
10/11/2022 13:16	S22-5176	Block 1 Lot 5, Bais St., Pragmatic	ABSENCE	ABSENCE	10
10/19/2022 14:00	S22-5360	HOA Office, Adelina Complex	ABSENCE	ABSENCE	5
10/11/2022 09:40	S22-5164	Tawi Tawi St. South City Homes	ABSENCE	ABSENCE	24
10/11/2022 09:21	S22-5162	Water Pump, South Plains II Subdivision	ABSENCE	ABSENCE	19
10/11/2022 09:39	S22-5163	Block 11 Lot 2, South Plains II Subdivision	ABSENCE	ABSENCE	30

NOT VALID WITHOUT QR CODE



REVIEWED BY:

*[Signature]*  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

*[Signature]*  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
10/11/2022 08:40	S22-5170	Water Pump, Town & Country, Amsterdam St.	ABSENCE	ABSENCE	< 1
10/11/2022 09:00	S22-5171	Blk 35 Lot 21, Southville Town & Country	ABSENCE	ABSENCE	< 1
10/11/2022 10:01	S22-5172	Blk 2 Lot 5, Town & Country, Pennsylvania	ABSENCE	ABSENCE	5
10/11/2022 10:21	S22-5173	Water Pump, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	13
10/11/2022 10:48	S22-5174	Blk 1 Lt 16, Phase 4, Olivarez Homes South	ABSENCE	ABSENCE	14
<b>BRGY. SORO – SORO</b>					
10/03/2022 13:32	S22-4944	Water Pump, 9067 Manila S Road	ABSENCE	ABSENCE	< 1
10/03/2022 13:18	S22-4945	#76 Manila S Road	ABSENCE	ABSENCE	< 1
<b>BRGY. TIMBAO</b>					
10/13/2022 15:50	S22-5234	Water Pump, San Antonio South	ABSENCE	ABSENCE	< 1
10/13/2022 16:01	S22-5235	Block 3 Lot 23, San Antonio South	ABSENCE	ABSENCE	< 1
<b>BRGY. ZAPOTE</b>					
10/19/2022 09:20	S22-5331	Water Pump, Summer Breeze	ABSENCE	ABSENCE	1
10/19/2022 09:27	S22-5332	Club House Entrance, Summer Breeze	ABSENCE	ABSENCE	1
10/19/2022 08:40	S22-5333	Elevated Water Tank, Evergreen	ABSENCE	ABSENCE	1
10/19/2022 08:49	S22-5334	Clubhouse, Evergreen	ABSENCE	ABSENCE	4
10/19/2022 09:43	S22-5343	Water Pump, Jubilation Village - South	ABSENCE	ABSENCE	4
10/19/2022 09:36	S22-5342	Clubhouse, Jubilation Village - South	ABSENCE	ABSENCE	1
10/19/2022 11:18	S22-5341	Clubhouse, Jubilation Village - West	ABSENCE	ABSENCE	1
10/19/2022 12:59	S22-5359	Clubhouse, Althea Residences	ABSENCE	ABSENCE	5

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)