

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME : LAGUNA AAAWATER CORPORATION (LAGUNA WATER)**

**ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna**

**ATTENTION : BIÑAN CITY HEALTH OFFICE (CHO)**

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES : 62**

**TOTAL PARAMETERS TESTED : 5**

**ANALYSIS DATE(S) : 05/07/2020-05/29/2020**

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
<b>BRGY. BIÑAN</b>							
05/07/2020 10:56	S20-2948	Laguna Wellfield 1	7.66 / 26.9	0.51	ABSENCE	ABSENCE	5
05/07/2020 12:15	S20-2951	Guardhouse Entrance, Phase 4C, San Jose Village I	7.21 / 27.6	0.41	ABSENCE	ABSENCE	2
05/07/2020 12:15	S20-2952	Clubhouse, Phase 3B, San Jose Village I	7.15 / 27.5	0.38	ABSENCE	ABSENCE	2
05/07/2020 11:49	S20-2953	Pump 11, Phase 5, San Jose Village II	6.27 / 22.6	0.39	ABSENCE	ABSENCE	< 1
05/07/2020 11:55	S20-2954	Clubhouse, Phase 5, San Jose Village II	6.25 / 29.5	0.32	ABSENCE	ABSENCE	2
05/07/2020 12:05	S20-2955	Clubhouse, Phase 6, San Jose Village III	6.28 / 24.6	0.29	ABSENCE	ABSENCE	4
05/07/2020 13:15	S20-2956	Main Gate, AVIDA Shophouse	7.25 / 29.7	0.34	ABSENCE	ABSENCE	2
05/07/2020 13:05	S20-2957	Parking Lot Faucet, De La Salle University and Technology Complex	7.09 / 26.5	0.26	ABSENCE	ABSENCE	< 1
<b>BRGY. CANLALAY</b>							
05/26/2020 13:14	S20-3229	Clubhouse, Golden City Canlalay	8.15 / 31.0	0.23	ABSENCE	ABSENCE	30
<b>BRGY. DELA PAZ</b>							
05/26/2020 12:48	S20-3231	Water Pump, Almeda Subdivision	7.48 / 29.5	0.51	ABSENCE	ABSENCE	< 1
<b>BRGY. HALANG</b>							
05/20/2020 13:30	S20-3225	9999 WP Metroville Complex	7.80 / 28.8	0.78	ABSENCE	ABSENCE	< 1
05/20/2020 13:42	S20-3226	Clubhouse, Metroville Complex	7.68 / 29.4	0.64	ABSENCE	ABSENCE	< 1
<b>BRGY. LANGKIWA</b>							
05/26/2020 14:08	S20-3272	Block 3 Lot 9, Phase II, Southville	8.09 / 28.2	0.19	ABSENCE	ABSENCE	7

**NOT VALID WITHOUT QR CODE**

**REVIEWED BY:**

**CERTIFIED CORRECT BY:**



JETHRO D. ESCOBIN  
Microbiology Unit Manager

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20	TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
05/07/2020 14:20	S20-2962	Drinking Fountain, Southville 5A National High School	7.40 / 26.8	0.28	ABSENCE	ABSENCE	-
05/07/2020 14:15	S20-2963	Drinking Fountain, Langkiwa Elementary School	7.20 / 33.7	0.24	ABSENCE	ABSENCE	-
<b>BRGY. LOMA</b>							
05/07/2020 13:45	S20-2958	Block 43 Lot 13, Celina Technopark	7.10 / 27.5	0.16	ABSENCE	ABSENCE	< 1
05/07/2020 15:00	S20-2960	Drinking Fountain, Loma Elementary School	7.47 / 26.7	0.20	ABSENCE	ABSENCE	-
05/27/2020 12:56	S20-3304	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air III	7.85 / 27.8	0.17	ABSENCE	ABSENCE	-
05/27/2020 13:25	S20-3305	Hilcrest Road, Block 10 Lot 24, Laguna Bel-Air III	7.84 / 29.2	0.18	ABSENCE	ABSENCE	-
05/27/2020 13:37	S20-3306	Clubhouse, Laguna Bel-Air III	7.74 / 30.1	0.16	ABSENCE	ABSENCE	-
<b>BRGY. MAMPLASAN</b>							
05/07/2020 14:01	S20-2959	Clubhouse, Verdana Homes Subdivision	7.04 / 33.4	0.26	ABSENCE	ABSENCE	-
05/19/2020 12:59	S20-3191	United Laboratories (UNILAB) Inc.	7.56 / 27.3	0.35	ABSENCE	ABSENCE	< 1
<b>BRGY. POBLACION</b>							
05/23/2020 15:56	S20-3239	Water Pump, Poblacion	6.81 / 31.2	0.05	ABSENCE	ABSENCE	-
05/26/2020 12:30	S20-3232	Barangay Hall, Poblacion	7.64 / 29.1	0.48	ABSENCE	ABSENCE	< 1
<b>BRGY. PLATERO</b>							
05/27/2020 10:48	S20-3285	Elevated Water Tank, Mondo Bambini	7.20 / 30.1	0.20	ABSENCE	ABSENCE	-
05/27/2020 10:58	S20-3286	Clubhouse, Mondo Bambini	7.24 / 29.1	0.20	ABSENCE	ABSENCE	-
05/27/2020 12:20	S20-3287	Elevated Water Tank, Prima Casa	7.20 / 30.3	0.33	ABSENCE	ABSENCE	-
05/27/2020 12:37	S20-3288	Clubhouse, Prima Casa	7.24 / 30.1	0.27	ABSENCE	ABSENCE	-
05/27/2020 12:54	S20-3289	Water Pump, Spring Time	7.21 / 29.3	0.15	ABSENCE	ABSENCE	-
05/27/2020 13:05	S20-3290	Block 1 Lot 7, Spring Time	7.18 / 29.6	0.10	ABSENCE	ABSENCE	-
05/19/2020 11:30	S20-3193	Sea-oil, National Road	6.58 / 31.1	0.20	ABSENCE	ABSENCE	< 1
<b>BRGY. SAN ANTONIO</b>							
05/19/2020 13:15	S20-3199	Biñan City Hall	7.66 / 28.7	0.43	ABSENCE	ABSENCE	5
05/19/2020 13:09	S20-3200	Alonte Stadium	7.48 / 30.9	0.60	ABSENCE	ABSENCE	< 1
05/19/2020 11:49	S20-3194	Water Pump, Margarita Homes Subdivision	7.30 / 29.2	0.04	ABSENCE	ABSENCE	72
05/19/2020 11:56	S20-3195	Block 1 Lot 12, Margarita Homes Subdivision	7.46 / 28.7	0.06	ABSENCE	ABSENCE	50
05/26/2020 12:04	S20-3230	9022 Water Pump, Faraon Subdivision	7.07 / 32.7	0.50	ABSENCE	ABSENCE	< 1
05/19/2020 12:42	S20-3197	Mercury Drug Store, Pavillion Mall	7.64 / 29.1	0.20	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:



JETHRO D. ESCOBIN  
Microbiology Unit Manager

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
05/07/2020 15:20	S20-2961	Jacobo Integrated National High School	7.26 / 27.8	0.36	ABSENCE	ABSENCE	-
05/19/2020 12:31	S20-3196	Cistern Tank, Pavillion Mall	7.58 / 29.6	0.34	ABSENCE	ABSENCE	1
<b>BRGY. SANTO NIÑO</b>							
05/19/2020 12:20	S20-3198	Jollibee National Hi-Way	7.51 / 28.4	0.28	ABSENCE	ABSENCE	< 1
<b>BRGY. SAN VICENTE</b>							
05/19/2020 14:08	S20-3202	407 Water Pump, San Vicente Subdivision	7.65 / 29.8	0.02	ABSENCE	ABSENCE	6
05/26/2020 12:56	S20-3273	Block 8 Lot 6, Bayabas St., Phase 7 Olivarez Homes	7.78 / 30.2	0.25	ABSENCE	ABSENCE	2
05/26/2020 13:22	S20-3274	Cistern Tank, Central Mall	7.78 / 30.2	0.25	ABSENCE	ABSENCE	320
<b>BRGY. SANTO TOMAS</b>							
05/19/2020 14:28	S20-3192	Water Pump, Adelina Subdivision	7.62 / 28.5	0.03	ABSENCE	ABSENCE	34
05/19/2020 14:38	S20-3203	HOA Office, Adelina Subdivision	7.58 / 28.6	0.30	ABSENCE	ABSENCE	< 1
05/26/2020 11:56	S20-3279	Water Pump, Pragmatic	7.70 / 28.9	0.13	ABSENCE	ABSENCE	5
05/26/2020 12:09	S20-3280	Block 80 Lot 4,, Kanlaon St., Pragmatic	7.85 / 30.3	0.05	ABSENCE	ABSENCE	6
05/26/2020 12:30	S20-3270	Block 42 Lot 16 Tawi Tawi St., Phase 6, South City Homes	7.83 / 31.7	0.13	ABSENCE	ABSENCE	< 1
05/26/2020 11:13	S20-3268	Pump, South Plains II Subdivision	6.92 / 28.0	0.34	ABSENCE	ABSENCE	< 1
05/26/2020 11:18	S20-3269	Block 11 Lot 2, South Plains II Subdivision	7.13 / 28.9	0.39	ABSENCE	ABSENCE	< 1
05/26/2020 15:00	S20-3275	Water Pump, Town & Country, Amsterdam	8.07 / 27.1	0.16	ABSENCE	ABSENCE	< 1
05/26/2020 15:12	S20-3276	Blk 35 Lt 21, Town & Country, Amsterdam	7.96 / 28.2	0.18	ABSENCE	ABSENCE	1
05/26/2020 15:42	S20-3277	Blk 2 Lt 5, Town & Country, Pennsylvania	7.77 / 26.7	0.20	ABSENCE	ABSENCE	8
05/26/2020 15:42	S20-3278	Blk 1 Lt 16, Phase 4, Olivarez Home South	7.82 / 27.4	0.28	ABSENCE	ABSENCE	5
<b>BRGY. SORO – SORO</b>							
05/20/2020 14:26	S20-3227	Water Pump, 9067 Manila S Road	7.84 / 28.6	0.04	ABSENCE	ABSENCE	66
05/20/2020 13:14	S20-3228	#76 Manila S Road	7.68 / 29.5	0.08	ABSENCE	ABSENCE	2
<b>BRGY. TUBIGAN</b>							
05/26/2020 13:47	S20-3271	#60 Florinda Compound	7.93 / 31.4	0.04	ABSENCE	ABSENCE	220
<b>BRGY. ZAPOTE</b>							
05/27/2020 11:38	S20-3281	Water Pump, Summer Breeze	7.22 / 30.3	0.22	ABSENCE	ABSENCE	-
05/27/2020 12:03	S20-3282	Clubhouse, Summer Breeze	7.18 / 29.7	0.18	ABSENCE	ABSENCE	-
05/27/2020 11:11	S20-3283	Elevated Water Tank, Evergreen	7.14 / 30.1	0.20	ABSENCE	ABSENCE	-
05/27/2020 11:21	S20-3285	Clubhouse, Evergreen	7.25 / 29.6	0.13	ABSENCE	ABSENCE	-
05/19/2020 13:30	S20-3201	Clubhouse, Althea Residences	7.68 / 30.2	0.17	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN  
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s) (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.



**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**LEGEND:** **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

**DEVIATIONS:** No deviation noted on sample collection and submission.

**METHODS:** **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
JETHRO D. ESCOBIN  
Microbiology Unit Manager

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s) (PRC 0060968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.*