

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

10/10/2

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 15

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 08/03/2023-08/15/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIGAA					
08/15/2023 08:36	S23-4533	#253 Elsol Subdivision	ABSENCE	ABSENCE	< 1
BRGY. GULOD					
08/15/2023 14:00	S23-4517	Celestine Ville Subdivision	ABSENCE	ABSENCE	< 1
08/15/2023 14:12	S23-4518	Guard House, Celestine Ville	ABSENCE	ABSENCE	< 1
BRGY. MARINIG					
08/15/2023 13:44	S23-4521	Celestine Homes, Phase 1 Subdivision	ABSENCE	ABSENCE	4
08/15/2023 13:15	S23-4522	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	< 1
08/15/2023 13:00	S23-4523	Celestine Homes, Phase 2 Subdivision	ABSENCE	ABSENCE	< 1
08/15/2023 14:04	S23-4524	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	6
08/15/2023 13:22	S23-4525	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	< 1
08/15/2023 13:13	S23-4526	Block 19 Lot 33, Phase 3, Southville	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. NIUGAN					
08/15/2023 09:04	S23-4534	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	< 1
08/15/2023 13:03	S23-4528	Block 40 Lot 132, Phase 8, Southville	ABSENCE	ABSENCE	280
08/15/2023 12:51	S23-4527	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	< 1
08/15/2023 12:04	S23-4530	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	< 1
08/15/2023 12:28	S23-4529	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	< 1
BRGY. SALA					
08/15/2023 14:22	S23-4535	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	5

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**– Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 30

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 08/03/2023-08/24/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BANAY-BANAY					
08/15/2023 11:58	S23-4531	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	5
08/15/2023 12:09	S23-4532	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	< 1
BRGY. BANLIC					
08/15/2023 08:40	S23-4501	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
08/15/2023 09:01	S23-4502	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MAMATID					
08/15/2023 11:20	S23-4513	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
08/15/2023 11:34	S23-4514	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
08/22/2023 14:40	S23-3598	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	14
08/15/2023 13:21	S23-4509	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/22/2023 12:10	S23-4665	Water Pump, Block 198, Galacia St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/15/2023 13:45	S23-4508	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/15/2023 13:22	S23-4510	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/22/2023 12:33	S23-4666	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	4
08/15/2023 11:14	S23-4540	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
08/15/2023 14:21	S23-4506	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	5
08/15/2023 14:38	S23-4507	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	27
08/15/2023 11:35	S23-4541	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	8


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
08/15/2023 11:22	S23-4542	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	8
08/15/2023 11:50	S23-4511	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
08/15/2023 12:01	S23-4512	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	2
08/15/2023 10:49	S23-4543	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	1
08/15/2023 11:00	S23-4544	Block 58 Lot 6, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	4
08/15/2023 12:15	S23-4519	9001, Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1
08/15/2023 12:21	S23-4520	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	<1
BRGY. PULO					
08/15/2023 10:34	S23-4497	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	< 1
08/15/2023 10:50	S23-4498	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	< 1
08/15/2023 10:10	S23-4499	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	< 1
08/15/2023 10:16	S23-4500	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	< 1
BRGY. SAN ISIDRO					
08/15/2023 09:41	S23-4505	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	< 1
08/15/2023 09:20	S23-4503	Water Pump, San Isidro Heights Subdivision	ABSENCE	ABSENCE	6
08/15/2023 09:33	S23-4504	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis