

DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916 **WEBSITE:** www.lagunawater.com.ph

10/10/2

**CUSTOMER NAME**: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

## **SUMMARY OF LABORATORY ANALYSIS**

NO. OF SAMPLES : 15 TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 11/07/2022- 11/08/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM <sup>A</sup>			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC <sup>B</sup> (CFU/mL)	
BRGY. BIGAA						
11/08/2022 09:41	S22-5542	#253 Elsol Subdivision	ABSENCE	ABSENCE	22	
BRGY. GULOD						
11/07/2022 14:22	S22-5500	Water Pump, Block 12, Noah St., Celestine Ville	ABSENCE	ABSENCE	1	
11/07/2022 14:31	S22-5501	Guard House, Celestine Ville	ABSENCE	ABSENCE	< 1	
BRGY. MARINIG						
11/08/2022 10:21	S22-5530	Water Pump, Block 3 Lot 17, Phase 1, Celestine Homes	ABSENCE	ABSENCE	26	
11/08/2022 10:51	S22-5531	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	53	
11/08/2022 10:35	S22-5532	Water Pump, Block 9, Carnation St., Phase 2, Celestine Homes	ABSENCE	ABSENCE	<1	
11/08/2022 10:43	S22-5533	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	<1	
11/08/2022 11:07	S22-5534	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	3	
11/08/2022 11:19	S22-5535	Block 19 Lot 33, Phase 3, Southville	ABSENCE	ABSENCE	< 1	

**NOT VALID WITHOUT QR CODE** 

**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0090336)

Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORM <sup>A</sup>			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC <sup>B</sup> (CFU/mL)	
BRGY. NIUGAN						
11/08/2022 09:20	S22-5543	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	11	
11/08/2022 11:58	S22-5537	Block 40 Lot 127, Phase 8, Southville	ABSENCE	ABSENCE	2	
11/08/2022 11:45	S22-5536	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	<1	
11/08/2022 13:06	S22-5539	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	3	
11/08/2022 13:21	S22-5538	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	15	
BRGY. SALA						
11/08/2022 09:56	S22-5544	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	<1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

**LEGEND:** <u>HPC</u> – Heterotrophic Plate Count; <u>CFU</u> – Colony Forming Units; <u>MDL</u> – Method Detection Limit; <u>LOQ</u> – Limit of Quantification; <u>NA</u> – Not Applicable; ( - ) Not performed

**DEVIATIONS:** No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

**NOT VALID WITHOUT QR CODE** 

**REVIEWED BY:** 

NOWEL ELLISON G. RAMOS, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0090336) **CERTIFIED CORRECT BY:** 

ANNA KARLAS. GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

**CUSTOMER NAME**: LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

**SUMMARY OF LABORATORY ANALYSIS** 

NO. OF SAMPLES : 30 TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 11/07/2022-11/08/22

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC <sup>B</sup> (CFU/mL)
BRGY. BANAY-BANAY					
11/08/2022 12:32	S22-5540	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	93
11/08/2022 12:43	S22-5541	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	62
BRGY. BANLIC					
11/07/2022 08:16	S22-5483	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	1
11/07/2022 08:10	S22-5484	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	25
BRGY. MAMATID					
11/07/2022 11:21	S22-5496	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	<1
11/07/2022 11:38	S22-5497	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	3
11/07/2022 12:55	S22-5490	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	7
11/07/2022 12:25	S22-5492	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	14
11/07/2022 13:22	S22-5498	Water Pump, Block 198, Galacia St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/07/2022 13:10	S22-5491	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/07/2022 12:37	S22-5493	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	<1
11/07/2022 13:36	S22-5499	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/08/2022 14:03	S22-5549	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/07/2022 13:50	S22-5488	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	< 1
11/07/2022 13:57	S22-5489	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	2
11/08/2022 13:55	S22-5550	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	14

NOT VALID WITHOUT QR CODE

**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

NOWEL ÉLLISON G. RAMOS, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0090336) ANNA KARLA S. GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); DENR (C.R. No. 091/2022) PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916 WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER			
			COLIFORMA			
			TOTAL (Coliforms/ 100mL)	FECAL/ E. coli (Coliforms/ 100 mL)	HPC <sup>B</sup> (CFU/mL)	
11/08/2022 13:45	S22-5551	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	4	
11/07/2022 11:49	S22-5494	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	<1	
11/07/2022 11:58	S22-5495	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	1	
11/08/2022 14:17	S22-5552	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	<1	
11/08/2022 14:25	S22-5553	Block 58 Lot 6, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	2	
11/07/2022 10:41	S22-5502	9001, Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	<1	
11/07/2022 10:59	S22-5503	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	1	
BRGY. PULO						
11/07/2022 10:11	S22-5479	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	3	
11/07/2022 10:18	S22-5480	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	3	
11/07/2022 09:21	S22-5481	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	1	
11/07/2022 09:33	S22-5482	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	1	
BRGY. SAN ISIDRO						
11/07/2022 09:01	S22-5487	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	<1	
11/07/2022 08:26	S22-5485	Water Pump, San Isidro Heights Subdivision	ABSENCE	ABSENCE	<1	
11/07/2022 08:41	S22-5486	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	<1	

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC - Heterotrophic Plate Count; CFU - Colony Forming Units; MDL - Method Detection Limit; LOQ - Limit of Quantification; NA - Not Applicable ( - ) Not performed

**DEVIATIONS:** No deviation noted on sample collection and submission.

METHODS: A- Enzyme Substrate; B - Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT OR CODE

**REVIEWED BY:** 

NOWEL ELLISON G. RAMOS, RMT

Microbiology Unit Manager (OIC)

License No(s). (PRC 0090336)

S. GUTIERREZ, RMT

**CERTIFIED CORRECT BY:** 

Laboratory Services Manager License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis