

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II (CHO-2)

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 12/01/2020-12/09/2020

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. MAMATID							
12/01/2020 17:36	S20-8212	Water Pump, Buena Rosario Subdivision	7.70 / 28.9	0.10	ABSENCE	ABSENCE	< 1
12/01/2020 18:07	S20-8213	Block 7 Lot 6, Buena Rosario Subdivision	7.38 / 28.6	0.28	ABSENCE	ABSENCE	< 1
12/01/2020 16:08	S20-8206	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	7.60 / 27.8	0.18	ABSENCE	ABSENCE	< 1
12/01/2020 16:38	S20-8208	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	7.38 / 29.6	0.25	ABSENCE	ABSENCE	< 1
12/01/2020 18:20	S20-8214	Water Pump, Block 198, Galacia St., Phase 2, Mabuhay City Homes	7.45 / 28.7	0.55	ABSENCE	ABSENCE	2
12/01/2020 16:14	S20-8207	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	7.45 / 28.5	0.15	ABSENCE	ABSENCE	< 1
12/01/2020 16:49	S20-8209	Block 134 Lot 22, Phase 2, Mabuhay City Homes	7.48 / 28.7	0.20	ABSENCE	ABSENCE	< 1
12/01/2020 18:35	S20-8215	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	7.48 / 27.5	0.45	ABSENCE	ABSENCE	< 1
12/03/2020 13:00	S20-8329	Water Pump, Joshua St., Phase 5, Mabuhay City Homes	-	1.02	ABSENCE	ABSENCE	< 1
12/03/2020 13:05	S20-8330	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	-	0.50	ABSENCE	ABSENCE	2
12/01/2020 15:20	S20-8204	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	7.30 / 27.3	0.58	ABSENCE	ABSENCE	< 1
12/01/2020 15:38	S20-8205	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	7.50 / 26.4	0.28	ABSENCE	ABSENCE	< 1
12/03/2020 13:29	S20-8331	Water Pump, Panganig St., Phase 3, Mabuhay City Homes	-	0.59	ABSENCE	ABSENCE	< 1
12/03/2020 13:17	S20-8332	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	-	0.69	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
12/01/2020 17:14	S20-8210	Water Pump, Phase 1E Mabuhay Executive	7.36 / 27.8	0.07	ABSENCE	ABSENCE	< 1
12/01/2020 17:20	S20-8211	Block 236 Lot 9, Phase 1E Mabuhay Executive	7.56 / 28.3	0.06	ABSENCE	ABSENCE	< 1
BRGY. PULO							
12/03/2020 11:03	S20-8320	Water Pump, Block 12 Lot 22, Cabuyao Central	-	0.06	ABSENCE	ABSENCE	41
12/03/2020 11:17	S20-8321	Clubhouse, Narra Avenue, Cabuyao Central	-	0.47	ABSENCE	ABSENCE	8
12/07/2020 10:43	S20-8434	Water Pump, Block 11, Willow Park Homes	-	0.17	ABSENCE	ABSENCE	2
12/03/2020 10:52	S20-8323	Clubhouse, Willow Park Homes	-	0.07	ABSENCE	ABSENCE	98

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION (LAGUNA WATER)

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I (CHO-1)

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 23

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 12/01/2020-12/05/2020

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BANAY-BANAY							
12/01/2020 13:40	S20-8200	Water Pump, Block 63, Lakeside Nest Subdivision	7.48 / 27.5	0.10	ABSENCE	ABSENCE	< 1
12/01/2020 14:00	S20-8201	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	7.50 / 29.3	0.12	ABSENCE	ABSENCE	< 1
BRGY. BANLIC							
12/07/2020 11:09	S20-8433	Water Pump, Gran Seville Subdivision	-	0.14	ABSENCE	ABSENCE	< 1
12/03/2020 12:08	S20-8325	Gate Entrance, Gran Seville Subdivision	-	0.14	ABSENCE	ABSENCE	< 1
BRGY. BIGAA							
12/01/2020 14:15	S20-8202	#253 Elsol Subdivision	7.68 / 19.0	0.28	ABSENCE	ABSENCE	< 1
BRGY. GULOD							
12/01/2020 18:40	S20-8216	Water Pump, Block 12, Noah St., Celestine Ville	7.60 / 29.5	0.25	ABSENCE	ABSENCE	< 1
12/01/2020 19:00	S20-8217	Guardhouse, Celestine Ville	7.56 / 27.4	0.16	ABSENCE	ABSENCE	< 1
BRGY. MARINIG							
12/01/2020 11:30	S20-8190	Block 3 Lot 17, Phase 1, Celestine Homes	7.80 / 29.0	0.13	ABSENCE	ABSENCE	1
12/01/2020 11:38	S20-8191	Block 23, Lot 10, Phase 1, Celestine Homes	7.66 / 29.8	0.09	ABSENCE	ABSENCE	< 1
12/01/2020 12:05	S20-8192	Water Pump, Block 9, Carnation St., Phase 2, Celestine Homes	7.55 / 29.1	0.51	ABSENCE	ABSENCE	< 1
12/01/2020 12:12	S20-8193	Block 13 Lot 2, Phase 2, Celestine Homes	7.38 / 28.3	0.38	ABSENCE	ABSENCE	< 1
12/01/2020 12:25	S20-8194	Water Pump, Block 25, Phase 3, Southville	7.40 / 28.4	0.57	ABSENCE	ABSENCE	< 1
12/01/2020 12:40	S20-8195	Block 19 Lot 33, Phase 3, Southville	7.80 / 29.6	0.36	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

[Signature]
ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. NIUGAN							
12/01/2020 14:28	S20-8203	Block 2 Lot 6, St. Francis Homes	7.48 / 27.6	0.14	ABSENCE	ABSENCE	< 1
12/01/2020 13:15	S20-8197	Block 40 Lot 132, Phase 8, Southville	7.68 / 27.5	0.20	ABSENCE	ABSENCE	1
12/01/2020 13:00	S20-8196	Water Pump, Block 45, Phase 8, Southville	7.75 / 28.9	0.16	ABSENCE	ABSENCE	2
12/01/2020 13:30	S20-8199	Block 47 Lot 101, Phase 10, Southville	7.55 / 29.3	0.08	ABSENCE	ABSENCE	180
12/01/2020 13:28	S20-8198	Water Pump, Block 54, Phase 10, Southville	7.50 / 28.6	0.14	ABSENCE	ABSENCE	240
12/01/2020 19:15	S20-8218	Water Pump, Phase 9, Southville	7.48 / 25.0	0.09	ABSENCE	ABSENCE	2
BRGY. SALA							
12/01/2020 19:59	S20-8220	Gate Entrance, Amaia Scapes	7.40 / 27.8	0.60	ABSENCE	ABSENCE	2
BRGY. SAN ISIDRO							
12/03/2020 12:40	S20-8328	Block 3 Lot 33, Multiland IV	-	1.33	ABSENCE	ABSENCE	< 1
12/03/2020 12:24	S20-8326	Water Pump, San Isidro Heights Subdivision	-	1.39	ABSENCE	ABSENCE	7
12/03/2020 12:31	S20-8327	Block 3 Lot 1, San Isidro Heights Subdivision	-	0.96	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis