

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** LAGUNA AAAWATER CORPORATION

**ADDRESS :** G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

**ATTENTION :** CABUYAO CITY HEALTH OFFICE I

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES :** 15

**TOTAL PARAMETERS TESTED :** 3


**ANALYSIS DATE(S) :** 12/05/2023-12/27/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. BIGAA</b>					
12/05/2023 09:29	S23-6457	#253 Elsol Subdivision	ABSENCE	ABSENCE	< 1
<b>BRGY. GULOD</b>					
12/27/2023 10:16	S23-6891	Celestine Ville Subdivision	ABSENCE	ABSENCE	< 1
12/27/2023 10:10	S23-6890	Guard House, Celestine Ville	ABSENCE	ABSENCE	< 1
<b>BRGY. MARINIG</b>					
12/05/2023 10:42	S23-6445	Celestine Homes, Phase 1 Subdivision	ABSENCE	ABSENCE	< 1
12/05/2023 11:31	S23-6446	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	< 1
12/05/2023 11:03	S23-6447	Celestine Homes, Phase 2 Subdivision	ABSENCE	ABSENCE	< 1
12/05/2023 11:18	S23-6448	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	22
12/05/2023 11:49	S23-6449	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	< 1
12/05/2023 11:56	S23-6450	Block 19 Lot 33, Phase 3, Southville	ABSENCE	ABSENCE	< 1


**NOT VALID WITHOUT QR CODE**



**REVIEWED BY:**

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. NIUGAN</b>					
12/05/2023 08:52	S23-6458	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	< 1
12/05/2023 12:24	S23-6452	Block 40 Lot 132, Phase 8, Southville	ABSENCE	ABSENCE	< 1
12/05/2023 12:17	S23-6048	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	< 1
12/05/2023 12:59	S23-6454	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	1
12/05/2023 12:50	S23-6453	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	1
<b>BRGY. SALA</b>					
12/05/2023 10:01	S23-6459	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; ( - ) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME : LAGUNA AAAWATER CORPORATION**

**ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna**

**ATTENTION : CABUYAO CITY HEALTH OFFICE II**

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES : 30**

**TOTAL PARAMETERS TESTED : 3**


**ANALYSIS DATE(S) : 12/05/2023-12/27/2023**

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. BANAY-BANAY</b>					
12/05/2023 13:10	S23-6455	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	< 1
12/05/2023 13:19	S23-6456	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	< 1
<b>BRGY. BANLIC</b>					
12/21/2023 12:54	S23-6842	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
12/21/2023 12:38	S23-6843	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
<b>BRGY. MAMATID</b>					
12/27/2023 10:30	S23-6886	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
12/27/2023 10:42	S23-6887	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
12/27/2023 12:29	S23-6882	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
12/27/2023 12:10	S23-6880	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
12/27/2023 12:16	S23-6881	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
12/27/2023 12:40	S23-6883	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
12/27/2023 13:10	S23-6889	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
12/05/2023 13:58	S23-6464	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
12/27/2023 09:40	S23-6878	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	< 1
12/27/2023 09:50	S23-6879	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
12/05/2023 13:37	S23-6465	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

  
ANNA KARLA G. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM <sup>A</sup>		HPC <sup>B</sup> (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
12/05/2023 13:46	S23-6466	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
12/27/2023 11:02	S23-6884	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
12/27/2023 11:12	S23-6885	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
12/05/2023 14:09	S23-6467	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
12/05/2023 14:21	S23-6468	Block 58 Lot 6, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
12/27/2023 13:16	S23-6892	9001, Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1
12/27/2023 13:24	S23-6893	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	3
<b>BRGY. PULO</b>					
12/21/2023 12:10	S23-6838	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	< 1
12/21/2023 12:18	S23-6839	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	7
12/21/2023 11:40	S23-6840	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	5
12/21/2023 11:52	S23-6841	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	< 1
<b>BRGY. SAN ISIDRO</b>					
12/21/2023 13:07	S23-6846	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	< 1
12/21/2023 12:52	S23-6844	Water Pump, San Isidro Homes Subdivision	ABSENCE	ABSENCE	11
12/21/2023 12:59	S23-6845	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1

**REMARKS:** Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

**LEGEND:** **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable ( - ) Not performed

**DEVIATIONS:** No deviation noted on sample collection and submission.


**METHODS:** **A** – Enzyme Substrate; **B** – Pour Plate

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:

  
NOWEL ELLISON G. RAMOS, RMT  
Microbiology Unit Manager  
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis