

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 15

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 02/05/2024-02/05/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIGAA					
02/05/2024 15:38	S24-0700	#253 Elsol Subdivision	ABSENCE	ABSENCE	< 1
BRGY. GULOD					
02/05/2024 13:38	S24-0678	Celestine Ville Subdivision	ABSENCE	ABSENCE	< 1
02/05/2024 14:01	S24-0679	Guard House, Celestine Ville	ABSENCE	ABSENCE	< 1
BRGY. MARINIG					
02/05/2024 13:40	S24-0683	Celestine Homes, Phase 1 Subdivision	ABSENCE	ABSENCE	< 1
02/05/2024 14:57	S24-0684	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	< 1
02/05/2024 14:58	S24-0688	Celestine Homes, Phase 2 Subdivision	ABSENCE	ABSENCE	< 1
02/05/2024 14:47	S24-0687	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	72
02/05/2024 13:18	S24-0689	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	< 1
02/05/2024 12:15	S24-0690	Block 19 Lot 33, Phase 3, Southville	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. NIUGAN					
02/05/2024 10:06	S24-0701	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	< 1
02/05/2024 12:36	S24-0693	Block 40 Lot 132, Phase 8, Southville	ABSENCE	ABSENCE	< 1
02/05/2024 12:20	S24-0692	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	< 1
02/05/2024 11:50	S24-0696	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	< 1
02/05/2024 11:42	S24-0695	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	< 1
BRGY. SALA					
02/05/2024 15:17	S24-0702	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 31

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 02/05/2024-02/28/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BANAY-BANAY					
02/05/2024 10:39	S24-0698	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	< 1
02/05/2024 11:00	S24-0699	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	< 1
BRGY. BANLIC					
02/21/2024 11:41	S24-1067	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
02/21/2024 11:59	S24-1068	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MAMATID					
02/05/2024 09:00	S24-0672	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
02/05/2024 09:18	S24-0673	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
02/05/2024 13:01	S24-0666	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	6
02/05/2024 12:18	S24-0663	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
02/05/2024 12:34	S24-0664	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
02/05/2024 13:12	S24-0667	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	18
02/05/2024 10:40	S24-0676	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
02/05/2024 10:29	S24-0675	Water Pump, Block 198, Galacia St., Phase II	ABSENCE	ABSENCE	< 1
02/21/2024 11:41	S24-1076	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	35
02/05/2024 11:23	S24-0660	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	< 1
02/05/2024 11:41	S24-0661	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
02/21/2024 11:24	S24-1077	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
02/21/2024 11:33	S24-1078	Block 9 Lot 11, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
02/05/2024 08:24	S24-0669	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
02/05/2024 08:36	S24-0670	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
02/21/2024 11:52	S24-1079	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
02/21/2024 12:06	S24-1080	Block 60 Lot 1, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
02/05/2024 09:40	S24-0680	9001, Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1
02/05/2024 09:52	S24-0681	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1
BRGY. PULO					
02/26/2024 08:10	S24-1159	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	< 1
02/21/2024 12:30	S24-1070	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	< 1
02/26/2024 08:29	S24-1160	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	< 1
02/21/2024 12:49	S24-1071	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	< 1
BRGY. SAN ISIDRO					
02/21/2024 12:25	S24-1075	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	< 1
02/21/2024 12:42	S24-1073	Water Pump, San Isidro Homes Subdivision	ABSENCE	ABSENCE	< 1
02/21/2024 12:44	S24-1074	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis