

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 15

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 03/04/2024-03/04/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIGAA					
03/04/2024 10:15	S24-1259	#253 Elsol Subdivision	ABSENCE	ABSENCE	28
BRGY. GULOD					
03/04/2024 12:12	S24-1276	Celestine Ville Subdivision	ABSENCE	ABSENCE	< 1
03/04/2024 12:18	S24-1278	Guard House, Celestine Ville	ABSENCE	ABSENCE	< 1
BRGY. MARINIG					
03/04/2024 11:21	S24-1242	Celestine Homes, Phase 1 Subdivision	ABSENCE	ABSENCE	< 1
03/04/2024 12:46	S24-1243	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	2
03/04/2024 12:06	S24-1245	Celestine Homes, Phase 2 Subdivision	ABSENCE	ABSENCE	3
03/04/2024 12:32	S24-1246	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	< 1
03/04/2024 13:12	S24-1248	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	1
03/04/2024 13:21	S24-1249	Block 19 Lot 33, Phase 3, Southville	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. NIUGAN					
03/04/2024 09:34	S24-1260	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	2
03/04/2024 13:28	S24-1252	Block 40 Lot 132, Phase 8, Southville	ABSENCE	ABSENCE	< 1
03/04/2024 13:25	S24-1251	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	< 1
03/04/2024 14:42	S24-1255	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	21
03/04/2024 14:25	S24-1254	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	57
BRGY. SALA					
03/04/2024 10:45	S24-1261	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 31

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 03/04/2024-03/21/2024

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BANAY-BANAY					
03/04/2024 12:19	S24-1257	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	< 1
03/04/2024 16:04	S24-1258	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	63
BRGY. BANLIC					
03/20/2024 11:17	S24-1673	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
03/20/2024 11:28	S24-1674	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	18
BRGY. MAMATID					
03/07/2024 09:59	S24-1347	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
03/07/2024 10:14	S24-1348	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
03/04/2024 10:34	S24-1270	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	2
03/04/2024 11:05	S24-1267	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
03/04/2024 11:16	S24-1268	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
03/04/2024 10:41	S24-1271	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
03/07/2024 12:09	S24-1351	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
03/04/2024 09:45	S24-1273	Water Pump, Block 198, Galacia St., Phase II	ABSENCE	ABSENCE	< 1
03/22/2024 08:08	S24-1778	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
03/07/2024 12:20	S24-1341	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	< 1
03/07/2024 12:25	S24-1342	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	2
03/20/2024 12:30	S24-1676	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	2


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA G. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
03/20/2024 12:39	S24-1677	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	100
03/07/2024 10:33	S24-1344	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
03/07/2024 10:45	S24-1345	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
03/22/2024 08:42	S24-1779	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
03/22/2024 08:20	S24-1780	Block 60 Lot 1, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
03/07/2024 11:16	S24-1349	9001, Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1
03/07/2024 11:21	S24-1350	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1
BRGY. PULO					
03/20/2024 10:43	S24-1669	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	12
03/20/2024 10:54	S24-1670	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	69
03/20/2024 10:09	S24-1671	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	4
03/20/2024 10:24	S24-1672	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	6
BRGY. SAN ISIDRO					
03/22/2024 09:37	S24-1777	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	< 1
03/22/2024 09:11	S24-1775	Water Pump, San Isidro Homes Subdivision	ABSENCE	ABSENCE	< 1
03/22/2024 09:24	S24-1776	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis