

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 15

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 11/14/2023-11/23/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIGAA					
11/14/2023 12:26	S23-6054	#253 Elsol Subdivision	ABSENCE	ABSENCE	< 1
BRGY. GULOD					
11/23/2023 09:50	S23-6255	Celestine Ville Subdivision	ABSENCE	ABSENCE	3
11/23/2023 10:12	S23-6266	Guard House, Celestine Ville	ABSENCE	ABSENCE	14
BRGY. MARINIG					
11/14/2023 11:21	S23-6042	Celestine Homes, Phase 1 Subdivision	ABSENCE	ABSENCE	< 1
11/14/2023 11:48	S23-6043	Block 23, Lot 10, Phase 1, Celestine Homes	ABSENCE	ABSENCE	5
11/14/2023 11:33	S23-6044	Celestine Homes, Phase 2 Subdivision	ABSENCE	ABSENCE	1
11/14/2023 11:40	S23-6045	Block 13 Lot 2, Phase 2, Celestine Homes	ABSENCE	ABSENCE	1
11/14/2023 10:29	S23-6046	Water Pump, Block 25, Phase 3, Southville	ABSENCE	ABSENCE	< 1
11/14/2023 10:48	S23-6047	Block 19 Lot 33, Phase 3, Southville	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLAS G. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. NIUGAN					
11/14/2023 08:54	S23-6055	Block 2 Lot 6, St. Francis Homes VI	ABSENCE	ABSENCE	< 1
11/14/2023 10:37	S23-6049	Block 40 Lot 132, Phase 8, Southville	ABSENCE	ABSENCE	< 1
11/14/2023 10:29	S23-6048	Water Pump, Block 42, Phase 8, Southville	ABSENCE	ABSENCE	< 1
11/14/2023 10:16	S23-6051	Block 47 Lot 101, Phase 10, Southville	ABSENCE	ABSENCE	< 1
11/14/2023 10:08	S23-6050	Water Pump, Block 54, Phase 10, Southville	ABSENCE	ABSENCE	18
BRGY. SALA					
11/14/2023 12:00	S23-6056	Gate Entrance, Amaia Scapes	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable; (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : CABUYAO CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 30

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 11/14/2023-11/30/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BANAY-BANAY					
11/14/2023 09:45	S23-6052	Water Pump, Block 63, Lakeside Nest Subdivision	ABSENCE	ABSENCE	42
11/14/2023 09:31	S23-6053	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	ABSENCE	ABSENCE	30
BRGY. BANLIC					
11/22/2023 09:10	S23-6233	Water Pump, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
11/22/2023 09:21	S23-6234	Gate Entrance, Gran Seville Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MAMATID					
11/23/2023 11:00	S23-6251	Water Pump, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
11/23/2023 11:12	S23-6252	Block 7 Lot 6, Buena Rosario Subdivision	ABSENCE	ABSENCE	< 1
11/23/2023 11:55	S23-6247	Water Pump, Block 141, Carmona St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/23/2023 12:30	S23-6245	Water Pump, Block 101, Samar St., Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/23/2023 12:45	S23-6246	Block 95 Lot 57, Guimaras St., Phase 1 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/23/2023 12:16	S23-6248	Block 134 Lot 22, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/23/2023 11:34	S23-6254	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/30/2023 10:59	S23-6371	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/23/2023 09:29	S23-6243	Water Pump, Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	ABSENCE	ABSENCE	< 1
11/23/2023 09:38	S23-6244	Block 19 Lot 13, Phase 3 Luxury, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/30/2023 11:27	S23-6372	Water Pump, Panganig St., Phase 3 Cluster, Mabuhay City Homes	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
11/30/2023 11:39	S23-6373	Block 1 Lot 17, Dizon St., Phase 3, Mabuhay City Homes	ABSENCE	ABSENCE	< 1
11/23/2023 10:34	S23-6249	Water Pump, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
11/30/2023 13:20	S23-6253	Block 236 Lot 9, Phase 1E Mabuhay Executive	ABSENCE	ABSENCE	< 1
11/30/2023 10:30	S23-6369	Water Pump, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
11/30/2023 10:41	S23-6370	Block 58 Lot 6, Phase 6A, Mabuhay City	ABSENCE	ABSENCE	< 1
11/23/2023 13:05	S23-6257	9001, Block 252, Mabuhay City Subdivision	ABSENCE	ABSENCE	< 1
11/23/2023 13:20	S23-6258	Jimeno Residence, Mabuhay City Subdivision	ABSENCE	ABSENCE	3
BRGY. PULO					
11/22/2023 11:16	S23-6229	Water Pump, Block 12 Lot 22, Cabuyao Central	ABSENCE	ABSENCE	< 1
11/22/2023 11:29	S23-6230	Clubhouse, Narra Avenue, Cabuyao Central	ABSENCE	ABSENCE	< 1
11/28/2023 13:40	S23-6303	Water Pump, Block 11, Willow Park Homes	ABSENCE	ABSENCE	< 1
11/28/2023 13:59	S23-6304	Clubhouse, Willow Park Homes	ABSENCE	ABSENCE	< 1
BRGY. SAN ISIDRO					
11/22/2023 11:16	S23-6237	Block 3 Lot 33, Multiland IV	ABSENCE	ABSENCE	< 1
11/22/2023 09:42	S23-6235	Water Pump, San Isidro Homes Subdivision	ABSENCE	ABSENCE	< 1
11/22/2023 10:10	S23-6236	Block 3 Lot 1, San Isidro Heights Subdivision	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis