

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-6517

DATE/TIME SUBMITTED : 12/06/2023 14:30

DATE/TIME COLLECTION : 12/06/2023 10:19

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : APO ST., AYALA GREENFIELD ESTATES, SAMAT ST., BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|--|---------------------------------|-----------|-------------------|--|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.46 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 12/06/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert- 18®) | 12/06/2023 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert- 18®) | 12/06/2023 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 12/06/2023 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 090336)

CERTIFIED CORRECT BY:



KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-6516

DATE/TIME SUBMITTED : 12/06/2023 14:30

DATE/TIME COLLECTION : 12/06/2023 10:12

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BLOCK 11, KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|----------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.40 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 12/06/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/06/2023 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/06/2023 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 12/06/2023 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 090336)

CERTIFIED CORRECT BY:

KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-6518

DATE/TIME SUBMITTED : 12/06/2023 14:30

DATE/TIME COLLECTION : 12/06/2023 10:25

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|----------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.31 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 12/06/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/06/2023 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/06/2023 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 12/06/2023 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 090336)

CERTIFIED CORRECT BY:



KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-6804

DATE/TIME SUBMITTED : 12/19/2023 15:00

DATE/TIME COLLECTION : 12/19/2023 14:01

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|----------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.61 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 12/19/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/19/2023 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/19/2023 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 12/19/2023 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 090336)

CERTIFIED CORRECT BY:



KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-6875

DATE/TIME SUBMITTED : 12/27/2023 15:00

DATE/TIME COLLECTION : 12/27/2023 08:19

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|-----------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.40 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 12/27/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/27/2023 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/27/2023 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 12/27/2023 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: **A** – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 090336)

CERTIFIED CORRECT BY:



KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-6876

DATE/TIME SUBMITTED : 12/27/2023 15:00

DATE/TIME COLLECTION : 12/27/2023 08:33

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|-----------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.98 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 12/27/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/27/2023 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/27/2023 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 12/27/2023 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 090336)

CERTIFIED CORRECT BY:



KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-6877

DATE/TIME SUBMITTED : 12/27/2023 15:00

DATE/TIME COLLECTION : 12/27/2023 08:45

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BLOCK 23, LOT 33, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|----------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.56 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 12/27/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/27/2023 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/27/2023 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 12/27/2023 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 090336)

CERTIFIED CORRECT BY:



KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-6802

DATE/TIME SUBMITTED : 12/19/2023 15:00

DATE/TIME COLLECTION : 12/19/2023 13:01

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : CISTERN TANK, NATIONAL UNIVERSITY, BRGY. MILAGROSA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|-----------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.30 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 12/19/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/19/2023 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 12/19/2023 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 12/19/2023 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 090336)

CERTIFIED CORRECT BY:



KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-6803

DATE/TIME SUBMITTED : 12/19/2023 15:00

DATE/TIME COLLECTION : 12/19/2023 13:12

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : EDUCATION BUILDING, NATIONAL UNIVERSITY, BRGY. MILAGROSA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|-----------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.30 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 11/09/2023 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 11/09/2023 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 11/09/2023 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 11/09/2023 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 090336)

CERTIFIED CORRECT BY:



KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)