

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-1840 Date Prepared : 06/28/2019  
 Sample Code : S19-2460  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 06/04/2019 17:01 Date/Time Submitted : 06/04/2019 20:01  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : BLOCK 12 SAMAT ST., PHASE 1, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>2</b>	500 (max.)	9215B. Pour Plate Method	06/04/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units


**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-1841 Date Prepared : 06/28/2019

Sample Code : S19-2461

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 06/04/2019 17:08 Date/Time Submitted : 06/04/2019 20:01

Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig

Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate

Sample Source Characteristics : Distribution – Network Sampling Point

References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : BLOCK 11 KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	06/04/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 6/28/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-1842 Date Prepared : 06/28/2019  
 Sample Code : S19-2462  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 06/04/2019 17:17 Date/Time Submitted : 06/04/2019 20:01  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	06/04/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-1843

Date Prepared : 06/28/2019

Sample Code : S19-2463

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 06/04/2019 16:01

Date/Time Submitted : 06/04/2019 20:01

Collected By : Ohwen L. Catindig

Submitted By : Ohwen L. Catindig

Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate

Sample Source Characteristics : Source – Treated Water (w/ Chlorination)

References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	06/04/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-1844 Date Prepared : 06/28/2019  
Sample Code : S19-2464  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 06/04/2019 16:12 Date/Time Submitted : 06/04/2019 20:01  
Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Distribution – Network Sampling Point  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>130</b>	500 (max.)	9215B. Pour Plate Method	06/04/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units


**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-1845

Date Prepared : 06/28/2019

Sample Code : S19-2465

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 06/04/2019 16:22

Date/Time Submitted : 06/04/2019 20:01

Collected By : Ohwen L. Catindig

Submitted By : Ohwen L. Catindig

Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate

Sample Source Characteristics : Source – Treated Water (w/ Chlorination)

References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>300</b>	500 (max.)	9215B. Pour Plate Method	06/04/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units


**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-1846 Date Prepared : 06/28/2019  
Sample Code : S19-2466  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 06/04/2019 16:29 Date/Time Submitted : 06/04/2019 20:01  
Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Distribution – Network Sampling Point  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : BLOCK 39 LOT 5, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	6/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>20</b>	500 (max.)	9215B. Pour Plate Method	06/04/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.  
Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*