

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1441 Date Issued : 05/27/2019
 Sample Code : S19-2282 Document Number : 19-WQM-05-CAL-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 05/22/2019 10:52 Date/Time Submitted : 05/22/2019 17:16
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : BLOCK 12 SAMAT ST., PHASE 1, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	05/22/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/22/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1442 Date Issued : 05/27/2019
 Sample Code : S19-2283 Document Number : 19-WQM-05-CAL-02
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 05/22/2019 11:45 Date/Time Submitted : 05/22/2019 17:16
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 11 KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Heterotrophic Plate Count	CFU/mL	1	9215B. Pour Plate Method	05/22/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/29/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1443 Date Issued : 05/27/2019
 Sample Code : S19-2284 Document Number : 19-WQM-05-CAL-03
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 05/22/2019 11:59 Date/Time Submitted : 05/22/2019 17:16
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Heterotrophic Plate Count	CFU/mL	2	9215B. Pour Plate Method	05/22/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/29/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1444 Date Issued : 05/27/2019
 Sample Code : S19-2285 Document Number : 19-WQM-05-CAL-04
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 05/22/2019 10:37 Date/Time Submitted : 05/22/2019 17:16
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Heterotrophic Plate Count	CFU/mL	11	9215B. Pour Plate Method	05/22/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/29/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1445 Date Issued : 05/27/2019
 Sample Code : S19-2286 Document Number : 19-WQM-05-CAL-05
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 05/22/2019 10:45 Date/Time Submitted : 05/22/2019 17:16
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Heterotrophic Plate Count	CFU/mL	11	9215B. Pour Plate Method	05/22/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/24/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1446 Date Issued : 05/27/2019
 Sample Code : S19-2287 Document Number : 19-WQM-05-CAL-06
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 05/22/2019 10:45 Date/Time Submitted : 05/22/2019 17:16
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Heterotrophic Plate Count	CFU/mL	6	9215B. Pour Plate Method	05/22/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/29/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1447 Date Issued : 05/27/2019
 Sample Code : S19-2288 Document Number : 19-WQM-05-CAL-07
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 05/22/2019 11:05 Date/Time Submitted : 05/22/2019 17:16
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 39 LOT 5, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/22/2019	JDE
Heterotrophic Plate Count	CFU/mL	4	9215B. Pour Plate Method	05/22/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. JERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 5/22/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis