

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2888 Date Prepared : 10/07/2019  
Sample Code : S19-5055  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 09/10/2019 15:20 Date/Time Submitted : 09/10/2019 16:12  
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Distribution – Network Sampling Point  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : BLOCK 12 SAMAT ST., PHASE 1, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA**


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	3	500 (max.)	9215B. Pour Plate Method	9/10/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2889 Date Prepared : 10/07/2019  
 Sample Code : S19-5056  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 09/10/2019 15:14 Date/Time Submitted : 09/10/2019 16:12  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


**RESULTS OF LABORATORY ANALYSIS**

**SAMPLE LOCATION : BLOCK 11 KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA**


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	500 (max.)	9215B. Pour Plate Method	9/10/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 10/7/2019

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2890 Date Prepared : 10/07/2019  
Sample Code : S19-5057  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 09/10/2019 15:35 Date/Time Submitted : 09/10/2019 16:12  
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Distribution – Network Sampling Point  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	500 (max.)	9215B. Pour Plate Method	9/10/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check:

10/7/2019

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2891 Date Prepared : 10/07/2019  
Sample Code : S19-5058  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 09/10/2019 14:23 Date/Time Submitted : 09/10/2019 16:12  
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	4	500 (max.)	9215B. Pour Plate Method	9/10/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 10/7/2019

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*



ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2892 Date Prepared : 10/07/2019  
 Sample Code : S19-5059  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 09/10/2019 14:48 Date/Time Submitted : 09/10/2019 16:12  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


**RESULTS OF LABORATORY ANALYSIS**

**SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	500 (max.)	9215B. Pour Plate Method	9/10/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check:

10/7/2019

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2893 Date Prepared : 10/07/2019

Sample Code : S19-5060

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 09/10/2019 14:40 Date/Time Submitted : 09/10/2019 16:12

Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.

Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

Sample Source Characteristics : Source – Treated Water (w/ Chlorination)

References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


## RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	33	500 (max.)	9215B. Pour Plate Method	9/10/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check:

10/7/2019

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2894 Date Prepared : 10/07/2019  
Sample Code : S19-5061  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 09/10/2019 14:33 Date/Time Submitted : 09/10/2019 16:12  
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Distribution – Network Sampling Point  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : BLOCK 39 LOT 5, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	9/10/2019	JDE
Heterotrophic Plate Count	CFU/mL	28	500 (max.)	9215B. Pour Plate Method	9/10/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 10/7/2019

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*