

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2263 Date Prepared : 07/30/2019
Sample Code : S19-3483
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 07/15/2019 12:15 Date/Time Submitted : 07/15/2019 13:01
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Distribution – Network Sampling Point
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : BLOCK 12 SAMAT ST., PHASE 1, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYZED | |
|---|------------------|-----------|-----------------|---|-----------|-----|
| | | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Heterotrophic Plate Count | CFU/mL | 5 | 500 (max.) | 9215B. Pour Plate Method | 7/15/2019 | JDE |

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.
Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2264 Date Prepared : 07/30/2019
 Sample Code : S19-3484
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 07/15/2019 12:08 Date/Time Submitted : 07/15/2019 13:01
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 11 KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYZED | |
|---|------------------|-----------|-----------------|---|-----------|-----|
| | | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Heterotrophic Plate Count | CFU/mL | 6 | 500 (max.) | 9215B. Pour Plate Method | 7/15/2019 | JDE |

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2265 Date Prepared : 07/30/2019
Sample Code : S19-3485
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 07/15/2019 12:27 Date/Time Submitted : 07/15/2019 13:01
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Distribution – Network Sampling Point
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYZED | |
|---|------------------|-----------|-----------------|---|-----------|-----|
| | | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Heterotrophic Plate Count | CFU/mL | 1 | 500 (max.) | 9215B. Pour Plate Method | 7/15/2019 | JDE |


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.
Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2266 Date Prepared : 07/30/2019
Sample Code : S19-3486
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 07/15/2019 10:47 Date/Time Submitted : 07/15/2019 13:01
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL,
CALAMBA CITY, LAGUNA**

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYZED | |
|---|---------------------|-----------|--------------------|--|-----------|-----|
| | | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Heterotrophic Plate Count | CFU/mL | < 1 | 500 (max.) | 9215B. Pour Plate Method | 7/15/2019 | JDE |

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2267 Date Prepared : 07/30/2019
Sample Code : S19-3487
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 07/15/2019 11:46 Date/Time Submitted : 07/15/2019 13:01
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Distribution – Network Sampling Point
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA


| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYZED | |
|---|------------------|-----------|----------------|---|-----------|-----|
| | | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Heterotrophic Plate Count | CFU/mL | 13 | 500 (max.) | 9215B. Pour Plate Method | 7/15/2019 | JDE |

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.
Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2268 Date Prepared : 07/30/2019
Sample Code : S19-3488
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 07/15/2019 11:26 Date/Time Submitted : 07/15/2019 13:01
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYZED | |
|---|------------------|-----------|-----------------|---|-----------|-----|
| | | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Heterotrophic Plate Count | CFU/mL | < 1 | 500 (max.) | 9215B. Pour Plate Method | 7/15/2019 | JDE |

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.
Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Bifian (Poblacion), Bifian City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2269 Date Prepared : 07/30/2019
 Sample Code : S19-3489
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 07/15/2019 10:58 Date/Time Submitted : 07/15/2019 13:01
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 39 LOT 5, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYZED | |
|---|------------------|-----------|-----------------|---|-----------|-----|
| | | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 7/15/2019 | JDE |
| Heterotrophic Plate Count | CFU/mL | 3 | 500 (max.) | 9215B. Pour Plate Method | 7/15/2019 | JDE |

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis