

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1766

DATE/TIME SUBMITTED : 03/12/2020 12:47

DATE/TIME COLLECTION : 03/12/2020 11:08

COLLECTED BY : Elmer P. Palmares Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : BLOCK 12 SAMAT ST., PHASE 1, AYALA GREENFILEDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/12/2020	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/12/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	03/12/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR STAMP



O
R
I
G



TR20-0815

March 19, 2020 1:26 PM

REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1767

DATE/TIME SUBMITTED : 03/12/2020 12:47

DATE/TIME COLLECTION : 03/12/2020 11:01

COLLECTED BY : Elmer P. Palmares Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : BLOCK 11 KANLAON ST., AYALA GREENFILEDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/12/2020	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/12/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	03/12/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR STAMP



O
R
I
G




TR20-0816

March 19, 2020 1:28 PM

REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1768

DATE/TIME SUBMITTED : 03/12/2020 12:47

DATE/TIME COLLECTION : 03/12/2020 11:19

COLLECTED BY : Elmer P. Palmares Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFILEDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/12/2020	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/12/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	03/12/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR STAMP



O
R
I
G



TR20-0817

March 19, 2020 1:29 PM

REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1915

DATE/TIME SUBMITTED : 03/18/2020 10:49

DATE/TIME COLLECTION : 03/18/2020 10:00

COLLECTED BY : Elmer P. Palmares Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES LAGUNA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/18/2020	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/18/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	9215B. Pour Plate Method	03/18/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR STAMP



ANALYZED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1917

DATE/TIME SUBMITTED : 03/18/2020 10:49

DATE/TIME COLLECTION : 03/18/2020 10:15

COLLECTED BY : Elmer P. Palmares Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES LAGUNA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/18/2020	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/18/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	03/18/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR STAMP



O
R
I
G



TR20-0827

March 24, 2020 3:09 PM

ANALYZED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTERREZ, RMT
Laboratory Services Manager, OIC
PRC license No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1770

DATE/TIME SUBMITTED : 03/12/2020 12:47

DATE/TIME COLLECTION : 03/12/2020 10:27

COLLECTED BY : Elmer P. Palmares Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : BLOCK 39 LOT 5, AMAIA SCAPES LAGUNA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/12/2020	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/12/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	03/12/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR STAMP



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1916

DATE/TIME SUBMITTED : 03/18/2020 10:49

DATE/TIME COLLECTION : 03/18/2020 10:15

COLLECTED BY : Elmer P. Palmares Jr.

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES LAGUNA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/18/2020	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/18/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	03/18/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR STAMP



O
R
I
G



TR20-0829

March 25, 2020 11:15 AM

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager, OIC

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager, OIC
PRC License No. 0060968