

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 75

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 01/06/2022 – 01/29/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
01/05/2022 15:19	S22-0025	Laguna Wellfield 1	7.27 / 26.5	0.05	ABSENCE	ABSENCE	< 1
01/13/2022 12:25	S22-0166	Guardhouse Entrance, Phase 4C, San Jose Village I	7.29 / 27.6	0.28	ABSENCE	ABSENCE	-
01/13/2022 12:38	S22-0167	Clubhouse, Phase 3B, San Jose Village II	7.38 / 26.5	0.30	ABSENCE	ABSENCE	-
01/13/2022 11:59	S22-0168	Pump 11, Phase 5, San Jose Village II	7.29 / 26.4	0.16	ABSENCE	ABSENCE	-
01/13/2022 12:10	S22-0169	Clubhouse, Phase 5, San Jose Village II	7.39 / 27.5	0.20	ABSENCE	ABSENCE	-
01/13/2022 12:12	S22-0170	Clubhouse, Phase 6, San Jose Village III	7.38 / 26.5	0.25	ABSENCE	ABSENCE	-
01/13/2022 13:05	S22-0171	Main Gate, AVIDA Shophouse	7.26 / 27.5	0.48	ABSENCE	ABSENCE	-
01/13/2022 11:45	S22-0172	DLSU Science and Technology Complex, LTI Spine Road	7.29 / 29.7	0.45	ABSENCE	ABSENCE	-
BRGY. CANLALAY							
01/18/2022 13:58	S22-0257	Clubhouse, Golden City Subdivision	7.41 / 28.0	0.23	ABSENCE	ABSENCE	< 1
01/18/2022 14:11	S22-0258	Drinking Fountain, Canlalay Elementary School	7.37 / 27.8	0.21	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ							
01/18/2022 13:24	S22-0261	Water Pump, Almeda Subdivision	7.68 / 28.2	0.20	ABSENCE	ABSENCE	< 1
BRGY. GANADO							
01/19/2022 16:00	S22-0304	Ganado Elementary School	7.27 / 27.7	0.47	ABSENCE	ABSENCE	61
BRGY. HALANG							
01/18/2022 14:23	S22-0253	9999 Water Pump Metroville Complex	7.33 / 27.5	0.57	ABSENCE	ABSENCE	96
01/18/2022 14:31	S22-0254	Clubhouse, Metroville Complex	7.38 / 27.8	0.36	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
01/06/2022 11:20	S22-0035	Block 3 Lot 9, Phase II, Southville	7.30 / 27.5	0.20	ABSENCE	ABSENCE	-

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:



[Signature]
ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
01/13/2022 11:05	S22-0176	Drinking Fountain, Southville 5A National High School	7.26 / 28.1	0.14	ABSENCE	ABSENCE	-
01/13/2022 11:18	S22-0177	Drinking Fountain, Langkiwa Elementary School	7.38 / 27.5	0.12	ABSENCE	ABSENCE	-
BRGY. LOMA							
01/13/2022 11:28	S22-0173	Block 43 Lot 13, Celina Technopark	7.30 / 27.5	0.26	ABSENCE	ABSENCE	-
01/13/2022 12:48	S22-0188	Brenna Model House, Laguna Bel-Air III	7.26 / 27.8	0.12	ABSENCE	ABSENCE	-
01/13/2022 13:07	S22-0189	Block 2, Hilcrest Road, Laguna Bel-Air III	7.16 / 27.2	0.13	ABSENCE	ABSENCE	-
01/13/2022 12:58	S22-0190	Clubhouse, Laguna Bel-Air III	7.18 / 26.8	0.15	ABSENCE	ABSENCE	-
01/13/2022 11:36	S22-0175	Drinking Fountain, Loma Elementary	7.19 / 26.3	0.24	ABSENCE	ABSENCE	-
BRGY. MAMPLASAN							
01/13/2022 11:15	S22-0174	Clubhouse, Verdana Homes Subdivision	7.21 / 27.1	0.38	ABSENCE	ABSENCE	-
01/19/2022 15:40	S22-0305	United Laboratories (UNILAB) Inc.	7.33 / 27.7	0.72	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
01/18/2022 13:00	S22-0262	Barangay Hall	7.46 / 27.4	0.16	ABSENCE	ABSENCE	10
BRGY. PLATERO							
01/17/2022 12:31	S22-0215	Elevated Water Tank, Mondo Bambini	7.64 / 27.8	0.20	ABSENCE	ABSENCE	< 1
01/17/2022 12:41	S22-0216	Clubhouse, Mondo Bambini	7.69 / 29.0	0.11	ABSENCE	ABSENCE	< 1
01/17/2022 13:38	S22-0217	Elevated Water Tank, Prima Casa	7.88 / 28.9	0.37	ABSENCE	ABSENCE	< 1
01/17/2022 13:50	S22-0218	Clubhouse, Prima Casa	7.84 / 29.1	0.53	ABSENCE	ABSENCE	< 1
01/17/2022 14:03	S22-0219	Water Pump, Spring Time	7.58 / 28.8	0.33	ABSENCE	ABSENCE	< 1
01/17/2022 14:13	S22-0220	Block 7 Lot 10, Spring Time	7.56 / 28.7	0.34	ABSENCE	ABSENCE	< 1
01/19/2022 17:32	S22-0307	Sea-oil, National Road	7.23 / 33.3	0.17	ABSENCE	ABSENCE	7
01/19/2022 17:57	S22-0309	Drinking Fountain, St. Michael School	7.29 / 27.1	0.19	ABSENCE	ABSENCE	16
01/17/2022 13:17	S22-0224	Water Pump, Jubilation Village - East	7.71 / 26.3	0.15	ABSENCE	ABSENCE	< 1
01/17/2022 13:26	S22-0225	Clubhouse, Jubilation Village - East	7.71 / 27.4	0.16	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SAN ANTONIO							
01/19/2022 15:29	S22-0315	Water Pump, Biñan City Hall	7.37 / 28.2	0.30	ABSENCE	ABSENCE	< 1
01/19/2022 15:23	S22-0316	Alonte Stadium	7.38 / 28.3	0.59	ABSENCE	ABSENCE	< 1
01/19/2022 17:09	S22-0310	Water Pump, Margarita Homes Subdivision	7.65 / 28.2	0.06	ABSENCE	ABSENCE	< 1
01/19/2022 17:15	S22-0311	Block 1 Lot 12, Margarita Homes	7.62 / 28.2	< 0.02	ABSENCE	ABSENCE	< 1
01/18/2022 12:39	S22-0259	9022 Water Pump, Faraon Subdivision	7.79 / 29.2	0.86	ABSENCE	ABSENCE	< 1
01/18/2022 12:24	S22-0263	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	7.33 / 27.2	0.13	ABSENCE	ABSENCE	2
01/19/2022 16:28	S22-0312	Cistern Tank, Pavilion Mall	7.65 / 27.9	0.25	ABSENCE	ABSENCE	< 1
01/19/2022 16:42	S22-0313	Reyes Barbecue, Pavilion Mall	7.54 / 27.2	0.39	ABSENCE	ABSENCE	< 1
01/18/2022 12:56	S22-0260	Malaban Health Center	7.54 / 28.5	0.94	ABSENCE	ABSENCE	< 1
BRGY. SANTO NIÑO							
01/19/2022 16:53	S22-0314	Jollibee National Hi-Way	7.44 / 27.2	0.24	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
01/19/2022 15:03	S22-0317	407 Water Pump, San Vicente Subdivision	7.51 / 29.1	0.18	ABSENCE	ABSENCE	< 1
01/06/2022 11:38	S22-0036	Drinking Fountain, San Vicente Elementary School	7.38 / 28.5	0.28	ABSENCE	ABSENCE	-
01/06/2022 12:01	S22-0037	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.27 / 26.1	0.18	ABSENCE	ABSENCE	-
01/06/2022 15:20	S22-0038	Cistern Tank, Central Mall	7.29 / 27.5	0.20	ABSENCE	ABSENCE	-
01/19/2022 17:43	S22-0308	Biñan Doctor's Hospital	7.42 / 27.6	0.16	ABSENCE	ABSENCE	< 1
BRGY. SANTO TOMAS							
01/28/2022 12:01	S22-0525	Water Pump, Adelina Complex 3	7.40 / 27.9	0.25	ABSENCE	ABSENCE	-
01/28/2022 12:13	S22-0526	HOA Office, Adelina Complex	7.35 / 26.5	0.18	ABSENCE	ABSENCE	-
01/06/2022 12:29	S22-0044	Water Pump, Pragmatic Subdivision	7.29 / 27.5	0.26	ABSENCE	ABSENCE	-
01/06/2022 12:40	S22-0045	Block 1 Lot 5, Bais St., Pragmatic	7.30 / 29.1	0.25	ABSENCE	ABSENCE	-
01/06/2022 14:21	S22-0033	Tawi Tawi St., Phase 6, South City Homes	7.39 / 26.1	0.26	ABSENCE	ABSENCE	-
01/06/2022 13:59	S22-0031	Water Pump, South Plains II Subdivision	7.29 / 27.8	0.40	ABSENCE	ABSENCE	-
01/06/2022 14:13	S22-0032	Block 11 Lot 2, South Plains II Subdivision	7.36 / 27.1	0.19	ABSENCE	ABSENCE	-


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
01/06/2022 10:41	S22-0039	Water Pump, Town & Country, Amsterdam	7.30 / 27.5	0.41	ABSENCE	ABSENCE	-
01/06/2022 10:55	S22-0040	Blk 35 Lot 21, Southville Town & Country	7.29 / 27.5	0.19	ABSENCE	ABSENCE	-
01/06/2022 11:10	S22-0041	Blk 2 Lot 5, Town & Country, Pennsylvania	7.26 / 26.1	0.28	ABSENCE	ABSENCE	-
01/06/2022 13:15	S22-0042	Water Pump, Phase 4, Olivarez Homes South	7.21 / 27.0	0.38	ABSENCE	ABSENCE	-
01/06/2022 13:22	S22-0043	Blk 1 Lt 16, Phase 4, Olivarez Homes South	7.33 / 28.1	0.25	ABSENCE	ABSENCE	-
BRGY. SORO – SORO							
01/18/2022 14:47	S22-0255	Water Pump, 9067 Manila S Road	7.38 / 27.4	0.96	ABSENCE	ABSENCE	50
01/18/2022 14:39	S22-0256	#76 Manila S Road	7.33 / 27.6	0.91	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO							
01/13/2022 10:40	S22-0178	Water Pump, San Antonio South	7.29 / 27.5	0.13	ABSENCE	ABSENCE	-
01/13/2022 10:51	S22-0179	Block 23 Lot 3, San Antonio South	7.38 / 26.5	0.10	ABSENCE	ABSENCE	-
BRGY. TUBIGAN							
01/06/2022 14:38	S22-0034	#60 Florinda Compound	7.28 / 27.5	0.21	ABSENCE	ABSENCE	-
BRGY. ZAPOTE							
01/17/2022 11:40	S22-0211	Water Pump, Summer Breeze	7.59 / 27.6	0.55	ABSENCE	ABSENCE	< 1
01/17/2022 11:49	S22-0212	Clubhouse, Summer Breeze	7.51 / 27.9	0.52	ABSENCE	ABSENCE	< 1
01/17/2022 12:04	S22-0213	Elevated Water Tank, Evergreen	7.59 / 28.1	1.12	ABSENCE	ABSENCE	< 1
01/17/2022 12:16	S22-0214	Clubhouse, Evergreen	7.58 / 27.6	1.12	ABSENCE	ABSENCE	< 1
01/17/2022 12:54	S22-0222	Water Pump, Jubilation Village - South	7.65 / 28.2	0.28	ABSENCE	ABSENCE	< 1
01/17/2022 13:03	S22-0223	Clubhouse, Jubilation Village - South	7.74 / 28.6	0.21	ABSENCE	ABSENCE	< 1
01/17/2022 14:31	S22-0221	Clubhouse, Jubilation Village - West	7.47 / 27.9	0.40	ABSENCE	ABSENCE	< 1
01/17/2022 14:44	S22-0226	Clubhouse, Althea Residences	7.70 / 27.6	0.23	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable


DEVIATIONS: No deviation noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.