

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 23

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 01/05/2022 – 01/13/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
01/05/2022 15:19	S22-0025	Laguna Wellfield 1	7.27 / 26.5	0.05	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN							
01/11/2022 15:01	S22-0136	Water Pump, Block 57, Phase 1, Southville	7.74 / 28.2	1.19	ABSENCE	ABSENCE	< 1
01/11/2022 15:14	S22-0137	Block 25 Lot 7, Phase 3, Southville	7.59 / 30.1	1.04	ABSENCE	ABSENCE	< 1
01/11/2022 14:39	S22-0140	Block 2 Lot 16, Phase 8, Southville	7.27 / 28.3	0.51	ABSENCE	ABSENCE	< 1
01/11/2022 14:55	S22-0138	Southville Integrated Highschool	7.76 / 30.2	1.19	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN							
01/11/2022 15:55	S22-0133	Gate Entrance, Alfonso Homes I	7.19 / 29.2	0.45	ABSENCE	ABSENCE	< 1
01/11/2022 16:04	S22-0131	#621 Rizal Boulevard	7.24 / 28.4	0.42	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK							
01/11/2022 16:25	S22-0132	Santa Rosa City Hall	7.17 / 29.0	0.41	ABSENCE	ABSENCE	< 1
01/11/2022 16:18	S22-0139	Drinking Fountain I, Central I Elementary	7.19 / 28.9	0.41	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN							
01/11/2022 16:44	S22-0130	Block 8 Lot 16, Bayshore III	7.28 / 28.7	0.43	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

[Signature]
ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. TAGAPO							
01/06/2022 12:15	S22-0047	#6031 JP Rizal Boulevard	7.56 / 29.5	0.56	ABSENCE	ABSENCE	-
01/06/2022 12:47	S22-0049	Block 1 Lot 18, Fairfield of Margana Subdivision	7.62 / 29.3	0.92	ABSENCE	ABSENCE	-
01/06/2022 12:30	S22-0057	Water Pump, Rosewood Homes I	7.56 / 29.8	1.19	ABSENCE	ABSENCE	-
01/06/2022 12:35	S22-0058	Block 3 Lot 31, Rosewood Homes I	7.56 / 28.5	1.06	ABSENCE	ABSENCE	-
01/06/2022 13:00	S22-0059	Block 2 Lot 8, Rosewood Homes II	7.56 / 28.9	1.12	ABSENCE	ABSENCE	-
01/06/2022 11:31	S22-0048	Clubhouse, Buena Rosa 1 Subdivision	7.25 / 27.1	0.08	ABSENCE	ABSENCE	-
01/06/2022 12:02	S22-0050	Block 1 Lot 64, Buena Rosa 10 Subdivision	7.18 / 28.2	0.08	ABSENCE	ABSENCE	-
01/06/2022 14:00	S22-0051	Cistern Tank, SM Santa Rosa	7.71 / 27.9	0.22	ABSENCE	ABSENCE	-
01/06/2022 14:06	S22-0052	Admin Pantry, SM Santa Rosa	7.66 / 27.7	0.75	ABSENCE	ABSENCE	-
01/06/2022 13:24	S22-0053	Cistern Tank, Robinson's Mall	7.86 / 29.7	0.06	ABSENCE	ABSENCE	-
01/06/2022 13:35	S22-0054	Buko House, Robinson's Mall	7.85 / 27.8	0.06	ABSENCE	ABSENCE	-
01/10/2022 14:00	S22-0076	Water Pump, Metrogate Heritage Subd.	7.38 / 27.4	0.77	ABSENCE	ABSENCE	< 1
01/10/2022 14:10	S22-0077	Clubhouse, Metrogate Heritage Subd.	7.40 / 27.5	0.59	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 45

TOTAL PARAMETERS TESTED : 5


ANALYSIS DATE(S) : 01/05/2022 – 01/28/2022

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)			
BRGY. BIÑAN							
01/05/2022 15:19	S22-0025	Laguna Wellfield 1	7.27 / 26.5	0.05	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO							
01/06/2022 11:10	S22-0046	#1354 Facundo Compound	7.29 / 26.1	0.09	ABSENCE	ABSENCE	-
01/10/2022 10:01	S22-0079	Clubhouse, South Hampton Residences	7.31 / 26.4	0.28	ABSENCE	ABSENCE	< 1
01/10/2022 13:40	S22-0075	Santos Residence, JB Village	7.29 / 26.5	0.38	ABSENCE	ABSENCE	< 1
01/28/2022 10:40	S22-0524	Cistern Tank, Waltermart Santa Rosa	7.65 / 26.5	0.15	ABSENCE	ABSENCE	-
01/28/2022 10:31	S22-0523	2 nd Floor faucet, Waltermart, Santa Rosa	7.80 / 27.6	0.01	ABSENCE	ABSENCE	-
BRGY. DILA							
01/10/2022 12:01	S22-0063	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.37 / 26.5	0.28	ABSENCE	ABSENCE	< 1
01/10/2022 12:10	S22-0064	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.40 / 27.6	0.19	ABSENCE	ABSENCE	< 1
01/10/2022 12:16	S22-0065	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	7.40 / 26.5	0.36	ABSENCE	ABSENCE	< 1
01/10/2022 12:22	S22-0066	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	7.29 / 27.8	0.24	ABSENCE	ABSENCE	< 1
01/17/2022 08:23	S22-0209	Clubhouse, Alabaster St., Villa Esmeralda	7.36 / 26.5	0.16	ABSENCE	ABSENCE	< 1
01/10/2022 12:21	S22-0067	Drinking Fountain, Dila Elementary	7.31 / 26.5	0.18	ABSENCE	ABSENCE	< 1
BRGY. DITA							
01/10/2022 12:45	S22-0068	Water Pump, Block 24 Lot 2, New Santa Rosa Homes	7.34 / 27.4	0.18	ABSENCE	ABSENCE	< 1
01/10/2022 12:31	S22-0069	Block 19 Lot 11, New Santa Rosa Homes	7.21 / 28.5	0.14	ABSENCE	ABSENCE	< 1
01/10/2022 12:59	S22-0070	Water Tank, SolCar Ville Subdivision	7.40 / 26.5	0.60	ABSENCE	ABSENCE	< 1
01/10/2022 13:10	S22-0071	Block 3 Lot 7, SolCar Ville Subdivision	7.48 / 27.6	0.45	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
01/10/2022 13:16	S22-0072	#1780, National Road	7.30 / 26.5	0.36	ABSENCE	ABSENCE	< 1
01/10/2022 14:18	S22-0078	R & B Ice Plant, Inc.	7.38 / 29.5	0.45	ABSENCE	ABSENCE	< 1
01/10/2022 10:18	S22-0080	Clubhouse, San Lorenzo Royale	7.28 / 27.5	0.24	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE							
01/18/2022 11:53	S22-0264	Science High School, Phase 1, Laguna Bel-Air	7.32 / 27.5	0.15	ABSENCE	ABSENCE	< 1
01/13/2022 12:40	S22-0187	Church, Block 108, Phase 5, Laguna Bel-Air	7.20 / 28.3	0.14	ABSENCE	ABSENCE	-
01/13/2022 13:49	S22-0186	Clubhouse, Phase 1, Laguna Bel-Air	7.29 / 27.9	0.19	ABSENCE	ABSENCE	-
01/13/2022 13:26	S22-0191	Block 47 Lot 12, Phase 4, Laguna Bel-Air	7.19 / 27.4	0.14	ABSENCE	ABSENCE	-
01/13/2022 11:05	S22-0180	Clubhouse, Phase 4B, Santa Rosa Village I	7.72 / 27.6	0.68	ABSENCE	ABSENCE	2
01/13/2022 11:15	S22-0181	Clubhouse, Santa Rosa Village II	7.71 / 26.7	0.68	ABSENCE	ABSENCE	-
01/13/2022 11:27	S22-0182	Pump 9 & 10, Santa Rosa Estates I	7.71 / 26.8	0.78	ABSENCE	ABSENCE	-
01/13/2022 11:33	S22-0183	Clubhouse, Santa Rosa Estates I	7.71 / 26.5	0.76	ABSENCE	ABSENCE	-
01/13/2022 12:07	S22-0192	Drinking Fountain, Don Jose National High School	7.14 / 26.1	1.76	ABSENCE	ABSENCE	-
BRGY. MACABLING							
01/06/2022 15:05	S22-0060	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	7.27 / 28.0	0.84	ABSENCE	ABSENCE	-
01/06/2022 14:44	S22-0055	Water Pump, Corinthian Subdivision	7.25 / 28.0	1.02	ABSENCE	ABSENCE	-
01/06/2022 14:56	S22-0056	Block 11 Lot 19, Corinthian Subdivision	7.32 / 28.3	0.87	ABSENCE	ABSENCE	-
BRGY. MALITLIT							
01/10/2022 13:29	S22-0073	Clubhouse, Casan Residencia Subdivision	7.25 / 26.5	0.16	ABSENCE	ABSENCE	< 1
01/10/2022 10:40	S22-0081	Water Pump, Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subdivision	7.37 / 26.5	0.40	ABSENCE	ABSENCE	< 1
01/10/2022 10:29	S22-0082	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subdivision	7.33 / 26.0	0.36	ABSENCE	ABSENCE	< 1
01/10/2022 11:16	S22-0085	Water Pump, Main Road, Phase 2, Terra Fortuna	7.25 / 27.5	0.16	ABSENCE	ABSENCE	< 1
01/10/2022 11:20	S22-0086	Block 11 Lot 16, Terra Fortuna	7.28 / 26.5	0.12	ABSENCE	ABSENCE	< 1
01/10/2022 10:59	S22-0083	Water Pump, 9999 W, Villa Las Casas	7.34 / 27.5	0.18	ABSENCE	ABSENCE	< 1
01/10/2022 11:10	S22-0084	Block 1 Lot 17, Villa Las Casas	7.38 / 29.1	0.14	ABSENCE	ABSENCE	< 1
01/10/2022 14:29	S22-0074	Drinking Fountain, Malitlit Elementary	7.28 / 27.5	0.18	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

[Signature]
ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

[Signature]
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC							
01/11/2022 15:29	S22-0134	Water Pump, Villa Mercedes	7.61 / 29.7	0.80	ABSENCE	ABSENCE	< 1
01/11/2022 15:37	S22-0135	Block 2 Lot 1, Villa Mercedes	7.56 / 29.6	0.93	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ							
01/17/2022 09:08	S22-0206	Block 6 Lot 8, Buklod Diwa	7.38 / 25.2	0.36	ABSENCE	ABSENCE	< 1
01/17/2022 08:46	S22-0207	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	7.34 / 25.5	0.15	ABSENCE	ABSENCE	< 1
01/17/2022 08:41	S22-0208	Wash Area, Pulong Sta. Cruz Elementary School	7.39 / 24.9	0.21	ABSENCE	ABSENCE	< 1
BRGY. SANTO DOMINGO							
01/13/2022 11:48	S22-0184	Clubhouse Santa Rosa Estates II	7.71 / 27.6	0.77	ABSENCE	ABSENCE	-

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric ; **C** - Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.