

CITY/MUNICIPALITY : BIÑAN	MONTH : March	YEAR : 2019
DOH ACCREDIATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-03-BIN

NO	SAMPLE LOCATION			DATE COLLECTED	MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE	HPC ¹ CFU/mL		Coliforms/100 mL ²		
					TOTAL	<i>Escherichia coli</i>	
BRGY. BIÑAN							
1	Laguna Well Field 1	S	4-Mar	< 1	ABSENCE	ABSENCE	
2	Guardhouse Entrance, Phase 4C, San Jose Village I	D	13-Mar	-	ABSENCE	ABSENCE	
3	Clubhouse, Phase 3B, San Jose Village I	D	13-Mar	-	ABSENCE	ABSENCE	
4	Pump 11, Phase 5, San Jose Village II	S	13-Mar	-	ABSENCE	ABSENCE	
5	Clubhouse, Phase 5, San Jose Village II	D	13-Mar	-	ABSENCE	ABSENCE	
6	Clubhouse, Phase 6, San Jose Village III	D	13-Mar	-	ABSENCE	ABSENCE	
7	Guardhouse, AVIDA Shophouse	D	13-Mar	-	ABSENCE	ABSENCE	
8	De La Salle University and Technology Complex	D	13-Mar	-	ABSENCE	ABSENCE	
BRGY. CANLALAY							
9	Clubhouse, Golden City Canlalay	D	11-Mar	-	ABSENCE	ABSENCE	
10	Drinking Fountain, Canlalay Elementary School	D	11-Mar	-	ABSENCE	ABSENCE	
BRGY. DELA PAZ							
11	Water Pump, Almeda Subdivision	S	11-Mar	-	ABSENCE	ABSENCE	
12	Barangay Hall	D	11-Mar	-	ABSENCE	ABSENCE	
BRGY. GANADO							
13	Drinking Fountain, Ganado Elementary School	D	13-Mar	-	ABSENCE	ABSENCE	
BRGY. HALANG							
14	9999 WP Metroville Complex	S	11-Mar	-	ABSENCE	ABSENCE	
15	Clubhouse, Metroville Complex	D	11-Mar	-	ABSENCE	ABSENCE	
BRGY. LANGKIWA							
16	Block 3 Lot 9, Phase II, Southville, Langkiwa	D	13-Mar	-	ABSENCE	ABSENCE	
BRGY. LOMA							
17	Water Pump, Block 4 Lot 37, Celina Technopark	S	13-Mar	-	ABSENCE	ABSENCE	
18	Block 43 Lot 13, Celina Technopark	D	13-Mar	-	ABSENCE	ABSENCE	
19	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air 3	D	5-Mar	< 1	ABSENCE	ABSENCE	
20	Block 10 Lot 24, Laguna Bel-Air 3	D	5-Mar	< 1	ABSENCE	ABSENCE	
21	Clubhouse, Laguna Bel-Air 3	D	5-Mar	< 1	ABSENCE	ABSENCE	
22	Drinking Fountain, Loma Elementary School	D	13-Mar	-	ABSENCE	ABSENCE	
BRGY. MAMPLASAN							
23	Clubhouse, Verdana Homes Subdivision	D	13-Mar	-	ABSENCE	ABSENCE	
24	United Laboratories (UNILAB) Inc.	D	13-Mar	-	ABSENCE	ABSENCE	
BRGY. POBLACION							
25	Water Pump, Brgy. Poblacion	S	11-Mar	-	ABSENCE	ABSENCE	
26	Brgy. Hall	D	11-Mar	-	ABSENCE	ABSENCE	
BRGY. PLATERO							
27	Elevated Water Tank, Mondo Bambini	S	14-Mar	-	ABSENCE	ABSENCE	
28	Clubhouse, Mondo Bambini	D	27-Mar	-	PRESENCE	ABSENCE	
29	Elevated Water Tank, Prima Casa	S	14-Mar	-	ABSENCE	ABSENCE	
30	Clubhouse, Prima Casa	D	14-Mar	-	ABSENCE	ABSENCE	
31	Water Pump, Spring Time	S	14-Mar	-	ABSENCE	ABSENCE	
32	Block 1 Lot 7, Spring Time	D	14-Mar	-	ABSENCE	ABSENCE	


33	Drinking Fountain, St. Michael School of Biñan	D	13-Mar	-	ABSENCE	ABSENCE
34	Sea-oil, National Road	D	13-Mar	-	ABSENCE	ABSENCE
BRGY. SAN ANTONIO						
35	Biñan City Hall	S	13-Mar	-	ABSENCE	ABSENCE
36	Alonte Stadium	D	13-Mar	-	ABSENCE	ABSENCE
37	Water Pump, Margarita Homes Subdivision	S	13-Mar	-	ABSENCE	ABSENCE
38	Block 5 Lot 12, Margarita Homes Subdivision	D	13-Mar	-	ABSENCE	ABSENCE
39	9022 Water Pump (WP) Faraon Subdivision	S	11-Mar	-	ABSENCE	ABSENCE
40	Malaban Health Center	D	11-Mar	-	ABSENCE	ABSENCE
41	Drinking Fountain 1, Malaban Elementary School	D	11-Mar	-	ABSENCE	ABSENCE
42	Drinking Fountain 2, Malaban Elementary School	D	11-Mar	-	ABSENCE	ABSENCE
43	Cistern Tank, Pavillion Mall	D	13-Mar	-	ABSENCE	ABSENCE
44	Mesa Inasal, Pavillion Mall	D	13-Mar	-	ABSENCE	ABSENCE
BRGY. SANTO NIÑO						
45	Jollibee National Hi-Way	D	13-Mar	-	ABSENCE	ABSENCE
BRGY. SAN VICENTE						
46	Block 8 Lot 6, Bayabas St., Phase 8 Olivarez Homes	D	11-Mar	-	ABSENCE	ABSENCE
47	Cistern Tank, Central Mall	D	11-Mar	-	ABSENCE	ABSENCE
48	Drinking Fountain, San Vicente Elementary Sch.	D	11-Mar	-	ABSENCE	ABSENCE
BRGY. SANTO TOMAS						
49	Water Pump, Adelina Subdivsion	S	13-Mar	-	ABSENCE	ABSENCE
50	Block 1 Lot 16, Phase 4, Olivarez Homes South	D	13-Mar	-	ABSENCE	ABSENCE
51	Water Pump, Pragmatic	S	11-Mar	-	ABSENCE	ABSENCE
52	Block 1 Lot 5, Bais St., Pragmatic	D	11-Mar	-	ABSENCE	ABSENCE
53	Tawi Tawi St., Phase 6, South City Homes	D	11-Mar	-	ABSENCE	ABSENCE
54	Pump, South Plains II Subdivision	S	11-Mar	-	ABSENCE	ABSENCE
55	Block 11 Lot 2, South Plains II Subdivision	D	11-Mar	-	ABSENCE	ABSENCE
56	Block 35 Lot 21, Southville Town and Country	D	13-Mar	-	ABSENCE	ABSENCE
57	Block 2 Lot 5, Town & Country - Pennsylvania	D	13-Mar	-	ABSENCE	ABSENCE
BRGY. SORO - SORO						
58	9067 Soro-soro	S	11-Mar	-	ABSENCE	ABSENCE
59	#76 Soro-Soro	D	11-Mar	-	ABSENCE	ABSENCE
BRGY. TUBIGAN						
60	#60 Florinda Compound	D	11-Mar	-	ABSENCE	ABSENCE
BRGY. ZAPOTE						
61	Wate Pump, Summer Breeze	S	14-Mar	-	ABSENCE	ABSENCE
62	Clubhouse, Summer Breeze	D	14-Mar	-	ABSENCE	ABSENCE
63	Elevated Water Tank, Evergreen	S	14-Mar	-	ABSENCE	ABSENCE
64	Clubhouse, Evergreen	D	14-Mar	-	ABSENCE	ABSENCE
65	Clubhouse, Althea	D	13-Mar	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		65	PNSDW LIMIT	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Collilert®-18)

CERTIFIED CORRECT:

 **ANNA KARLA S. GUTIERREZ, RMT**
Microbiologist
PRC License No. 0060968

NOTED BY:

 **CYRIL A. ERICA, RMT**
Laboratory Services Manager
PRC License No. 0054161

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : CABUYAO	MONTH : March	YEAR : 2019
DOH ACCREDIATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-03-CAB


NO	ADDRESS	TYPE	DATE COLLECTED	MICROBIOLOGICAL QUALITY		
				HPC ¹	Coliforms/100 mL ²	
					CFU/mL	TOTAL
BRGY. BANAY-BANAY						
1	Water Pump, Block 63, Lakeside Nest Subdivision	S	6-Mar	-	ABSENCE	ABSENCE
2	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	D	6-Mar	-	ABSENCE	ABSENCE
BRGY. BANLIC						
3	Water Pump, Gran Seville Subdivision	S	13-Mar	< 1	ABSENCE	ABSENCE
4	Gate Entrance, Gran Seville Subdivision	D	13-Mar	2	ABSENCE	ABSENCE
BRGY. BIGAA						
5	#253 Elsol Subdivision	D	6-Mar	-	ABSENCE	ABSENCE
BRGY. GULOD						
6	Block 12, Noah St., Celestine Ville	S	6-Mar	-	ABSENCE	ABSENCE
7	Guardhouse, Celestine Ville	D	6-Mar	-	ABSENCE	ABSENCE
BRGY. MARINIG						
8	Block 3 Lot 17, Phase 1, Celestine Homes	S	6-Mar	-	ABSENCE	ABSENCE
9	Block 23, Lot 10, Phase 1, Celestine Homes	D	6-Mar	-	ABSENCE	ABSENCE
10	Block 9, Carnation St., Phase 2, Celestine Homes	S	6-Mar	-	ABSENCE	ABSENCE
11	Block 13 Lot 2, Phase 2, Celestine Homes	D	6-Mar	-	ABSENCE	ABSENCE
BRGY. NIUGAN						
12	Water Pump, Block 25, Phase 3, Southville	S	6-Mar	-	ABSENCE	ABSENCE
13	Block 19 Lot 33, Phase 3, Southville	D	6-Mar	-	ABSENCE	ABSENCE
14	Block 2 Lot 6, St. Francis Homes 6	D	6-Mar	-	ABSENCE	ABSENCE
15	Water Pump, Block 45, Phase 8, Southville	S	6-Mar	-	ABSENCE	ABSENCE
16	Block 40 Lot 132, Southville	D	6-Mar	-	ABSENCE	ABSENCE
17	Water Pump, Block 54, Phase 10, Southville	S	6-Mar	-	ABSENCE	ABSENCE
18	Block 47 Lot 101, Phase 10, Southville	D	6-Mar	-	ABSENCE	ABSENCE
BRGY. SAN ISIDRO						
19	Block 3 Lot 33, Multiland IV	D	13-Mar	< 1	ABSENCE	ABSENCE
20	Water Pump, San Isidro Heights Subdivision	S	13-Mar	< 1	ABSENCE	ABSENCE
21	Block 3 Lot 1, San Isidro Heights Subdivision	D	13-Mar	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED			21	PNSDW	< 1	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

CITY/MUNICIPALITY : CABUYAO	MONTH : March	YEAR : 2019
DOH ACCREDITATION NO. : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-03-CAB


SAMPLE LOCATION				MICROBIOLOGICAL QUALITY		
NO	ADDRESS	TYPE	DATE COLLECTED	HPC ¹	Coliforms/100 mL ²	
				CFU/mL	TOTAL	<i>Escherichia coli</i>
BRGY. MAMATID						
1	Tank, Buena Rosario Subdivision	S	6-Mar	-	ABSENCE	ABSENCE
2	Block 7 Lot 6, Buena Rosario Subdivision	D	6-Mar	-	ABSENCE	ABSENCE
3	Block 101 Samar st., Phase 2, Mabuhay City	S	6-Mar	-	ABSENCE	ABSENCE
4	Block 94 Lot 57, Guimaras St., Phase 1, Mabuhay City	D	6-Mar	-	ABSENCE	ABSENCE
5	Block 141, Carmona St., Phase 2, Mabuhay City	S	6-Mar	-	ABSENCE	ABSENCE
6	Block 134 Lot 22, Phase 2, Mabuhay City	D	6-Mar	-	ABSENCE	ABSENCE
7	Block 198, Galacia St., Phase 2, Mabuhay City	S	13-Mar	< 1	ABSENCE	ABSENCE
8	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	D	13-Mar	< 1	ABSENCE	ABSENCE
9	Panganig St., Phase 3 Cluster, Mabuhay City	S	13-Mar	< 1	ABSENCE	ABSENCE
10	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	D	13-Mar	< 1	ABSENCE	ABSENCE
11	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	S	13-Mar	< 1	ABSENCE	ABSENCE
12	Block 19 Lot 13, Malang St., Phase 3 Luxury, Mabuhay	D	13-Mar	< 1	ABSENCE	ABSENCE
13	Water Pump, Joshua St., Phase 5, Mabuhay City	S	13-Mar	< 1	ABSENCE	ABSENCE
14	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	D	13-Mar	< 1	ABSENCE	ABSENCE
15	Source, Phase 1E Mabuhay Executive	S	6-Mar	-	ABSENCE	ABSENCE
16	Block 236 Lot 9, Phase 1E Mabuhay Executive	D	6-Mar	-	ABSENCE	ABSENCE
BRGY. PULO						
17	Water Pump, Block 12 Lot 22, Cabuyao Central	S	13-Mar	< 1	ABSENCE	ABSENCE
18	Clubhouse, Narra Avenue, Cabuyao Central	D	13-Mar	< 1	ABSENCE	ABSENCE
19	Water Pump, Block 11, Willow Park Homes	S	13-Mar	< 1	ABSENCE	ABSENCE
20	Clubhouse, Willow Park Homes	D	13-Mar	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED			20	PNSDW	<500	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

CITY/MUNICIPALITY : SANTA ROSA	MONTH : March	YEAR : 2019
DOH ACCREDIATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-03-STR

NO	ADDRESS	TYPE	DATE COLLECTED	MICROBIOLOGICAL QUALITY		
				HPC ¹	Coliforms/100 mL ²	
				CFU/mL	TOTAL	<i>Escherichia coli</i>
BRGY. CAINGIN						
1	Water Pump, Block 57, Phase 1, Southville	S	12-Mar	< 1	ABSENCE	ABSENCE
2	Block 25 Lot 7, Phase 3, Southville	D	12-Mar	< 1	ABSENCE	ABSENCE
3	Block 46 Lot 2, Phase 2, Southville	D	12-Mar	< 1	ABSENCE	ABSENCE
BRGY. KANLURAN						
4	#621 Rizal Boulevard	D	12-Mar	< 1	ABSENCE	ABSENCE
BRGY. LABAS						
5	Block 18 Lot 2, Alfonso Homes I	D	12-Mar	< 1	ABSENCE	ABSENCE
BRGY. MALUSAK						
6	Drinking Fountain 1, Central 1 Elementary Sch.	D	12-Mar	< 1	ABSENCE	ABSENCE
7	Drinking Fountain, Santa Rosa City Hall	D	12-Mar	150	ABSENCE	ABSENCE
BRGY. MARKET AREA						
8	Source, Market Area	S	12-Mar	< 1	ABSENCE	ABSENCE
BRGY. SINALHAN						
9	Block 8 Lot 16, Bayshore III	D	12-Mar	10	ABSENCE	ABSENCE
10	4026, Sinalhan Road, Purok 2	S	12-Mar	< 1	ABSENCE	ABSENCE
11	Amoranto Compound, Phase 2, Sinalhan	D	12-Mar	< 1	ABSENCE	ABSENCE
BRGY. TAGAPO						
12	Water Pump, Fairfield of Margana Subdivision	S	11-Mar	110	ABSENCE	ABSENCE
13	Block 2 Lot 21, Fairfield of Margana Subdivision	D	11-Mar	< 1	ABSENCE	ABSENCE
14	Water Pump, Rosewood Homes I	S	11-Mar	< 1	ABSENCE	ABSENCE
15	Block 3 Lot 31, Rosewood Homes I	D	11-Mar	< 1	ABSENCE	ABSENCE
16	Block 4 Lot 1, Rosewood Homes II	D	11-Mar	< 1	ABSENCE	ABSENCE
17	#31 JP Rizal Boulevard	D	11-Mar	290	ABSENCE	ABSENCE
18	Clubhouse, Buena Rosa 1 Subdivision	D	11-Mar	150	ABSENCE	ABSENCE
19	Water Pump, Buena Rosa 10 Subdivision	S	11-Mar	1	ABSENCE	ABSENCE
20	Block 1 Lot 64, Buena Rosa 10 Subdivision	D	11-Mar	1	ABSENCE	ABSENCE
21	Cistern Tank, SM Sta. Rosa	D	11-Mar	< 1	ABSENCE	ABSENCE
22	2nd Floor Faucet, SM Sta. Rosa	D	11-Mar	6	ABSENCE	ABSENCE
23	Cistern Tank, Robinson's Mall	D	11-Mar	140	ABSENCE	ABSENCE
24	Chummie Shawarma, Robinson's Mall	D	11-Mar	11	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED			24	PNSDW	<500	ABSENCE

REMARKS: Samples analyzed as submitted


LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:

 **ANNA KARLA S. GUTIERREZ, RMT**
Microbiologist
PRC License No. 0060968

NOTED BY:

 **CYRIL A. ERICA, RMT**
Laboratory Services Manager
PRC License No. 0054161

CITY/MUNICIPALITY		SANTA ROSA		MONTH		March		YEAR		2019	
DOH ACCREDITATION NO.		04A-001-1820-LW-2		VALIDITY		December 31, 2020		DOCUMENT NO.		19WQM-03-STR	
NO	SAMPLE LOCATION			DATE COLLECTED	MICROBIOLOGICAL QUALITY						
	ADDRESS	TYPE	HPC ¹		Coliforms/100 mL ²						
					CFU/mL	TOTAL	<i>Escherichia coli</i>				
BRGY. BALIBAGO											
1	#1354 Facundo Compound	D	11-Mar	330	ABSENCE	ABSENCE					
2	5555 Water Pump Elevated, South Hampton	S	14-Mar	-	ABSENCE	ABSENCE					
3	Clubhouse, South Hampton	D	14-Mar	-	ABSENCE	ABSENCE					
4	Block 5 Lot 19, JB Village, Sta. Rosa Tagaytay Road	D	11-Mar	< 1	ABSENCE	ABSENCE					
BRGY. DILA											
5	Phase 3E, Mabuhay Homes 2000	S	11-Mar	< 1	ABSENCE	ABSENCE					
6	Block 2 Lot 10, Mabuhay Homes 2000	D	11-Mar	< 1	ABSENCE	ABSENCE					
7	Block 12, Phase 2E, Mabuhay Homes 2000	S	11-Mar	< 1	ABSENCE	ABSENCE					
8	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	D	11-Mar	1	ABSENCE	ABSENCE					
9	Drinking Fountain, Dila Elementary School	D	11-Mar	< 1	ABSENCE	ABSENCE					
BRGY. DITA											
10	Block 24 Lot 2, New Santa Rosa Homes	S	11-Mar	< 1	ABSENCE	ABSENCE					
11	Block 19 Lot 11, New Santa Rosa Homes	D	11-Mar	< 1	ABSENCE	ABSENCE					
12	Block 4 Lot 32, San Lorenzo Royale	S	14-Mar	-	ABSENCE	ABSENCE					
13	Block 11 Lot 52, San Lorenzo Royale	D	14-Mar	-	ABSENCE	ABSENCE					
14	Water Tank, SolCar Ville Subdivision	S	11-Mar	< 1	ABSENCE	ABSENCE					
15	Block 3 Lot 7, SolCar Ville Subdivision	D	11-Mar	< 1	ABSENCE	ABSENCE					
16	Clubhouse, Villa Esmeralda	D	14-Mar	-	ABSENCE	ABSENCE					
17	#1780 National Road	D	11-Mar	< 1	ABSENCE	ABSENCE					
18	R & B Ice Plant, Inc.	D	11-Mar	1	ABSENCE	ABSENCE					
19	Science High School, Phase 1, Laguna Bel-Air	D	5-Mar	< 1	ABSENCE	ABSENCE					
20	Block 34 Lot 59, Phase 1, Laguna Bel-Air	D	5-Mar	< 1	ABSENCE	ABSENCE					
21	Church, Block 108, Phase 5, Laguna Bel-Air	D	5-Mar	< 1	ABSENCE	ABSENCE					
22	Block 47 Lot 12 Laguna Bel-Air IV	D	5-Mar	< 1	ABSENCE	ABSENCE					
23	8001, Pump 1, Acacia St., Santa Rosa Village I	S	5-Mar	3	ABSENCE	ABSENCE					
24	Clubhouse, Phase 4B, Santa Rosa Village I	D	5-Mar	< 1	ABSENCE	ABSENCE					
25	Clubhouse, Santa Rosa Village II	D	5-Mar	< 1	ABSENCE	ABSENCE					
26	Pump 9 & 10, Santa Rosa Estates I	S	5-Mar	< 1	ABSENCE	ABSENCE					
27	Clubhouse Santa Rosa Estates I	D	5-Mar	< 1	ABSENCE	ABSENCE					
BRGY. DON JOSE											
28	Drinking Fountain, Don Jose National High School	D	5-Mar	< 1	ABSENCE	ABSENCE					
BRGY. MACABLING											
29	Deepwell, Buena Rosa 9 Subdivision	S	11-Mar	25	ABSENCE	ABSENCE					
30	Block 4 Lot 26, Phase 2, Buena Rosa 9 Subdivision	D	11-Mar	91	ABSENCE	ABSENCE					
31	Deepwell, Corinthian Subdivision	S	11-Mar	< 1	ABSENCE	ABSENCE					
32	Block 11 Lot 19, Corinthian Subdivision	D	11-Mar	< 1	ABSENCE	ABSENCE					
33	Water Pump, Metrogate	S	11-Mar	2	ABSENCE	ABSENCE					
34	Clubhouse, Metrogate	D	11-Mar	1	ABSENCE	ABSENCE					
BRGY. MALITLIT											
35	Clubhouse Casan Residencia Subdivision	D	11-Mar	< 1	ABSENCE	ABSENCE					
36	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	S	14-Mar	-	ABSENCE	ABSENCE					


37	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	D	14-Mar	-	ABSENCE	ABSENCE
38	Main Road, Phase 2, Terra Fortuna	S	14-Mar	-	ABSENCE	ABSENCE
39	Block 11 Lot 16, Terra Fortuna	D	14-Mar	-	ABSENCE	ABSENCE
40	9999 W, Villa Las Casas	S	14-Mar	-	ABSENCE	ABSENCE
41	Block 1 Lot 17, Villa Las Casas	D	14-Mar	-	ABSENCE	ABSENCE
42	Drinking Fountain, Malitlit Elementary School	D	11-Mar	< 1	ABSENCE	ABSENCE
43	Blowoff, Eton City	D	5-Mar	< 1	ABSENCE	ABSENCE
BRGY. POOC						
44	Deepwell, Alinsod	S	12-Mar	< 1	ABSENCE	ABSENCE
45	Tank, Villa Mercedes	S	12-Mar	< 1	PRESENCE	ABSENCE
46	Block 2 Lot 1, Villa Mercedes	D	12-Mar	< 1	ABSENCE	ABSENCE
47	Drinking Fountain 1, Pulong Sta. Cruz Elementary Sch.	D	14-Mar	-	ABSENCE	ABSENCE
48	Drinking Fountain 2, Pulong Sta. Cruz Elementary Sch.	D	14-Mar	-	ABSENCE	ABSENCE
49	Block 6 Lot 8, Buklod Diwa	D	14-Mar	-	ABSENCE	ABSENCE
BRGY. SANTO DOMINGO						
50	Clubhouse Santa Rosa Estates II	D	5-Mar	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		50	PNSDW LIMIT	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:


ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0885 Date Issued : 04/04/2019
 Sample Code : S19-978 Document Number : 19-WQM-03-CAL-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/04/2019 13:24 Date/Time Submitted : 03/04/2019 15:12
 Collected By : Ohwen L. Cantindig Submitted By : Ohwen L. Cantindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 12 SAMAT ST., PHASE 1, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/04/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0886 Date Issued : 04/04/2019
 Sample Code : S19-979 Document Number : 19-WQM-03-CAL-02
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/04/2019 13:27 Date/Time Submitted : 03/04/2019 15:12
 Collected By : Ohwen L. Cantindig Submitted By : Ohwen L. Cantindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : BLOCK 11 KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/04/2019	JDE

Remarks: Samples Analyzed as Submitted.


Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0887 Date Issued : 04/04/2019
 Sample Code : S19-980 Document Number : 19-WQM-03-CAL-03
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/04/2019 13:46 Date/Time Submitted : 03/04/2019 15:12
 Collected By : Ohwen L. Cantindig Submitted By : Ohwen L. Cantindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/04/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0888 Date Issued : 04/04/2019
 Sample Code : S19-981 Document Number : 19-WQM-03-CAL-04
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/04/2019 12:36 Date/Time Submitted : 03/04/2019 15:12
 Collected By : Ohwen L. Cantindig Submitted By : Ohwen L. Cantindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	6	9215B. Pour Plate Method	03/04/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0889 Date Issued : 04/04/2019
 Sample Code : S19-982 Document Number : 19-WQM-03-CAL-05
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/04/2019 12:47 Date/Time Submitted : 03/04/2019 15:12
 Collected By : Ohwen L. Cantindig Submitted By : Ohwen L. Cantindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	2	9215B. Pour Plate Method	03/04/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0890 Date Issued : 04/04/2019
 Sample Code : S19-983 Document Number : 19-WQM-03-CAL-06
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/04/2019 12:53 Date/Time Submitted : 03/04/2019 15:12
 Collected By : Ohwen L. Cantindig Submitted By : Ohwen L. Cantindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/04/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0891 Date Issued : 04/04/2019
 Sample Code : S19-984 Document Number : 19-WQM-03-CAL-07
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/04/2019 13:02 Date/Time Submitted : 03/04/2019 15:12
 Collected By : Ohwen L. Cantindig Submitted By : Ohwen L. Cantindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 39 LOT 5, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/04/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/04/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0875 Date Issued : 04/03/2019
 Sample Code : S19-1422 Document Number : 19-WQM-03-ALA-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 14:34 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 “Philippine National Standards for Drinking Water of 2017”

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER TANK, BELLA VITA HOMES, SAN ANDRES, ALAMINOS, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0877 Date Issued : 04/03/2019
 Sample Code : S19-1424 Document Number : 19-WQM-03-PAB-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 16:27 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : CLUBHOUSE, BELLA VITA HOMES, SAN ANDRES, ALAMINOS, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0877 Date Issued : 04/03/2019
 Sample Code : S19-1424 Document Number : 19-WQM-03-PAB-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 14:42 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP, BELLA VITA SUBDIVISION, SAN BARTOLOME, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/1/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0878 Date Issued : 04/03/2019
 Sample Code : S19-1425 Document Number : 19-WQM-03-PAB-02
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 15:04 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 95 LOT 2 & 3, BELLA VITA SUBDIVISION, SAN BARTOLOME, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.


Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0879 Date Issued : 04/03/2019
 Sample Code : S19-1426 Document Number : 19-WQM-03-PAB-03
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 13:48 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0880 Date Issued : 04/03/2019
 Sample Code : S19-1427 Document Number : 19-WQM-03-PAB-04
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 13:54 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 “Philippine National Standards for Drinking Water of 2017”

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BLOCK 65 LOT 2, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0881 Date Issued : 04/03/2019
 Sample Code : S19-1428 Document Number : 19-WQM-03-STR-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 11:26 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : SOURCE, AFTER DMI-65 FILTRATION, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0882 Date Issued : 04/03/2019
 Sample Code : S19-1429 Document Number : 19-WQM-03-STR-02
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 11:39 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : GRANDSTAND, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0883 Date Issued : 04/03/2019
 Sample Code : S19-1430 Document Number : 19-WQM-03-STR-03
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 12:03 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18 [®])	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18 [®])	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0884 Date Issued : 04/03/2019
 Sample Code : S19-1431 Document Number : 19-WQM-03-STR-04
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 12:32 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : OLD CAPITOL BUILDING, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18 [®])	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18 [®])	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0885 Date Issued : 04/03/2019
Sample Code : S19-1432 Document Number : 19-WQM-03-STR-05
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 03/25/2019 12:08 Date/Time Submitted : 03/25/2019 17:25
Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Distribution – Network Sampling Point
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : CISTERN TANK, LAGUNA MEDICAL CENTER, LAGUNA, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.
Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0886 Date Issued : 04/03/2019
 Sample Code : S19-1433 Document Number : 19-WQM-03-STR-06
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/25/2019 12:17 Date/Time Submitted : 03/25/2019 17:25
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : KITCHEN, LAGUNA MEDICAL CENTER, LAGUNA, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/25/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/25/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:



CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0892 Date Issued : 04/04/2019
 Sample Code : S19-1031 Document Number : 19-WQM-03-PAG-01
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 11:55 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : WATER PUMP, PUROK 6, MORESCO VILLE 2, SABANG, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	16	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0893 Date Issued : 04/04/2019
Sample Code : S19-1032 Document Number : 19-WQM-03-PAG-02
Name of Company / Customer : Laguna Water Corporation
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
Date/Time Collected : 03/05/2019 12:01 Date/Time Submitted : 03/05/2019 20:35
Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
Sample Source Characteristics : Distribution – Network Sampling Point
References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 “Philippine National Standards for Drinking Water of 2017”

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : RESERVOIR, PUROK 6, MORESCO VILLE 2, SABANG, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	13	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist
PRC License No. 0060968

NOTED BY:


CYRIL A. ERICA, RMT
Laboratory Services Manager
PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0894 Date Issued : 04/04/2019
 Sample Code : S19-1033 Document Number : 19-WQM-03-PAG-03
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 13:10 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : PUMP STATION #5, POBLACION 2, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	10	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0895 Date Issued : 04/04/2019
 Sample Code : S19-1034 Document Number : 19-WQM-03-PAG-04
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 13:22 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : PUMP STATION #4, BRGY. UNO, POBLACION 1, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.


Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0050968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0896 Date Issued : 04/04/2019
 Sample Code : S19-1035 Document Number : 19-WQM-03-PAG-05
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 13:33 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 “Philippine National Standards for Drinking Water of 2017”

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : HERNANDEZ RESIDENCE, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/1/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0897 Date Issued : 04/04/2019
 Sample Code : S19-1036 Document Number : 19-WQM-03-PAG-06
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 13:38 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : MENDOZA RESIDENCE, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	11	9215B. Pour Plate Method	03/05/2019	JDE


Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0898 Date Issued : 04/04/2019
 Sample Code : S19-1037 Document Number : 19-WQM-03-PAG-07
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 13:50 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : #248 GEN. LUNA ST., BRGY. MULAWIN, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/1/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0899 Date Issued : 04/04/2019
 Sample Code : S19-1038 Document Number : 19-WQM-03-PAG-08
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 14:07 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : PUMP STATION #7, BRGY. PINAGSANGAN, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	1	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/1/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0900 Date Issued : 04/04/2019
 Sample Code : S19-1039 Document Number : 19-WQM-03-PAG-09
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 14:18 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : MANALO RESIDENCE, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0901 Date Issued : 04/04/2019
 Sample Code : S19-1040 Document Number : 19-WQM-03-PAG-10
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 14:28 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : PUMP STATION #2, PINAGSANGAN, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	3	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.


Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0902 Date Issued : 04/04/2019
 Sample Code : S19-1041 Document Number : 19-WQM-03-PAG-11
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 14:36 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point 4
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : EMIL'S PANSITAN, PINAGSANGAN, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	43	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.

Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0903 Date Issued : 04/04/2019
 Sample Code : S19-1042 Document Number : 19-WQM-03-PAG-12
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 14:49 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point 4
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : BIG BOY EATERY, RIZAL STREET, BRGY. DOS, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.


Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/9/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0904 Date Issued : 04/04/2019
 Sample Code : S19-1043 Document Number : 19-WQM-03-PAG-13
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 15:05 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point 4
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : DELOS REYES RESIDENCE, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	3	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.


Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 4/4/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-0905 Date Issued : 04/04/2019
 Sample Code : S19-1044 Document Number : 19-WQM-03-PAG-14
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 03/05/2019 15:25 Date/Time Submitted : 03/05/2019 20:35
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point 4
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS


SAMPLE LOCATION : PAGWAD OFFICE, J.P RIZAL ST., BRGY. DOS, PAGSANJAN, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/05/2019	JDE
Heterotrophic Plate Count	CFU/mL	15	9215B. Pour Plate Method	03/05/2019	JDE

Remarks: Samples Analyzed as Submitted.


Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT
 Laboratory Services Manager
 PRC License No. 0054161

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis