

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1987

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 07:00

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : WATER PUMP, MORESCO VILLE II, BRGY. SABANG, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1988

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 07:15

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : RESERVOIR, MORESCO VILLE II, BRGY. SABANG, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1989

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 09:30

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : ARROYO RESIDENCE, BRGY. POBLACION 2, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s) (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1990

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 11:15

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : DIMAYUGA RESIDENCE, BRGY. SAMPALOC, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | 18 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1991

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 10:37

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : PUMP STATION 5, BRGY. POBLACION 2, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1992

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 08:14

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : BIG BOY EATERY, RIZAL STREET, BRGY. POBLACION 2, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|--|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Collert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Collert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | 4 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1993

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 09:45

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : DELOS REYES RESIDENCE, BRGY. UNO POBLACION 1, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | 12 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1994

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 10:48

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : PUMP STATION 4, BRGY. POBLACION UNO, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1995

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 08:47

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : PUMP STATION 7, BRGY. PINAGSANGAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1996

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 09:25

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : EMIL'S PANSITAN, BRGY. PINAGSANGAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s): (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1997

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 09:15

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : PUMP STATION 2, BRGY. PINAGSANGAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s): (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1998

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 09:00

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : MANALO RESIDENCE, BRGY. PINAGSANGAN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-1999

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 08:29

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : ZALAMEDA RESIDENCE., BRGY. MAULAWIN, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-2000

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 10:15

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : PAGWAD OFFICE, J.P. RIZAL ST., BRGY. DOS, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-2001

DATE/TIME SUBMITTED : 04/01/2020 14:06

DATE/TIME COLLECTION : 04/01/2020 07:52

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : AGUILAR RESIDENCE, BRGY. SAMPALOC, PAGSANJAN, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|----------------|---|------------|-----|
| | | | | DATE | BY |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 04/01/2020 | ACP |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 04/01/2020 | ACP |

REMARKS: Samples were analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

JETHRO D. ESCOBIN
Microbiology Unit Manager

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis