

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6382

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 09:40

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : WATER PUMP, MORESCO VILLE II, BRGY. SABANG, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.17	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6383

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 10:01

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : RESERVOIR, MORESCO VILLE II, BRGY. SABANG, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.35	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna AAWater Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S21-6384

**DATE/TIME SUBMITTED :** 09/09/2021 16:03

**DATE/TIME COLLECTION :** 09/09/2021 10:21

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** MAGNAYE RESIDENCE, BRGY. CABANBANAN, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.28	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6385

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 11:03

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : DIMAYUGA RESIDENCE, BRGY. SAMPALOC, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.28	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	63	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLAIS GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna AAWater Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION : N/A**

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S21-6386

**DATE/TIME SUBMITTED :** 09/09/2021 16:03

**DATE/TIME COLLECTION :** 09/09/2021 11:59

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** PUMP STATION 5, BRGY. POBLACION II, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	<b>0.38</b>	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<b>&lt; 1</b>	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6387

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 12:30

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : BIG BOY EATERY, RIZAL STREET, BRGY. POBLACION II, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.12	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)



**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna AAWater Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S21-6388

**DATE/TIME SUBMITTED :** 09/09/2021 16:03

**DATE/TIME COLLECTION :** 09/09/2021 12:45

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** DE DIOS RESIDENCE, BRGY. POBLACION I, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.24	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	48	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6389

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 11:30

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : PAGWAD OFFICE, BRGY. POBLACION II, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.33	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	2	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)



**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6390

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 14:31

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : SAMPALOC ELEMENTARY SCHOOL, BRGY. SAMPALOC, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.29	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6391

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 14:20

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : PUMP STATION 2, BRGY. PINAGSANJAN, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.38	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6392

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 13:45

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : FERRER RESIDENCE, BRGY. SAN ISIDRO, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.16	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna AAWater Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S21-6393

**DATE/TIME SUBMITTED :** 09/09/2021 16:03

**DATE/TIME COLLECTION :** 09/09/2021 13:20

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** PUMP STATION 4, BRGY. POBLACION I, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.35	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	5	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6394

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 14:05

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : PUMP STATION 7, BRGY. PINAGSANJAN, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.38	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	2	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna AAWater Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

## SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S21-6377

**DATE/TIME SUBMITTED :** 09/09/2021 16:03

**DATE/TIME COLLECTION :** 09/09/2021 09:28

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** AREZA PUBLIC MARKET, BRGY. BIÑAN, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.20	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)



**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6378

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 08:00

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : OLAN RESIDENCE, VILLA CORAZON ST., BRGY. BIÑAN, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.35	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6379

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 08:20

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : SITIO 3, PANTAY ROAD JESSI OCTABIO II, BRGY. BIÑAN, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.37	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME :** Laguna AAWater Corporation

**ADDRESS :** G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION :** N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S) :** S21-6380

**DATE/TIME SUBMITTED :** 09/09/2021 16:03

**DATE/TIME COLLECTION :** 09/09/2021 08:45

**COLLECTED BY :** Edwin O. Aguilar

**NO. OF SAMPLES :** 1

**TOTAL PARAMETERS TESTED :** 4

**SAMPLE LOCATION :** ASILLOS RESIDENCE BOUNDARY, BRGY. BIÑAN, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS :** 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.25	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	2	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE: A** – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME** : Laguna AAWater Corporation

**ADDRESS** : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

**ATTENTION** : N/A

### SUMMARY OF LABORATORY ANALYSIS

**SAMPLE CODE(S)** : S21-6381

**DATE/TIME SUBMITTED** : 09/09/2021 16:03

**DATE/TIME COLLECTION** : 09/09/2021 09:16

**COLLECTED BY** : Edwin O. Aguilar

**NO. OF SAMPLES** : 1

**TOTAL PARAMETERS TESTED** : 4

**SAMPLE LOCATION** : PHOENIX GAS STATION, BRGY. BIÑAN, PAGSANJAN, LAGUNA

**SAMPLE CHARACTERISTICS** : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.15	4500-Cl-G.DPD Colorimetric	09/09/2021	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	09/09/2021	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	09/09/2021	ACP

**REMARKS:** Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

\*- Performed onsite


**DEVIATIONS:** No deviations noted on sample collection and submission.

**METHOD REFERENCE:** Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:

  
ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

  
KRISTEEN Y. ALDAY, RCh  
Analytical Service Unit Manager  
License No(s). (PRC 0013295)

  
ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)