

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-2506

DATE/TIME SUBMITTED : 05/10/2023 15:30

DATE/TIME COLLECTION : 05/10/2023 12:00

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, BELLA VITA SUBDIVISION, BRGY. SAN BARTOLOME, SAN PABLO CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	1.15	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/10/2023	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/10/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/10/2023	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	05/10/2023	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-2507

DATE/TIME SUBMITTED : 05/10/2023 15:30

DATE/TIME COLLECTION : 05/10/2023 12:20

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : CLUBHOUSE, BELLA VITA SUBDIVISION, BRGY. SAN BARTOLOME, SAN PABLO CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.48	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/10/2023	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/10/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/10/2023	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	05/10/2023	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCH
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-2504

DATE/TIME SUBMITTED : 05/10/2023 15:30

DATE/TIME COLLECTION : 05/10/2023 10:50

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.52	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/10/2023	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/10/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/10/2023	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	<500 (cfu/mL)	9215B. Pour Plate Method	05/10/2023	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


CUSTOMER NAME : Laguna Water Corporation

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCH
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S23-2505

DATE/TIME SUBMITTED : 05/10/2023 15:30

DATE/TIME COLLECTION : 05/10/2023 11:25

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BLOCK 65 LOT 23, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYSIS	
					DATE	BY
*Residual Chlorine	mg/L	0.30	0.30 – 1.50	4500-Cl-G.DPD Colorimetric	05/10/2023	EOA
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/10/2023	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/10/2023	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	<500 (cfu/mL)	9215B. Pour Plate Method	05/10/2023	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE




REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)