

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2488 Date Prepared : 09/03/2019
 Sample Code : S19-4391
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 08/21/2019 11:30 Date/Time Submitted : 08/21/2019 22:40
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : WATER PUMP, BELLA VITA SUBDIVISION, SAN BARTOLOME, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18 [®])	8/21/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18 [®])	8/21/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist, Head
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
 Laboratory Services Manager
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2489 Date Prepared : 09/03/2019
 Sample Code : S19-4392
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 08/21/2019 11:36 Date/Time Submitted : 08/21/2019 22:40
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Distribution – Network Sampling Point
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : CLUBHOUSE, BELLA VITA SUBDIVISION, SAN BARTOLOME, SAN PABLO, LAGUNA


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	8/21/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	8/21/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist, Head
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
 Laboratory Services Manager
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/3/19

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2490 Date Prepared : 09/03/2019
 Sample Code : S19-4393
 Name of Company / Customer : Laguna Water Corporation
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna
 Date/Time Collected : 08/21/2019 13:12 Date/Time Submitted : 08/21/2019 22:40
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)
 References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : WATER PUMP, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18 [®])	8/21/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18 [®])	8/21/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Microbiologist, Head
 PRC License No. 0060968

NOTED BY:


 CYRIL A. ERICA, RMT, MLS(ASCP)^{CM}
 Laboratory Services Manager
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-2491 Date Prepared : 09/03/2019

Sample Code : S19-4394

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 08/21/2019 13:16 Date/Time Submitted : 08/21/2019 22:40

Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig

Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

Sample Source Characteristics : Distribution – Network Sampling Point

References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : BLOCK 65 LOT 2, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	8/21/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	8/21/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Microbiologist, Head
PRC License No. 0060968

NOTED BY:


CYRILA A. ERICA, RMT, MLS(ASCP)^{CM}
Laboratory Services Manager
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis