

DOH Accredited Testing Laboratory (04A-002-2123-LW-22); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna AAAWater Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S21-5192

DATE/TIME SUBMITTED : 07/15/2021 15:16

DATE/TIME COLLECTION : 07/15/2021 13:30

COLLECTED BY . Edwi

COLLECTED BY: Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED: 3

SAMPLE LOCATION : SOURCE AFTER DMI-65 FILTRATION, LAGUNA SPORTS COMPLEX, BRGY.BUBUKAL, SANTA CRUZ,

LAGUNA

SAMPLE CHARACTERISTICS

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/15/2021	NGR
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/15/2021	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	07/15/2021	NGR

REMARKS: Sample collection was performed by LWC accredited sampler and was analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

ALYSSA MARIE C. PENALES, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0064969)

Laboratory Services Manager License No. (CRC 0060968)

ANNA KARLA

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna AAAWater Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S21-5193

DATE/TIME SUBMITTED : 07/15/2021 15:16

DATE/TIME COLLECTION : 07/15/2021 13:15

COLLECTED BY: Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : OVAL, LAGUNA UNIVERSITY, BRGY. BUBUKAL, SANTA CRUZ CITY, LAGUNA

SAMPLE

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate **CHARACTERISTICS**

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/15/2021	NGR
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/15/2021	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	07/15/2021	NGR

REMARKS: Sample collection was performed by LWC accredited sampler and was analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT OR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

ALYSSA MARIE CIPENALES, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0064969)

ANNA KARLA Laboratory Services Manager License No(s) (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna AAAWater Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION: N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : **S21-5197 DATE/TIME SUBMITTED** : 07/15/2021 15:16

DATE/TIME COLLECTION : 07/15/2021 12:30 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL, SANTA

CRUZ CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

ANALYSIS PARAMETER(S) UNIT(S) RESULT(S) METHOD(S) DATE BY 9223B. Enzyme Substrate **Total Coliform** Coliforms/100 mL 07/15/2021 NGR **ABSENCE** Test (Colilert-18®) Thermotolerant Coliform / 9223B. Enzyme Substrate 07/15/2021 Coliforms/100 mL **ABSENCE** NGR Escherichia coli Test (Colilert-18®) **Heterotrophic Plate Count** Colony Forming 1 9215B. Pour Plate Method 07/15/2021 NGR (HPC)A Unit (CFU)/mL

REMARKS: Sample collection was performed by LWC accredited sampler and was analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

ALYSSA MARIE PENALES, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0064969) **CERTIFIED CORRECT BY:**

ANNA KARLA S. GUTIERREZ, RMT Laboratory Services Manager License No(s). (PPC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna AAAWater Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S21-5198 DATE/TIME SUBMITTED : 07/15/2021 15:16

DATE/TIME COLLECTION : 07/15/2021 12:45 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : OLD CAPITOL BLDG., CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL,

SANTA CRUZ CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/15/2021	NGR
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/15/2021	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	07/15/2021	NGR

REMARKS: Sample collection was performed by LWC accredited sampler and was analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

ALYSSA MARIE PENALES, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0064969) ANNA KARLA'S. GUTIERREZ, RM'
Laboratory Services Manager
License No(s). (PRC 0050968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-002-2123-LW-22); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna AAAWater Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

DATE/TIME SUBMITTED : 07/15/2021 15:16 SAMPLE CODE(S) : S21-5199

COLLECTED BY : Edwin O. Aguilar **DATE/TIME COLLECTION** : 07/15/2021 14:18

TOTAL PARAMETERS TESTED : 3 NO. OF SAMPLES : 1

SAMPLE LOCATION : KITCHEN, LAGUNA MEDICAL CENTER, SANTA CRUZ CITY, LAGUNA

SAMPLE

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate CHARACTERISTICS

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/15/2021	NGR
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/15/2021	NGR
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	1	9215B. Pour Plate Method	07/15/2021	NGR

REMARKS: Sample collection was performed by LWC accredited sampler and was analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

ALYSSA MARIE PENALES, RMT Microbiology Unit Manager (OIC) License No(s). (PRC 0064969)

ANNA KARLA Laboratory/Services Manager

License Nots). (RRC 0060958)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis