

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-2110

DATE/TIME SUBMITTED : 05/21/2025 13:20

DATE/TIME COLLECTION : 05/21/2025 10:30

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, SANTA CRUZ SPORTS COMPLEX, BRGY. BUBUKAL SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|-------------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.74 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 05/21/2025 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 05/21/2025 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*. Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE




REVIEWED BY:


SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-3266

DATE/TIME SUBMITTED : 05/21/2025 13:20

DATE/TIME COLLECTION : 05/21/2025 10:48

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : OVAL SPORTS COMPLEX, BRGY. BUBUKAL, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(/S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|--------------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.55 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 05/21/2025 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 05/21/2025 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*. Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE




REVIEWED BY:


SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-3260

DATE/TIME SUBMITTED : 05/21/2025 13:20

DATE/TIME COLLECTION : 05/21/2025 10:10

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVENUE, LAGUNA PROVINCIAL CAPITOL, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|-------------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 1.20 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 05/21/2025 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 05/21/2025 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:

KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-3261

DATE/TIME SUBMITTED : 05/21/2025 13:20

DATE/TIME COLLECTION : 05/21/2025 08:40

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : OLD CAPITOL BUILDING, CAPITOL COMPOUND, P. GUEVERRA AVENUE, LAGUNA PROVINCIAL CAPITOL, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|----------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.65 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 05/21/2025 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 05/21/2025 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017

NOT VALID WITHOUT QR CODE



REVIEWED BY:

SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:

KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-3263

DATE/TIME SUBMITTED : 05/21/2025 13:20

DATE/TIME COLLECTION : 05/21/2025 09:48

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : CISTERN TANK, LAGUNA MEDICAL CENTER, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|-------------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.70 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 05/21/2025 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 05/21/2025 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*. Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE




REVIEWED BY:


SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-3262

DATE/TIME SUBMITTED : 05/21/2025 13:20

DATE/TIME COLLECTION : 05/21/2025 09:29

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : KITCHEN, LAGUNA MEDICAL CENTER, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|-------------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.65 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 05/21/2025 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 05/21/2025 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*. Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE




REVIEWED BY:


SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-3264

DATE/TIME SUBMITTED : 05/21/2025 13:20

DATE/TIME COLLECTION : 05/21/2025 09:10

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : HAND HYGIENE, PROVINCIAL CAPITOL, SANTA CRUZ, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | PNSDW LIMIT(S) | METHOD(S) | ANALYSIS | |
|---|------------------------------|-----------|-------------------|---|------------|-----|
| | | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.38 | 0.30 – 1.50 | 4500-Cl-G.DPD Colorimetric | 05/21/2025 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 05/21/2025 | SBA |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | <500 (cfu/mL) | 9215B. Pour Plate Method | 05/21/2025 | SBA |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: ^A – Method is not part of DENR-ELR Recognized Parameters

*. Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.


METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

STANDARD REFERENCE: Standard Limit is based on Philippine National Standards for Drinking Water of 2017


NOT VALID WITHOUT QR CODE




REVIEWED BY:


SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis