

DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111

PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

**CUSTOMER NAME**: Laguna AAAWater Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

### **SUMMARY OF LABORATORY ANALYSIS**

SAMPLE CODE(S) : S20-6470 DATE/TIME SUBMITTED : 10/01/2020 16:20

DATE/TIME COLLECTION : 10/01/2020 08:00 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : SOURCE AFTER DMI-65 FILTRATION, LAGUNA SPORTS COMPLEX, BRGY.BUBUKAL, SANTA CRUZ

CITY, LAGUNA

SAMPLE CHARACTERISTICS

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	АСР
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	10/01/2020	ACP

**REMARKS:** Samples were analyzed as submitted.

**NOTE:** <u>A</u> – Method is not part of DENR-ELR Recognized Parameters

**DEVIATIONS:** No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

**NOT VALID WITHOUT QR CODE** 

**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

JETHRO D. ESCORIN Microbiology Unit Manager ANNA KARLA S GUTTERREZ, RMT Laboratory Services Manager

License No(s). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

**CUSTOMER NAME**: Laguna AAAWater Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

### SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-6471 **DATE/TIME SUBMITTED** : 10/01/2020 16:20

**DATE/TIME COLLECTION** : 10/01/2020 08:15 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : CANTEEN #4 IN FRONT OF LAGUNA UNIVERSITY, BRGY. BUBUKAL, SANTA CRUZ CITY, LAGUNA

**SAMPLE** 

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate **CHARACTERISTICS** 

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	10/01/2020	ACP

**REMARKS:** Samples were analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

**DEVIATIONS:** No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

Microbiology Unit Manager

ANNA KARLA Laboratory Services Manager

License No(s). (PBC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

**CUSTOMER NAME**: Laguna AAAWater Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

### **SUMMARY OF LABORATORY ANALYSIS**

**SAMPLE CODE(S)** : **S20-6472 DATE/TIME SUBMITTED** : 10/01/2020 16:20

DATE/TIME COLLECTION : 10/01/2020 07:00 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL, SANTA

**CRUZ CITY, LAGUNA** 

SAMPLE CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	10/01/2020	ACP

**REMARKS:** Samples were analyzed as submitted.

**NOTE:** <u>A</u> – Method is not part of DENR-ELR Recognized Parameters

**DEVIATIONS:** No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

**NOT VALID WITHOUT QR CODE** 

**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

JETHRO D. ESCORN Microbiology Unit Manager ANNA KARLAS. GUTTERREY, RMT Laboratory Services Manager License No(s). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

**CUSTOMER NAME**: Laguna AAAWater Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

## **SUMMARY OF LABORATORY ANALYSIS**

SAMPLE CODE(S) : S20-6473

**DATE/TIME SUBMITTED** : 10/01/2020 16:20

**DATE/TIME COLLECTION** : 10/01/2020 07:10

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

**TOTAL PARAMETERS TESTED : 3** 

**SAMPLE LOCATION** 

: OLD CAPITOL BLDG., CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL,

SANTA CRUZ CITY, LAGUNA

SAMPLE

**CHARACTERISTICS** 

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	АСР
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	АСР
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	10/01/2020	ACP

REMARKS: Samples were analyzed as submitted.

**NOTE:** A – Method is not part of DENR-ELR Recognized Parameters

**DEVIATIONS:** No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

**NOT VALID WITHOUT QR CODE** 

**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

JETHRO D. ESCOBIN Microbiology Unit Manager ANNA KARLAS. GUTIERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

**CUSTOMER NAME**: Laguna AAAWater Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

### **SUMMARY OF LABORATORY ANALYSIS**

**SAMPLE CODE(S)** : **S20-6474 DATE/TIME SUBMITTED** : 10/01/2020 16:20

DATE/TIME COLLECTION : 10/01/2020 07:15 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : CISTERN TANK, LAGUNA MEDICAL CENTER, SANTA CRUZ CITY, LAGUNA

SAMPLE

CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	11	9215B. Pour Plate Method	10/01/2020	ACP

REMARKS: Samples were analyzed as submitted.

**NOTE:** <u>A</u> – Method is not part of DENR-ELR Recognized Parameters **DEVIATIONS:** No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

JETHRO D. ESCOBA Microbiology Unit Manager ANNA KARLAS. GUTHERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

**CUSTOMER NAME**: Laguna AAAWater Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

# **SUMMARY OF LABORATORY ANALYSIS**

SAMPLE CODE(S) : S20-6475 DATE/TIME SUBMITTED : 10/01/2020 16:20

DATE/TIME COLLECTION : 10/01/2020 07:25 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : KITCHEN, LAGUNA MEDICAL CENTER, SANTA CRUZ CITY, LAGUNA

SAMPLE

CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	10/01/2020	ACP
Heterotrophic Plate Count (HPC) <sup>A</sup>	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	10/01/2020	ACP

REMARKS: Samples were analyzed as submitted.

**NOTE:** <u>A</u> – Method is not part of DENR-ELR Recognized Parameters **DEVIATIONS:** No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

**NOT VALID WITHOUT QR CODE** 

**REVIEWED BY:** 

**CERTIFIED CORRECT BY:** 

JETHRO D. ESCOBIN Microbiology Unit Manager ANNA KARLA S. GUTIERREZ, RMT Laboratory Services Manager License No(s) (PRC 0060968)