

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 21

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 08/03/2023-08/23/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
08/23/2023 13:07	S23-4681	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN					
08/17/2023 11:34	S23-4613	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	(-)
08/17/2023 11:57	S23-4614	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	(-)
08/17/2023 11:44	S23-4617	Block 2 Lot 16, Phase 9 Southville	ABSENCE	ABSENCE	(-)
08/17/2023 11:22	S23-4615	Southville Integrated Highschool	ABSENCE	ABSENCE	(-)
BRGY. KANLURAN					
08/16/2023 10:42	S23-4610	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
08/16/2023 09:54	S23-4609	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
08/17/2023 10:10	S23-4616	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	(-)
BRGY. SINALHAN					
08/16/2023 09:31	S23-4607	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
08/16/2023 12:23	S23-4593	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	4
08/16/2023 12:36	S23-4595	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1
08/16/2023 12:47	S23-4603	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1
08/16/2023 12:58	S23-4604	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	27
08/16/2023 11:40	S23-4594	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
08/16/2023 12:06	S23-4596	Block 14 Lot 7 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1
08/16/2023 13:52	S23-4597	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	2
08/16/2023 14:04	S23-4598	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1
08/16/2023 13:18	S23-4599	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	< 1
08/16/2023 13:30	S23-4600	Sizzlers, Robinson's Mall	ABSENCE	ABSENCE	2
08/03/2023 12:30	S23-4212	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1
08/03/2023 12:43	S23-4213	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	5

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 41

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 08/08/2023-08/23/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
08/23/2023 13:07	S23-4681	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO					
08/16/2023 12:20	S23-4608	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
08/08/2023 12:00	S23-4390	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
08/08/2023 10:13	S23-4396	Water Pump, South Hampton Residences	ABSENCE	ABSENCE	< 1
08/22/2023 13:45	S23-4667	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
08/22/2023 13:35	S23-4668	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	< 1
08/03/2023 10:24	S23-4211	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
08/03/2023 11:01	S23-4201	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	4
08/03/2023 11:12	S23-4202	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	2
08/03/2023 11:28	S23-4203	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
08/03/2023 11:50	S23-4204	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	27
08/08/2023 11:41	S23-4391	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	< 1
08/03/2023 13:31	S23-4205	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	4
BRGY. DITA					
08/03/2023 09:59	S23-4206	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	5
08/03/2023 09:29	S23-4207	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	7
08/03/2023 09:38	S23-4208	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	13


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
08/03/2023 10:10	S23-4209	#1780, National Road	ABSENCE	ABSENCE	13
08/03/2023 13:10	S23-4214	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	85
08/17/2023 12:47	S23-4619	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
08/14/2023 12:50	S23-4462	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
08/14/2023 13:44	S23-4461	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
08/14/2023 13:37	S23-4465	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
08/14/2023 10:45	S23-4456	Clubhouse, Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	1
08/14/2023 11:07	S23-4457	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	1
08/14/2023 11:20	S23-4458	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
08/14/2023 11:25	S23-4459	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
08/14/2023 12:36	S23-4466	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	< 1
BRGY. MACABLING					
08/16/2023 10:45	S23-4605	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	29
08/16/2023 11:00	S23-4601	Water Pump, Corinthian Subdivision	ABSENCE	ABSENCE	24
08/16/2023 11:14	S23-4602	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
08/03/2023 13:16	S23-4210	Guardhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	< 1
08/08/2023 11:17	S23-4395	Block 11 Lot 16, Terra Fortuna	ABSENCE	ABSENCE	1
08/08/2023 10:48	S23-4393	Water Pump, 9999 W, Villa Las Casas	ABSENCE	ABSENCE	34
08/08/2023 11:00	S23-4494	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC					
08/16/2023 10:56	S23-4611	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	(-)
08/16/2023 11:09	S23-4612	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	(-)
BRGY. PULONG STA. CRUZ					
08/08/2023 13:00	S23-4141	Manzano Residence	ABSENCE	ABSENCE	< 1
08/08/2023 11:52	S23-4397	Water Pump	ABSENCE	ABSENCE	< 1
08/08/2023 10:31	S23-4389	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1
08/08/2023 10:26	S23-4488	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1
08/08/2023 10:00	S23-4387	Block 6 Lot 8, Buklod Diwa	ABSENCE	ABSENCE	< 1
BRGY. SANTO DOMINGO					
08/16/2023 15:06	S23-4606	Clubhouse Santa Rosa Estates II	ABSENCE	ABSENCE	9
08/14/2023 11:56	S23-4467	Water Pump	ABSENCE	ABSENCE	< 1
08/14/2023 12:13	S23-4468	Tope Residence	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.