

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 04/28/2025-04/30/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
04/29/2025 09:30	S25-2724	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN					
04/28/2025 14:53	S25-2709	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	33
04/28/2025 15:29	S25-2710	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	14
04/28/2025 15:17	S25-2711	Southville Integrated Highschool	ABSENCE	ABSENCE	3
BRGY. KANLURAN					
04/28/2025 14:19	S25-2706	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
04/28/2025 13:58	S25-2705	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
04/28/2025 14:05	S25-2712	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	250
BRGY. SINALHAN					
04/28/2025 13:42	S25-2703	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
04/28/2025 13:19	S25-2691	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1
04/28/2025 12:40	S25-2693	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1
04/28/2025 13:00	S25-2700	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1
04/28/2025 13:09	S25-2701	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	16
04/28/2025 12:29	S25-2692	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
04/28/2025 13:27	S25-2694	Block 1 Lot 64 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1
04/28/2025 11:46	S25-2695	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
04/28/2025 11:51	S25-2696	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1
04/28/2025 12:19	S25-2697	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	< 1
04/28/2025 12:26	S25-2698	Buko Haus, Robinson's Mall	ABSENCE	ABSENCE	1
04/28/2025 12:10	S25-2682	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	44
04/28/2025 12:22	S25-2683	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	9

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 40

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 04/11/2025-04/30/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATIOHN	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
04/29/2025 09:30	S25-2724	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO					
04/28/2025 16:29	S25-2704	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
04/29/2025 10:05	S25-2731	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	1
04/25/2025 10:15	S25-2631	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
04/25/2025 10:05	S25-2632	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	< 1
04/28/2025 12:43	S25-2681	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
04/28/2025 10:29	S25-2671	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	11
04/28/2025 10:45	S25-2672	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
04/28/2025 11:10	S25-2673	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
04/28/2025 11:19	S25-2674	Block 34 Lot 9, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
04/29/2025 11:23	S25-2732	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	4
04/28/2025 11:40	S25-2675	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
04/28/2025 09:25	S25-2676	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
04/28/2025 09:01	S25-2677	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1
04/28/2025 09:12	S25-2678	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	4

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:

 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
04/28/2025 09:46	S25-2679	#1780, National Road	ABSENCE	ABSENCE	< 1
04/28/2025 10:10	S25-2684	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	22
04/29/2025 11:14	S25-2733	Gate Entrance, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
04/11/2025 08:31	S25-2412	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	13
04/11/2025 09:40	S25-2411	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	24
04/11/2025 09:29	S25-2413	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
04/11/2025 11:55	S25-2406	Clubhouse, Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	< 1
04/11/2025 11:36	S25-2407	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	7
04/11/2025 10:24	S25-2408	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
04/11/2025 10:33	S25-2409	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	1
04/30/2025 16:03	S25-2789	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	< 1
BRGY. MACABLING					
04/28/2025 11:09	S25-2702	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1
04/28/2025 10:57	S25-2699	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	100
BRGY. MALITLIT					
04/28/2025 10:01	S25-2680	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	< 1
04/29/2025 11:01	S25-2736	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	< 1
04/29/2025 10:28	S25-2734	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	< 1
04/29/2025 10:42	S25-2735	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1
BRGY. POOC					
04/28/2025 16:05	S25-2707	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	14
04/28/2025 15:52	S25-2708	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	<26
BRGY. PULONG STA. CRUZ					
04/29/2025 12:03	S25-2728	Water Pump, Buklod Diwa	ABSENCE	ABSENCE	< 1
04/29/2025 12:07	S25-2729	Block 6 Lot 8, Buklod Diwa	ABSENCE	ABSENCE	2
04/29/2025 1:44	S25-2730	Drinking Fountain II, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

[Signature]
 SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:

[Signature]
 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SANTO DOMINGO					
04/11/2025 10:51	S25-2410	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	2
04/11/2025 11:08	S25-2417	Water Pump, Sto. Domingo	ABSENCE	ABSENCE	15
04/11/2025 11:16	S25-2418	Labrador Residence	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: A– Enzyme Substrate; B– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.