

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS


NO. OF SAMPLES : 20


TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 02/17/2025-02/26/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
02/26/2025 15:52	S25-1284	Laguna Wellfield 1	ABSENCE	ABSENCE	11
BRGY. CAINGIN					
02/20/2025 14:04	S25-1128	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
02/20/2025 14:32	S25-1129	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
02/20/2025 14:16	S25-1130	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
02/20/2025 13:12	S25-1125	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
02/20/2025 12:32	S25-1124	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
02/20/2025 12:58	S25-1131	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
02/20/2025 11:54	S25-1122	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	65

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 NOWEL ELLISON G. RAMOS, RMT
 Microbiology Unit Manager
 License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
02/17/2025 14:16	S25-0958	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1
02/17/2025 13:36	S25-960	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1
02/17/2025 13:58	S25-0967	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1
02/17/2025 14:05	S25-0968	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	< 1
02/17/2025 15:18	S25-0959	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
02/17/2025 15:36	S25-0961	Block 1 Lot 67 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1
02/17/2025 14:52	S25-0962	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
02/17/2025 15:04	S25-0963	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1
02/17/2025 14:28	S25-0964	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	< 1
02/17/2025 14:36	S25-0965	Buko Haus, Robinson's Mall	ABSENCE	ABSENCE	< 1
02/18/2025 08:15	S25-1021	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	3
02/18/2025 08:28	S25-1022	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B**- Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS


NO. OF SAMPLES : 35

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 02/18/2025-02/26/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATIONH	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
02/26/2025 15:52	S25-1284	Laguna Wellfield 1	ABSENCE	ABSENCE	11
BRGY. BALIBAGO					
02/20/2025 14:56	S25-1123	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
02/18/2025 14:17	S25-1027	Water Pump, South Hampton Residences	ABSENCE	ABSENCE	3
02/18/202514:24	S25-1028	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	4
02/24/2025 14:31	S25-1196	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
02/24/2025 14:22	S25-1197	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	< 1
02/18/2025 12:47	S25-1020	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	8
BRGY. DILA					
02/18/2025 11:49	S25-1010	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
02/18/2025 12:03	S25-1011	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
02/18/2025 11:01	S25-1012	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	4
02/18/2025 11:13	S25-1013	Block 34 Lot 9, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	18
02/18/2025 14:02	S25-1029	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	4
02/18/2025 12:29	S25-1014	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
02/18/2025 10:19	S25-1015	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
02/18/2025 10:02	S25-1016	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	5
02/18/2025 10:22	S25-1017	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 NOWEL ELLISON G. RAMOS, RMT
 Microbiology Unit Manager
 License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

 ANNA KARLA G. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.


ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
02/18/2025 10:44	S25-1018	#1780, National Road	ABSENCE	ABSENCE	< 1
02/18/2025 09:50	S25-1023	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	160
02/18/2025 13:54	S25-1030	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
02/19/2025 09:11	S25-0420	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
02/26/2025 13:56	S25-1275	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
02/19/2025 10:11	S25-1086	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
02/19/2025 12:40	S25-1077	Clubhouse, Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	< 1
02/19/2025 12:30	S25-1078	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	< 1
02/19/2025 12:09	S25-1079	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
02/19/2025 12:16	S25-1080	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
02/19/2025 10:38	S25-1087	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	< 1
BRGY. MACABLING					
02/17/2025 16:00	S25-0969	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1
02/17/2025 15:51	S25-0966	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
02/26/2025 09:35	S25-1274	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	1
02/18/2025 13:37	S25-1033	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	< 1
02/18/2025 13:14	S25-1031	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	7
02/18/2025 13:25	S25-1032	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	2

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 NOWEL ELLISON G. RAMOS, RMT
 Microbiology Unit Manager
 License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:

 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC					
02/20/2025 13:36	S25-1126	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	< 1
02/20/2025 13:48	S25-1127	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	66
BRGY. PULONG STA. CRUZ					
02/18/2025 14:52	S25-1024	Water Pump	ABSENCE	ABSENCE	1
02/18/2025 15:01	S25-1025	Manzano, Buklod Diwa	ABSENCE	ABSENCE	1
02/18/2025 14:37	S25-1026	Drinking Fountain II, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	6
BRGY. SANTO DOMINGO					
02/19/2025 11:45	S25-1081	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	< 1
02/19/2025 11:06	S25-1088	Water Pump	ABSENCE	ABSENCE	22
02/19/2025 11:20	S25-1089	Masungsong Residence	ABSENCE	ABSENCE	110

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**– Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


 NOWEL ELLISON G. RAMOS, RMT
 Microbiology Unit Manager
 License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.