

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 03/06/2025-03/25/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
03/06/2025 12:43	S25-1476	Laguna Wellfield 1	ABSENCE	ABSENCE	40
BRGY. CAINGIN					
03/25/2025 11:37	S25-1952	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
03/25/2025 12:04	S25-1953	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
03/25/2025 11:49	S25-1954	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
03/25/2025 11:19	S25-1949	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
03/25/2025 11:01	S25-1948	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
03/25/2025 10:43	S25-1955	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
03/25/2025 09:58	S25-1946	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
03/13/2025 12:24	S25-1753	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	2
03/13/2025 14:46	S25-1755	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1
03/13/2025 12:14	S25-1762	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1
03/13/2025 12:10	S25-1763	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	< 1
03/13/2025 09:34	S25-1754	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
03/13/2025 09:56	S25-1756	Block 1 Lot 64 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1
03/13/2025 10:42	S25-1757	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
03/13/2025 10:55	S25-1758	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1
03/13/2025 11:20	S25-1759	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	< 1
03/13/2025 11:27	S25-1760	Buko Haus, Robinson's Mall	ABSENCE	ABSENCE	< 1
03/24/2025 09:28	S25-1941	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	110
03/24/2025 09:41	S25-1942	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:

 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 40

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 03/06/2025-03/28/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATIOHN	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
03/06/2025 12:43	S25-1476	Laguna Wellfield 1	ABSENCE	ABSENCE	40
BRGY. BALIBAGO					
03/25/2025 12:51	S25-1947	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
03/11/2025 11:12	S25-1626	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	26
03/24/2025 14:38	S25-1944	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
03/24/2025 14:22	S25-1945	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	< 1
03/24/2025 14:08	S25-1940	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	31
BRGY. DILA					
03/24/2025 12:03	S25-1930	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	76
03/24/2025 12:15	S25-1931	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	48
03/24/2025 11:28	S25-1932	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
03/24/2025 11:42	S25-1933	Block 34 Lot 9, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
03/11/2025 10:57	S25-1627	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	8
03/24/2025 12:26	S25-1933	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
03/24/2025 11:01	S25-1935	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
03/24/2025 10:29	S25-1936	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1
03/24/2025 10:47	S25-1937	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

Sheena Mae B. Andres
 SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:

Anna Karla S. Gutierrez
 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
03/24/2025 11:14	S25-1937	#1780, National Road	ABSENCE	ABSENCE	< 1
03/24/2025 10:16	S25-1943	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	160
03/11/2025 10:29	S25-1628	Gate Entrance, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
03/25/2025 14:32	S25-1957	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
03/25/2025 14:20	S25-1956	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	1
03/25/2025 14:11	S25-1960	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
03/26/2025 11:37	S25-2002	Clubhouse, Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	10
03/26/2025 11:23	S25-2003	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	< 1
03/28/2025 10:20	S25-2042	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	17
03/28/2025 10:29	S25-2043	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	16
03/26/2025 09:24	S25-2007	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	14
BRGY. MACABLING					
03/13/2025 13:21	S25-1764	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1
03/13/2025 13:13	S25-1761	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
03/24/2025 10:02	S25-1939	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	1
03/11/2025 10:34	S25-1631	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	< 1
03/11/2025 09:31	S25-1629	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	< 1
03/11/2025 09:54	S25-1630	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1
BRGY. POOC					
03/25/2025 12:20	S25-1950	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	< 1
03/25/2025 12:31	S25-1951	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ					
03/11/2025 11:43	S25-1623	Water Pump, Buklod Diwa	ABSENCE	ABSENCE	< 1
03/11/2025 11:55	S25-1624	Manzano, Buklod Diwa	ABSENCE	ABSENCE	< 1
03/11/2025 11:27	S25-1625	Drinking Fountain II, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

SHEENA MAE B. ANDRES
 Laboratory Analyst

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ
 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SANTO DOMINGO					
03/28/2025 10:48	S25-2044	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	28
03/26/2025 10:46	S25-2008	Water Pump, Sto. Domingo	ABSENCE	ABSENCE	120
03/26/2025 11:02	S25-2009	Labrador Residence	ABSENCE	ABSENCE	22

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-1470

DATE/TIME SUBMITTED : 03/06/2025 13:30

DATE/TIME COLLECTION : 03/06/2025 11:23

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.61	4500-Cl-G.DPD Colorimetric	03/06/2025	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/06/2025	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	03/06/2025	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	03/06/2025	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*. Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

SHEENA MAE B. ANDRES
Laboratory Analyst

CERTIFIED CORRECT BY:

KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)