

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 23

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 06/02/2021 – 06/25/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C) MDL: NA LOQ: NA	RESIDUAL CHLORINE ^B (mg/L) MDL: 0.06 LOQ: 0.20	COLIFORM ^C		HPC ^D (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)			
BRGY. BIÑAN							
06/03/2021 11:12	S21-4104	Laguna Wellfield 1	-	0.48	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN							
06/09/2021 13:56	S21-4326	Water Pump, Block 57, Phase 1, Southville	-	1.33	ABSENCE	ABSENCE	3
06/09/2021 14:34	S21-4327	Block 25 Lot 7, Phase 3, Southville	-	0.29	ABSENCE	ABSENCE	< 1
06/09/2021 14:14	S21-4328	Block 2 Lot 16, Phase 8, Southville	-	0.51	ABSENCE	ABSENCE	5
06/09/2021 07:28	S21-4237	Southville Integrated Highschool	7.56 / 27.1	0.36	ABSENCE	ABSENCE	20
BRGY. KANLURAN							
06/09/2021 08:15	S21-4232	Block 18 Lot 2, Alfonso Homes I	7.55 / 29.7	0.25	ABSENCE	ABSENCE	< 1
06/09/2021 07:21	S21-4230	#621 Rizal Boulevard	7.61 / 28.6	0.30	ABSENCE	ABSENCE	1
BRGY. MALUSAK							
06/09/2021 07:42	S21-4231	Santa Rosa City Hall	7.41 / 29.5	0.28	ABSENCE	ABSENCE	4
06/09/2021 07:10	S21-4233	Drinking Fountain I, Central I Elementary School	7.52 / 29.5	0.35	ABSENCE	ABSENCE	2
BRGY. SINALHAN							
06/09/2021 06:10	S21-4234	Block 8 Lot 16, Bayshore III	7.68 / 27.5	0.28	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. TAGAPO							
06/22/2021 11:53	S21-4537	#60 31 JP Rizal Boulevard	-	0.31	ABSENCE	ABSENCE	110
06/22/2021 12:20	S21-4539	Block 1 Lot 18, Fairfield of Margana Subdivision	-	0.42	ABSENCE	ABSENCE	< 1
06/22/2021 12:07	S21-4547	Water Pump, Rosewood Homes I	-	0.46	ABSENCE	ABSENCE	< 1
06/22/2021 12:01	S21-4548	Block 3 Lot 31, Rosewood Homes I	-	0.22	ABSENCE	ABSENCE	1
06/22/2021 12:38	S21-4549	Block 4 Lot 1, Rosewood Homes II	-	0.40	ABSENCE	ABSENCE	< 1
06/24/2021 11:22	S21-4626	Pump House Faucet, Buena Rosa 1 Subdivision	-	0.73	ABSENCE	ABSENCE	60
06/22/2021 11:44	S21-4540	Block 1 Lot 64, Buena Rosa 10 Subdivision	-	0.10	ABSENCE	ABSENCE	< 1
06/22/2021 13:50	S21-4541	Cistern Tank, SM Santa Rosa	-	0.49	ABSENCE	ABSENCE	< 1
06/22/2021 13:55	S21-4542	Admin Pantry, SM Santa Rosa	-	0.74	ABSENCE	ABSENCE	< 1
06/23/2021 13:40	S21-4605	Cistern Tank, Robinson's Mall	7.66 / 27.6	0.15	ABSENCE	ABSENCE	20
06/24/2021 13:26	S21-4627	Paotsin, Robinson's Mall	-	0.16	ABSENCE	ABSENCE	6
06/02/2021 14:50	S21-4070	Water Pump, Metrogate Heritage Subd.	7.56 / 27.1	0.61	ABSENCE	ABSENCE	< 1
06/02/2021 14:59	S21-4071	Clubhouse, Metrogate Heritage Subd.	7.59 / 28.0	0.40	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 46

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 06/01/2021 – 06/25/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
06/03/2021 11:12	S21-4104	Laguna Wellfield 1	-	0.48	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO							
06/22/2021 14:39	S21-4536	#1354 Facundo Compound	-	0.33	ABSENCE	ABSENCE	< 1
06/23/2021 12:01	S21-4593	Clubhouse, South Hampton Residences	7.68 / 27.3	0.36	ABSENCE	ABSENCE	< 1
06/02/2021 14:48	S21-4069	Block 5 Lot 25, JB Village	7.50 / 28.2	0.34	ABSENCE	ABSENCE	< 1
06/22/2021 14:59	S21-4575	Cistern Tank, Waltermart Santa Rosa	7.66 / 29.7	0.12	ABSENCE	ABSENCE	< 1
06/22/2021 15:16	S21-4576	2 nd Floor faucet, Waltermart, Santa Rosa	7.61 / 29.8	0.10	ABSENCE	ABSENCE	< 1
BRGY. DILA							
06/02/2021 13:16	S21-4057	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.60 / 27.5	0.39	ABSENCE	ABSENCE	1
06/02/2021 13:30	S21-4058	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.55 / 28.6	0.29	ABSENCE	ABSENCE	< 1
06/02/2021 13:50	S21-4059	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	7.54 / 27.1	0.34	ABSENCE	ABSENCE	< 1
06/02/2021 14:10	S21-4060	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	7.49 / 27.0	0.28	ABSENCE	ABSENCE	< 1
06/23/2021 09:40	S21-4603	Clubhouse, Alabaster St., Villa Esmeralda	7.68 / 27.2	0.48	ABSENCE	ABSENCE	< 1
06/02/2021 14:25	S21-4061	Drinking Fountain, Dila Elementary	7.50 / 27.3	0.26	ABSENCE	ABSENCE	< 1
BRGY. DITA							
06/02/2021 14:23	S21-4062	Block 24 Lot 2, New Santa Rosa Homes	7.55 / 28.5	0.26	ABSENCE	ABSENCE	< 1
06/02/2021 14:30	S21-4063	Block 19 Lot 11, New Santa Rosa Homes	7.52 / 27.5	0.21	ABSENCE	ABSENCE	< 1
06/02/2021 11:20	S21-4064	Water Tank, SolCar Ville Subdivision	7.47 / 27.4	0.67	ABSENCE	ABSENCE	< 1
06/02/2021 11:38	S21-4065	Block 3 Lot 7, SolCar Ville Subdivision	7.40 / 27.5	0.56	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
06/02/2021 11:59	S21-4066	#1780, National Road	7.43 / 28.1	0.48	ABSENCE	ABSENCE	< 1
06/02/2021 15:16	S21-4072	R & B Ice Plant, Inc.	7.55 / 28.1	0.55	ABSENCE	ABSENCE	< 1
06/23/2021 10:26	S21-4594	Clubhouse, San Lorenzo Royale	7.65 / 28.3	0.40	ABSENCE	ABSENCE	1
BRGY. DON JOSE							
06/01/2021 11:28	S21-3976	Science High School, Phase 1, Laguna Bel-Air	7.18 / 25.0	0.15	ABSENCE	ABSENCE	< 1
06/01/2021 11:00	S21-3978	Church, Block 108, Phase 5, Laguna Bel-Air	7.14 / 25.0	0.02	ABSENCE	ABSENCE	2
06/01/2021 11:42	S21-3977	Clubhouse, Phase 1, Laguna Bel-Air	7.30 / 25.0	0.12	ABSENCE	ABSENCE	< 1
06/01/2021 11:14	S21-3978	Block 47 Lot 12, Phase 4, Laguna Bel-Air	7.15 / 25.0	0.09	ABSENCE	ABSENCE	< 1
06/01/2021 10:06	S21-3935	8001, Pump 1, Acacia St., Santa Rosa Village I	7.55 / 29.7	0.37	ABSENCE	ABSENCE	< 1
06/01/2021 10:15	S21-3936	Clubhouse, Phase 4B, Santa Rosa Village I	7.47 / 30.1	0.30	ABSENCE	ABSENCE	< 1
06/01/2021 10:41	S21-3937	Clubhouse, Santa Rosa Village II	7.61 / 30.6	0.25	ABSENCE	ABSENCE	10
06/01/2021 10:59	S21-3938	Pump 9 & 10, Santa Rosa Estates I	7.45 / 30.6	0.20	ABSENCE	ABSENCE	1
06/01/2021 11:24	S21-3939	Clubhouse, Santa Rosa Estates I	7.45 / 30.6	0.28	ABSENCE	ABSENCE	< 1
06/01/2021 10:34	S21-3980	Drinking Fountain, Don Jose National High School	7.15 / 25.0	0.69	ABSENCE	ABSENCE	< 1
BRGY. MACABLING							
06/22/2021 11:05	S21-4550	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	-	0.82	ABSENCE	ABSENCE	< 1
06/22/2021 10:47	S21-4545	Water Pump, Corinthian Subdivision	-	1.46	ABSENCE	ABSENCE	< 1
06/22/2021 10:55	S21-4546	Block 11 Lot 19, Corinthian Subdivision	-	0.93	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT							
06/02/2021 14:38	S21-4067	Clubhouse, Casan Residencia Subdivision	7.44 / 27.2	0.14	ABSENCE	ABSENCE	< 1
06/23/2021 10:18	S21-4595	Water Pump, Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subdivision	7.68 / 27.5	0.28	ABSENCE	ABSENCE	< 1
06/23/2021 10:41	S21-4596	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subdivision	7.59 / 28.1	0.24	ABSENCE	ABSENCE	< 1
06/23/2021 11:41	S21-4599	Water Pump, Main Road, Phase 2, Terra Fortuna	7.48 / 27.3	0.10	ABSENCE	ABSENCE	< 1
06/23/2021 12:18	S21-4600	Block 11 Lot 16, Terra Fortuna	7.68 / 28.5	0.18	ABSENCE	ABSENCE	< 1
06/23/2021 11:16	S21-4597	Water Pump, 9999 W, Villa Las Casas	7.61 / 28.1	0.38	ABSENCE	ABSENCE	< 1
06/23/2021 11:28	S21-4598	Guard House, Villa Las Casas	7.59 / 27.1	0.31	ABSENCE	ABSENCE	< 1
06/02/2021 11:10	S21-4068	Drinking Fountain, Malitlit Elementary	7.48 / 26.1	0.21	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC							
06/09/2021 06:25	S21-4235	Water Pump, Villa Mercedes	7.65 / 28.1	0.31	ABSENCE	ABSENCE	< 1
06/09/2021 06:41	S21-4236	Block 2 Lot 1, Villa Mercedes	7.60 / 28.2	0.26	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ							
06/23/2021 12:18	S21-4592	Block 6 Lot 8, Buklod Diwa	7.45 / 27.5	0.22	ABSENCE	ABSENCE	< 1
06/23/2021 12:50	S21-4601	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	7.60 / 28.2	0.31	ABSENCE	ABSENCE	< 1
06/23/2021 13:21	S21-4602	Drinking Fountain II, Pulong Sta. Cruz Elementary School	7.65 / 28.1	0.36	ABSENCE	ABSENCE	< 1
BRGY. SANTO DOMINGO							
06/01/2021 11:10	S21-3940	Clubhouse Santa Rosa Estates II	7.61 / 30.7	0.30	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.