

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 22

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 05/03/2021 – 05/21/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20	TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN							
05/03/2021 16:00	S21-3223	Laguna Wellfield 1	7.51 / 27.8	0.67	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN							
05/19/2021 12:25	S21-3783	Water Pump, Block 57, Phase 1, Southville	-	1.28	ABSENCE	ABSENCE	< 1
05/19/2021 12:44	S21-3784	Block 25 Lot 7, Phase 3, Southville	-	1.08	ABSENCE	ABSENCE	< 1
05/19/2021 12:32	S21-3785	Block 52 Lot 27, Southville	-	1.33	ABSENCE	ABSENCE	< 1
05/19/2021 12:01	S21-3786	Block 2 Lot 16, Phase 9, Southville	-	0.20	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN							
05/19/2021 13:15	S21-3780	Gate Entrance, Alfonso Homes I	-	0.43	ABSENCE	ABSENCE	< 1
05/19/2021 13:23	S21-3778	#621 Rizal Boulevard	-	0.40	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK							
05/19/2021 13:32	S21-3779	Santa Rosa City Hall	-	0.23	ABSENCE	ABSENCE	30
BRGY. SINALHAN							
05/19/2021 13:49	S21-3777	Block 8 Lot 16, Bayshore III	-	0.16	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO							
05/18/2021 12:37	S21-3756	#60 31 JP Rizal Boulevard	-	1.04	ABSENCE	ABSENCE	< 1
05/18/2021 13:16	S21-3758	Block 1 Lot 18, Fairfield of Margana Subdivision	-	1.10	ABSENCE	ABSENCE	< 1
05/18/2021 12:51	S21-3766	Water Pump, Rosewood Homes I	-	1.37	ABSENCE	ABSENCE	< 1
05/18/2021 12:58	S21-3767	Block 3 Lot 31, Rosewood Homes I	-	1.21	ABSENCE	ABSENCE	< 1
05/18/2021 13:29	S21-3768	Block 2 Lot 8, Rosewood Homes II	-	1.32	ABSENCE	ABSENCE	< 1
05/18/2021 12:00	S21-3757	Eye wash, Buena Rosa 1 Subdivision	-	0.15	ABSENCE	ABSENCE	< 1
05/18/2021 12:23	S21-3759	Block 1 Lot 64, Buena Rosa 10 Subdivision	-	0.11	ABSENCE	ABSENCE	< 1
05/18/2021 14:49	S21-3760	Cistern Tank, SM Santa Rosa	-	0.26	ABSENCE	ABSENCE	< 1
05/18/2021 14:56	S21-3761	Admin Pantry, SM Santa Rosa	-	0.21	ABSENCE	ABSENCE	< 1
05/19/2021 14:21	S21-3788	Cistern Tank, Robinson's Mall	-	0.12	ABSENCE	ABSENCE	< 1
05/18/2021 14:18	S21-3763	Ilonggo, Robinson's Mall	-	< 0.02	ABSENCE	ABSENCE	< 1
05/06/2021 14:29	S21-3377	Water Pump, Metrogate Heritage Subd.	7.60 / 27.0	0.40	ABSENCE	ABSENCE	< 1
05/06/2021 15:00	S21-3378	Clubhouse, Metrogate Heritage Subd.	7.45 / 26.1	0.36	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: A – Electrometric; B – Colorimetric; C – Enzyme Substrate; D – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 47

TOTAL PARAMETERS TESTED : 5


ANALYSIS DATE(S) : 05/03/2021 – 05/27/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. BIÑAN							
05/03/2021 16:00	S21-3223	Laguna Wellfield 1	7.51 / 27.8	0.67	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO							
05/18/2021 13:54	S21-3755	#1354 Facundo Compound	-	0.40	ABSENCE	ABSENCE	< 1
05/17/2021 10:59	S21-3699	Clubhouse, South Hampton Residences	7.60 / 30.7	0.25	ABSENCE	ABSENCE	< 1
05/06/2021 14:10	S21-3376	Block 5 Lot 25, JB Village	7.61 / 27.0	0.35	ABSENCE	ABSENCE	-
05/25/2021 10:40	S21-3902	Cistern Tank, Waltermart Santa Rosa	7.47 / 30.7	0.16	ABSENCE	ABSENCE	40
05/25/2021 11:14	S21-3903	2 nd Floor faucet, Waltermart, Santa Rosa	7.55 / 30.3	0.10	ABSENCE	ABSENCE	63
BRGY. DILA							
05/06/2021 10:10	S21-3364	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.55 / 27.2	0.21	ABSENCE	ABSENCE	-
05/06/2021 10:18	S21-3365	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	7.60 / 27.3	0.14	ABSENCE	ABSENCE	-
05/06/2021 10:28	S21-3366	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	7.41 / 27.1	0.19	ABSENCE	ABSENCE	-
05/06/2021 10:40	S21-3367	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	7.40 / 27.1	0.18	ABSENCE	ABSENCE	-
05/17/2021 11:33	S21-3709	Clubhouse, Alabaster St., Villa Esmeralda	7.48 / 29.8	0.10	ABSENCE	ABSENCE	< 1
05/06/2021 11:00	S21-3368	Drinking Fountain, Dila Elementary	7.48 / 27.4	0.18	ABSENCE	ABSENCE	-
BRGY. DITA							
05/06/2021 11:20	S21-3369	Block 24 Lot 2, New Santa Rosa Homes	7.60 / 27.6	0.22	ABSENCE	ABSENCE	-
05/06/2021 11:38	S21-3370	Block 19 Lot 11, New Santa Rosa Homes	7.51 / 27.1	0.20	ABSENCE	ABSENCE	-
05/06/2021 11:49	S21-3371	Water Tank, SolCar Ville Subdivision	7.50 / 28.0	0.60	ABSENCE	ABSENCE	-
05/06/2021 12:00	S21-3372	Block 3 Lot 7, SolCar Ville Subdivision	7.48 / 27.1	0.48	ABSENCE	ABSENCE	-


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
05/06/2021 10:15	S21-3373	#1780, National Road	7.45 / 26.1	0.36	ABSENCE	ABSENCE	-
05/06/2021 15:35	S21-3379	R & B Ice Plant, Inc.	7.67 / 27.8	0.38	ABSENCE	ABSENCE	-
05/17/2021 11:16	S21-3700	Clubhouse, San Lorenzo Royale	7.51 / 30.7	0.12	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE							
05/20/2021 10:40	S21-3877	Science High School, Phase 1, Laguna Bel-Air	7.60 / 30.7	0.20	ABSENCE	ABSENCE	-
05/20/2021 10:20	S21-3879	Church, Block 108, Phase 5, Laguna Bel-Air	7.61 / 30.7	0.30	ABSENCE	ABSENCE	-
05/20/2021 10:59	S21-3878	Block 34 Lot 59, Phase 1, Laguna Bel-Air	7.55 / 30.7	0.24	ABSENCE	ABSENCE	-
05/20/2021 14:10	S21-3883	Block 47 Lot 12, Phase 4, Laguna Bel-Air	7.61 / 30.7	0.40	ABSENCE	ABSENCE	-
05/20/2021 08:20	S21-3871	8001, Pump 1, Acacia St., Santa Rosa Village I	7.61 / 30.7	0.35	ABSENCE	ABSENCE	-
05/20/2021 08:47	S21-3872	Clubhouse, Phase 4B, Santa Rosa Village I	7.55 / 30.3	0.27	ABSENCE	ABSENCE	-
05/20/2021 09:16	S21-3873	Clubhouse, Santa Rosa Village II	7.60 / 30.5	0.32	ABSENCE	ABSENCE	-
05/20/2021 09:33	S21-3874	Pump 9 & 10, Santa Rosa Estates I	7.45 / 30.7	0.40	ABSENCE	ABSENCE	-
05/20/2021 09:37	S21-3875	Clubhouse, Santa Rosa Estates I	7.60 / 30.6	0.37	ABSENCE	ABSENCE	-
05/20/2021 14:27	S21-3884	Drinking Fountain, Don Jose National High School	7.60 / 30.7	0.35	ABSENCE	ABSENCE	-
BRGY. MACABLING							
05/18/2021 11:41	S21-3769	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	-	0.40	ABSENCE	ABSENCE	< 1
05/18/2021 11:17	S21-3764	Water Pump, Corinthian Subdivision	-	0.75	ABSENCE	ABSENCE	< 1
05/18/2021 11:26	S21-3765	Block 11 Lot 19, Corinthian Subdivision	-	0.31	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT							
05/06/2021 13:20	S21-3374	Clubhouse, Casan Residencia Subdivision	7.51 / 28.1	0.30	ABSENCE	ABSENCE	-
05/17/2021 12:34	S21-3701	Water Pump, Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subdivision	7.44 / 29.8	0.24	ABSENCE	ABSENCE	< 1
05/17/2021 12:50	S21-3702	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subdivision	7.63 / 30.7	0.20	ABSENCE	ABSENCE	< 1
05/17/2021 13:14	S21-3705	Water Pump, Main Road, Phase 2, Terra Fortuna	7.44 / 30.7	0.08	ABSENCE	ABSENCE	< 1
05/17/2021 13:47	S21-3706	Block 11 Lot 16, Terra Fortuna	7.55 / 30.7	0.05	ABSENCE	ABSENCE	< 1
05/17/2021 12:14	S21-3703	Water Pump, 9999 W, Villa Las Casas	7.41 / 30.2	0.15	ABSENCE	ABSENCE	< 1
05/17/2021 11:58	S21-3704	Block 1 Lot 17, Villa Las Casas	7.44 / 29.7	0.12	ABSENCE	ABSENCE	< 1
05/06/2021 13:38	S21-3375	Drinking Fountain, Malitlit Elementary	7.68 / 26.1	0.27	ABSENCE	ABSENCE	-

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

Anna Karla S. Gutierrez
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20	TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC							
05/19/2021 12:56	S21-3781	Water Pump, Villa Mercedes	-	0.34	ABSENCE	ABSENCE	< 1
05/19/2021 13:04	S21-3782	Block 2 Lot 1, Villa Mercedes	-	0.28	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ							
05/19/2021 15:12	S21-3787	Pump Station	-	0.67	ABSENCE	ABSENCE	< 1
05/17/2021 10:30	S21-3698	Block 6 Lot 8, Buklod Diwa	7.61 / 29.7	0.13	ABSENCE	ABSENCE	< 1
05/17/2021 14:45	S21-3707	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	7.47 / 31.6	0.25	ABSENCE	ABSENCE	< 1
05/17/2021 14:27	S21-3708	Drinking Fountain II, Pulong Sta. Cruz Elementary School	7.55 / 29.7	0.24	ABSENCE	ABSENCE	< 1
BRGY. SANTO DOMINGO							
05/20/2021 10:15	S21-3876	Clubhouse Santa Rosa Estates II	7.55 / 30.7	0.25	ABSENCE	ABSENCE	-

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: A – Electrometric; B – Colorimetric; C – Enzyme Substrate; D – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.