

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 07/15/2025-07/30/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
07/29/2025 13:13	S25-4980	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN					
07/30/2025 14:52	S25-5049	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
07/30/2025 15:06	S25-5050	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
07/30/2025 14:43	S25-5051	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
07/30/2025 13:37	S25-5046	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
07/30/2025 12:56	S25-5045	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
07/30/2025 13:18	S25-5052	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
07/30/2025 12:43	S25-5043	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Agenojar
MARVIN JASPER G. AGENOJAR
Microbiology Unit Manager

CERTIFIED CORRECT BY:

Anna Karla S. Gutierrez
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
07/15/2025 13:02	S25-4673	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	2
07/15/2025 12:28	S25-4675	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	3
07/15/2025 12:43	S25-4682	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1
07/15/2025 12:51	S25-4683	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	< 1
07/15/2025 14:38	S25-4674	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
07/15/2025 14:24	S25-4676	Block 14 Lot 7, Buena Rosa 10	ABSENCE	ABSENCE	< 1
07/15/2025 13:48	S25-4677	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
07/15/2025 13:56	S25-4678	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1
07/15/2025 13:18	S25-4880	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	< 1
07/15/2025 13:26	S25-4881	Boko Haus, Robinson's Mall	ABSENCE	ABSENCE	16
07/28/2025 13:01	S25-4902	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	1
07/30/2025 10:40	S25-5019	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

CERTIFIED CORRECT BY:

Anna Karla S. Gutierrez
ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS


NO. OF SAMPLES : 40

TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 07/15/2025-07/30/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATIOHN	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
07/29/2025 13:13	S25-4980	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO					
07/30/2025 15:32	S25-5044	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
07/25/2025 12:17	S25-4877	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
07/25/2025 13:46	S25-4878	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
07/25/2025 13:55	S25-4879	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	< 1
07/28/2025 11:18	S25-4901	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	2
BRGY. DILA					
07/28/2025 12:50	S25-4891	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	36
07/28/2025 13:01	S25-4892	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	5
07/28/2025 12:19	S25-4893	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	1
07/28/2025 12:28	S25-4894	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
07/25/2025 12:00	S25-4876	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	1
07/28/2025 11:48	S25-4895	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	3
BRGY. DITA					
07/28/2025 10:29	S25-4896	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
07/28/2025 09:50	S25-4897	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	69
07/28/2025 09:59	S25-4898	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	61

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

CERTIFIED CORRECT BY:

 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
07/28/2025 10:18	S25-4899	#1780, National Road	ABSENCE	ABSENCE	< 1
07/28/2025 10:41	S25-4904	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	< 1
07/25/2025 11:46	S25-4875	Gate Entrance, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
07/23/2025 14:12	S25-4806	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	49
07/21/2025 12:13	S25-4777	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	2
07/21/2025 12:02	S25-4781	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
07/21/2025 14:14	S25-4772	Clubhouse, Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	--
07/21/2025 14:04	S25-4773	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	46
07/21/2025 12:54	S25-4774	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	5
07/21/2025 13:04	S25-4775	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
07/21/2025 14:34	S25-4782	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	210
BRGY. MACABLING					
07/15/2025 15:00	S25-4684	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1
07/15/2025 14:48	S25-4681	Clubhouse, Corinthian Subdivision	ABSENCE	ABSENCE	32
BRGY. MALITLIT					
07/28/2025 11:28	S25-4900	Clubhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	2
07/25/2025 11:34	S25-4874	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	< 1
07/25/2025 11:18	S25-4873	Water Pump, 9999, Villa Las Casas	ABSENCE	ABSENCE	< 1
07/23/2025 11:46	S25-4797	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	1
BRGY. POOC					
07/30/2025 14:12	S25-5047	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	40
07/30/2025 14:24	S25-5048	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	12
BRGY. PULONG STA. CRUZ					
07/23/2025 13:47	S25-4804	Water Pump, Buklod Diwa	ABSENCE	ABSENCE	< 1
07/25/2025 14:14	S25-4882	Manzano Residence, Buklod Diwa	ABSENCE	ABSENCE	86
07/25/2025 10:51	S25-4872	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


 MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

CERTIFIED CORRECT BY:


 ANNA KARLA S. GUTIERREZ, RMT
 Laboratory Services Manager
 License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SANTO DOMINGO					
07/21/2025 13:18	S25-4776	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	< 1
07/21/2025 13:30	S25-4783	Water Pump, Brgy. Sto. Domingo	ABSENCE	ABSENCE	8
07/21/2025 13:37	S25-4784	Labrador Residence	ABSENCE	ABSENCE	13

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: A- Enzyme Substrate; B – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-4974

DATE/TIME SUBMITTED : 07/29/2025 13:59

DATE/TIME COLLECTION : 07/29/2025 11:30

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	1.35	4500-Cl-G.DPD Colorimetric	07/29/2025	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/29/2025	KSG
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/29/2025	KSG
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	07/29/2025	KSG

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*. Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE




REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

CERTIFIED CORRECT BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)