

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 20

TOTAL PARAMETERS TESTED: 3


ANALYSIS DATE(S) : 11/13/2025-11/26/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
11/26/2025 11:17	S25-7658	Laguna Wellfield 1	ABSENCE	ABSENCE	3
BRGY. CAINGIN					
11/18/2025 14:09	S25-7475	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
11/18/2025 14:29	S25-7476	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	4
11/18/2025 14:17	S25-7477	Southville Integrated Highschool	ABSENCE	ABSENCE	36
BRGY. KANLURAN					
11/18/2025 12:25	S25-7472	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
11/18/2025 11:57	S25-7471	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
11/18/2025 12:07	S25-7478	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	2
BRGY. SINALHAN					
11/18/2025 11:14	S25-7469	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
11/13/2025 10:49	S25-7352	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1
11/13/2025 11:09	S25-7353	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1
11/13/2025 11:48	S25-7354	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	11
11/13/2025 11:39	S25-7355	Block 3 Lot 27, Rosewood Homes I	ABSENCE	ABSENCE	7
11/13/2025 10:26	S25-7350	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
11/13/2025 10:37	S25-7351	Block 14 Lot 7, Buena Rosa 10	ABSENCE	ABSENCE	< 1
11/13/2025 12:53	S25-7358	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
11/13/2025 13:01	S25-7359	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1
11/13/2025 12:07	S25-7356	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	4
11/20/2025 10:40	S25-7548	Pepa Wings, Robinson's Mall	ABSENCE	ABSENCE	47
11/20/2025 13:20	S25-7566	Water Pump, Metrogate Heritage Subdivision	ABSENCE	ABSENCE	< 1
11/20/2025 13:38	S25-7567	Clubhouse, Metrogate Heritage Subdivision	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A**- Enzyme Substrate; **B**– Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph
CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS


NO. OF SAMPLES : 39


TOTAL PARAMETERS TESTED : 3

ANALYSIS DATE(S) : 11/11/2025-11/26/2025

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATIOHN	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
11/26/2025 11:17	S25-7658	Laguna Wellfield 1	ABSENCE	ABSENCE	3
BRGY. BALIBAGO					
11/18/2025 14:41	S25-7470	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
11/13/2025 15:39	S25-7364	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
11/24/2025 11:57	S25-7579	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
11/24/2025 11:49	S25-7580	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	< 1
11/20/2025 14:00	S25-7565	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
11/20/2025 11:50	S25-7555	Water Pump, Phase IIIE, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
11/20/2025 12:12	S25-7556	Block 2 Lot 10, Phase IIIE, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
11/20/2025 12:29	S25-7557	Water Pump, Block 12, Phase IIE, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
11/20/2025 12:45	S25-7558	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
11/13/2025 15:03	S25-7363	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	< 1
11/20/2025 13:00	S25-7559	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
11/20/2025 10:41	S25-7560	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
11/20/2025 10:11	S25-7561	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1
11/20/2025 10:20	S25-7562	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE

REVIEWED BY:

 MARVIN JASPER G. ABENOJAR
 Microbiology Unit Manager

APPROVED BY:

 KRISTEEN Y. ALDAY, RCh
 Analytical Service Unit Manager
 License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
11/20/2025 11:00	S25-7563	#1780, National Road	ABSENCE	ABSENCE	< 1
11/20/2025 13:39	S25-7568	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	< 1
11/13/2025 14:23	S25-7362	Gate Entrance, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
11/11/2025 11:01	S25-7235	Church, Block 108, Phase V, Laguna Bel-Air	ABSENCE	ABSENCE	240
11/25/2025 14:02	S25-7652	Clubhouse, Phase I, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
11/11/2025 11:52	S25-7238	Block 47 Lot 12, Phase IV, Laguna Bel-Air	ABSENCE	ABSENCE	1
11/11/2025 14:40	S25-7229	Clubhouse, Phase IV-B, Santa Rosa Village I	ABSENCE	ABSENCE	130
11/11/2025 14:49	S25-7230	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	180
11/11/2025 13:26	S25-7231	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
11/11/2025 13:32	S25-7232	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
11/11/2025 12:24	S25-7239	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	64
BRGY. MACABLING					
11/13/2025 10:01	S25-7349	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1
11/13/2025 09:45	S25-7348	Clubhouse, Corinthian Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
11/20/2025 11:22	S25-7564	Guard house, Casan Residencia Subdivision	ABSENCE	ABSENCE	< 1
11/13/2025 13:42	S25-7361	Gate Entrance, Terra Fortuna	ABSENCE	ABSENCE	< 1
11/13/2025 13:25	S25-7360	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1
BRGY. POOC					
11/18/2025 13:41	S25-7473	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	14
11/18/2025 13:50	S25-7474	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ					
11/24/2025 12:21	S25-7581	Water Pump, Buklod Diwa	ABSENCE	ABSENCE	< 1
11/24/2025 12:29	S25-7582	Manzano Residence, Buklod Diwa	ABSENCE	ABSENCE	< 1
11/24/2025 12:10	S25-7584	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

Marvin Jasper G. Abenojar
MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:

Kristeen Y. Alday
KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. SANTO DOMINGO					
11/11/2025 13:46	S25-7233	Clubhouse, Santa Rosa Estates II	ABSENCE	ABSENCE	< 1
11/20/2025 13:49	S25-7551	Water Pump, Brgy. Sto. Domingo	ABSENCE	ABSENCE	< 1
11/20/2025 13:58	S25-7552	Labrador Residence	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: HPC – Heterotrophic Plate Count; CFU – Colony Forming Units; MDL – Method Detection Limit; LOQ – Limit of Quantification; NA – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: A– Enzyme Substrate; B – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S25-7659

DATE/TIME SUBMITTED : 11/26/2025 11:44

DATE/TIME COLLECTION : 11/26/2025 09:23

COLLECTED BY : Jonnel S. Mercado

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BOOSTER 1, LAGUNA TECHNOPARK INC., SANTA ROSA CITY, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
*Residual Chlorine	mg/L	0.74	4500-Cl-G.DPD Colorimetric	11/26/2025	JSM
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/26/2025	SBA
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	11/26/2025	SBA
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	< 1	9215B. Pour Plate Method	11/26/2025	SBA

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*. Performed onsite


DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 24th Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


MARVIN JASPER G. ABENOJAR
Microbiology Unit Manager

APPROVED BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)