

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE I

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 21

TOTAL PARAMETERS TESTED: 3

ANALYSIS DATE(S) : 10/19/2023-10/26/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
10/25/2023 10:05	S23-5812	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. CAINGIN					
10/19/2023 11:27	S23-5642	Water Pump, Block 57, Phase 1, Southville	ABSENCE	ABSENCE	< 1
10/19/2023 11:59	S23-5643	Block 25 Lot 7, Phase 3, Southville	ABSENCE	ABSENCE	< 1
10/19/2023 11:40	S23-5646	Block 2 Lot 16, Phase 8 Southville	ABSENCE	ABSENCE	< 1
10/19/2023 11:19	S23-5644	Southville Integrated Highschool	ABSENCE	ABSENCE	< 1
BRGY. KANLURAN					
10/19/2023 10:48	S23-5639	Gate Entrance, Alfonso Homes I	ABSENCE	ABSENCE	< 1
BRGY. MALUSAK					
10/19/2023 10:18	S23-5638	Santa Rosa City Hall, J.P. Rizal Boulevard	ABSENCE	ABSENCE	< 1
10/19/2023 10:27	S23-5645	Drinking Fountain, I, Central I Elementary	ABSENCE	ABSENCE	< 1
BRGY. SINALHAN					
10/19/2023 09:48	S23-5636	Block 8 Lot 16, Bayshore III	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. TAGAPO					
10/26/2023 09:15	S23-5839	#60 31 JP Rizal Boulevard	ABSENCE	ABSENCE	< 1
10/24/2023 11:03	S23-5745	Block 1 Lot 18, Fairfield of Margana Subdivision	ABSENCE	ABSENCE	< 1
10/24/2023 11:33	S23-5751	Water Pump, Rosewood Homes I	ABSENCE	ABSENCE	< 1
10/24/2023 11:43	S23-5752	Block 3 Lot 31, Rosewood Homes I	ABSENCE	ABSENCE	< 1
10/23/2023 10:48	S23-5690	Pump House Eye Wash, Buena Rosa 1 Subdivision	ABSENCE	ABSENCE	< 1
10/24/2023 10:15	S23-5746	Block 14 Lot 7 Buena Rosa 10 Subdivision	ABSENCE	ABSENCE	< 1
10/24/2023 12:34	S23-5747	Cistern Tank, SM Santa Rosa	ABSENCE	ABSENCE	< 1
10/24/2023 12:46	S23-5748	Admin Pantry, SM Santa Rosa	ABSENCE	ABSENCE	< 1
10/24/2023 12:04	S23-5749	Cistern Tank, Robinson's Mall	ABSENCE	ABSENCE	< 1
10/24/2023 12:16	S23-5750	Sizzlers, Robinson's Mall	ABSENCE	ABSENCE	< 1
10/23/2023 13:29	S23-5715	Water Pump, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1
10/23/2023 13:38	S23-5716	Clubhouse, Metrogate Heritage Subd.	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A**- Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:



NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:



ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : SANTA ROSA CITY HEALTH OFFICE II

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 41

TOTAL PARAMETERS TESTED : 3


ANALYSIS DATE(S) : 10/02/2023-10/26/2023

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. BIÑAN					
10/25/2023 10:05	S23-5812	Laguna Wellfield 1	ABSENCE	ABSENCE	< 1
BRGY. BALIBAGO					
10/19/2023 12:31	S23-5637	#4354 Facundo Compound	ABSENCE	ABSENCE	< 1
10/05/2023 10:26	S23-5435	Clubhouse, South Hampton Residences	ABSENCE	ABSENCE	< 1
10/05/2023 10:14	S23-5441	Water Pump, South Hampton Residences	ABSENCE	ABSENCE	< 1
10/24/2023 14:30	S23-5753	Cistern Tank, Waltermart Santa Rosa	ABSENCE	ABSENCE	< 1
10/24/2023 14:10	S23-5754	2 nd Floor faucet, Waltermart, Santa Rosa	ABSENCE	ABSENCE	< 1
10/23/2023 11:29	S23-5714	Block 5 Lot 25, JB Village	ABSENCE	ABSENCE	< 1
BRGY. DILA					
10/23/2023 12:18	S23-5704	Water Pump, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
10/23/2023 12:29	S23-5705	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000, Golden City Subdivision	ABSENCE	ABSENCE	< 1
10/23/2023 12:40	S23-5706	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
10/23/2023 12:58	S23-5707	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	ABSENCE	ABSENCE	< 1
10/05/2023 10:38	S23-5436	Clubhouse, Alabaster St., Villa Esmeralda	ABSENCE	ABSENCE	< 1
10/23/2023 11:49	S23-5708	Drinking Fountain, Dila Elementary	ABSENCE	ABSENCE	< 1
BRGY. DITA					
10/23/2023 10:50	S23-5709	Block 19 Lot 11, New Santa Rosa Homes	ABSENCE	ABSENCE	< 1
10/23/2023 10:01	S23-5710	Water Tank, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1
10/23/2023 10:14	S23-5711	Block 3 Lot 7, SolCar Ville Subdivision	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
10/23/2023 10:22	S23-5712	#1780, National Road	ABSENCE	ABSENCE	< 1
10/23/2023 11:123	S23-5717	R & B Ice Plant, Inc.	ABSENCE	ABSENCE	< 1
10/05/2023 10:47	S23-5437	Clubhouse, San Lorenzo Royale	ABSENCE	ABSENCE	< 1
BRGY. DON JOSE					
10/02/2023 10:11	S23-5322	Church, Block 108, Phase 5, Laguna Bel-Air	ABSENCE	ABSENCE	220
10/02/2023 11:23	S23-5321	Clubhouse, Phase 1, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
10/02/2023 11:11	S23-5325	Block 47 Lot 12, Phase 4, Laguna Bel-Air	ABSENCE	ABSENCE	< 1
10/02/2023 12:38	S23-5316	Clubhouse, Phase 4B, Santa Rosa Village I	ABSENCE	ABSENCE	< 1
10/02/2023 12:51	S23-5317	Clubhouse, Santa Rosa Village II	ABSENCE	ABSENCE	< 1
10/02/2023 11:58	S23-5318	Pump 9 & 10, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
10/02/2023 12:05	S23-5319	Clubhouse, Santa Rosa Estates I	ABSENCE	ABSENCE	< 1
10/02/2023 11:38	S23-5326	Drinking Fountain, Don Jose National High School	ABSENCE	ABSENCE	< 1
BRGY. MACABLING					
10/23/2023 10:24	S23-5689	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	ABSENCE	ABSENCE	< 1
10/23/2023 10:01	S23-5687	Water Pump, Corinthian Subdivision	ABSENCE	ABSENCE	< 1
10/23/2023 10:14	S23-5688	Block 11 Lot 19, Corinthian Subdivision	ABSENCE	ABSENCE	< 1
BRGY. MALITLIT					
10/23/2023 11:18	S23-5713	Guardhouse, Casan Residencia Subdivision	ABSENCE	ABSENCE	< 1
10/05/2023 10:03	S23-5440	Block 11 Lot 16, Terra Fortuna	ABSENCE	ABSENCE	< 1
10/05/2023 09:36	S23-5438	Water Pump, 9999 W, Villa Las Casas	ABSENCE	ABSENCE	< 1
10/05/2023 09:51	S23-5439	Block 1 Lot 17, Villa Las Casas	ABSENCE	ABSENCE	< 1


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER		
			COLIFORM ^A		HPC ^B (CFU/mL)
			TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
BRGY. POOC					
10/19/2023 12:11	S23-5640	Water Pump, Villa Mercedes	ABSENCE	ABSENCE	< 1
10/19/2023 12:19	S23-5641	Block 2 Lot 1, Villa Mercedes	ABSENCE	ABSENCE	< 1
BRGY. PULONG STA. CRUZ					
10/09/2023 09:19	S23-5455	Manzano Residence	ABSENCE	ABSENCE	< 1
10/09/2023 09:09	S23-5454	Water Pump	ABSENCE	ABSENCE	< 1
10/09/2023 08:49	S23-5453	Wash Area, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1
10/09/2023 08:30	S23-5452	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	ABSENCE	ABSENCE	< 1
BRGY. SANTO DOMINGO					
10/02/2023 13:07	S23-5320	Clubhouse Santa Rosa Estates II	ABSENCE	ABSENCE	< 1
10/04/2023 14:35	S23-5420	Water Pump	ABSENCE	ABSENCE	< 1
10/02/2023 13:50	S23-5328	Tope Residence	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable (-) Not performed

DEVIATIONS: No deviation noted on sample collection and submission.


METHODS: **A** – Enzyme Substrate; **B** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


NOWEL ELLISON G. RAMOS, RMT
Microbiology Unit Manager
License No(s). (PRC 0090336)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)