

DOH Accredited Testing Laboratory (04A-001-1820-LW-2); PNRI (RML No. Y04.04132.17); and PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

Test Report ID

: TR-19-1435

Date Issued

: 05/27/2019

Sample Code

: S19-2259

Document Number

: 19-WQM-05-STC-01

Name of Company / Customer

: Laguna Water Corporation

Address

: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected

: 05/21/2019 13:02

Date/Time Submitted : 05/21/2019 19:20

Collected By

: Elmer P. Palmares, Jr.

Submitted By

: Elmer P. Palmares, Jr.

Condition of Sample Upon Receipt

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium

thiosulfate

Sample Source Characteristics

: Source - Treated Water (w/ Chlorination)

References

: Standard Methods for the Examination of Water and Wastewater, 23rd Edition : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : SOURCE, AFTER DMI-65 FILTRATION, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate	05/21/2019	JDE
			Test (Colilert-18®)		
Thermotolerant Coliform /	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate	05/21/2019	JDE
Escherichia coli			Test (Colilert-18®)		
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	05/21/2019	JDE

Remarks: Samples Analyzed as Submitted. Legend: CFU - Colony Forming Units

CERTIFIED CORRECT BY:

Microbiologist PRC License No. 0060968 NOTED BY:

CYRIL A. FRICA RMT Laboratory Services Manager PRC License No. 0054161

Test Report QC Checked By:

Date of Test Report QC Check: July

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); PNRI (RML No. Y04.04132.17); and PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1436 Date Issued : 05/27/2019

Sample Code : \$19-2260 **Document Number** : 19-WQM-05-STC-02

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 05/21/2019 12:46 Date/Time Submitted : 05/21/2019 19:20

Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium Condition of Sample Upon Receipt

thiosulfate

Sample Source Characteristics : Distribution - Network Sampling Point

: Standard Methods for the Examination of Water and Wastewater, 23rd Edition References

: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : GRANDSTAND, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/21/2019	JDE
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/21/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	05/21/2019	JDE

Remarks: Samples Analyzed as Submitted. Legend: CFU - Colony Forming Units

CERTIFIED CORRECT BY:

Microbiologist

PRC License No. 0060968

NOTED BY:

ERICA, RIVIT Laboratory Services Manager

PRC License No. 0054161

Test Report QC Checked By:

Date of Test Report QC Check: Shalls

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-001-1820-LW-2);
PNRI (RML No. Y04.04132.17); and PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1437 Date Issued : 05/27/2019

Sample Code : S19-2261 Document Number : 19-WQM-05-STC-03

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 05/21/2019 13:25 Date/Time Submitted : 05/21/2019 19:20

Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.

Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium

thiosulfate

Sample Source Characteristics : Source – Treated Water (w/ Chlorination)

References : Standard Methods for the Examination of Water and Wastewater, 23rd Edition

: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA

AVE., LAGUNA PROVINCIAL CAPITOL, STA. CRUZ,

LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/21/2019	JDE
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/21/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	05/21/2019	JDE

Remarks: Samples Analyzed as Submitted. Legend: CFU – Colony Forming Units

CERTIFIED CORRECT BY:

ANNA KARLA S GUTTERREZ, RMT

Microbiologist
PRC License No. 0060968

Test Report QC Checked By:

NOTED BY:

CYRIL A. FRICA, RMT
Laboratory Services Manager
PRC License No. 0054161

By: Date of Test Report QC Check: Shalls

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); PNRI (RML No. Y04.04132.17); and PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

Test Report ID : TR-19-1438 Date Issued : 05/27/2019

Sample Code : \$19-2262 **Document Number** : 19-WQM-05-STC-04

Name of Company / Customer : Laguna Water Corporation

Address ; G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 05/21/2019 13:47 Date/Time Submitted : 05/21/2019 19:20

Collected By Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium Condition of Sample Upon Receipt

thiosulfate

Sample Source Characteristics

: Distribution - Network Sampling Point

: Standard Methods for the Examination of Water and Wastewater, 23rd Edition References

: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

RESULTS OF LABORATORY ANALYSIS

SAMPLE LOCATION : OLD CAPITOL BUILDING, CAPITOL COMPOUND, P.

GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL, STA.

CRUZ, LAGUNA

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYZED	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/21/2019	JDE
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	05/21/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	9215B. Pour Plate Method	05/21/2019	JDE

Remarks: Samples Analyzed as Submitted. Legend: CFU - Colony Forming Units

CERTIFIED CORRECT BY:

Microbiologist

PRC License No. 0060968

NOTED BY:

CYRIL A. PRICA, RMT **Laboratory Services Manager** PRC License No. 0054161

Test Report QC Checked By:

Date of Test Report QC Check: 41419

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAAWater Corporation. This report is certified to have passed the Laguna AAAWater Corporation Quality Control procedures for reporting results of analysis