

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME : LAGUNA AAAWATER CORPORATION**

**ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna**

**ATTENTION : SANTA ROSA CITY HEALTH OFFICE I**

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES : 25**

**TOTAL PARAMETERS TESTED : 5**

**ANALYSIS DATE(S) : 02/01/2021 – 02/17/2021**

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)  MDL: NA LOQ: NA	RESIDUAL CHLORINE <sup>B</sup> (mg/L)  MDL: 0.06 LOQ: 0.20	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. BIÑAN</b>							
02/01/2021 12:59	S20-0223	Laguna Wellfield 1	7.57 /29.7	0.70	ABSENCE	ABSENCE	< 1
<b>BRGY. CAINGIN</b>							
02/15/2021 11:42	S21-1272	Water Pump, Block 57, Phase 1, Southville	-	1.18	ABSENCE	ABSENCE	< 1
02/15/2021 12:28	S21-1273	Block 25 Lot 7, Phase 3, Southville	-	0.06	ABSENCE	ABSENCE	< 1
02/15/2021 11:48	S21-1274	Southville National Highschool	-	1.05	ABSENCE	ABSENCE	< 1
02/15/2021 12:00	S21-1276	Water Pump, Phase 8 & 9, Southville	-	0.13	ABSENCE	ABSENCE	< 1
02/15/2021 12:06	S21-1277	Block 2 Lot 16, Phase 9, Southville	-	0.28	ABSENCE	ABSENCE	< 1
02/15/2021 12:34	S21-1278	Water Pump, Phase 5, Southville	-	0.13	ABSENCE	ABSENCE	< 1
<b>BRGY. KANLURAN</b>							
02/15/2021 12:53	S21-1269	Gate Entrance, Alfonso Homes I	-	0.12	ABSENCE	ABSENCE	< 1
02/15/2021 12:59	S21-1267	#621 Rizal Boulevard	-	0.10	ABSENCE	ABSENCE	1
<b>BRGY. MALUSAK</b>							
02/15/2021 13:11	S21-1268	Santa Rosa City Hall	-	0.07	ABSENCE	ABSENCE	20
02/15/2021 14:14	S21-1275	Drinking Fountain 1, Central Elementary School	-	0.19	ABSENCE	ABSENCE	20
<b>BRGY. SINALHAN</b>							
02/15/2021 13:29	S21-1266	Block 8 Lot 16, Bayshore III	-	0.11	ABSENCE	ABSENCE	11

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> ( - / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. TAGAPO</b>							
02/08/2021 12:19	S21-0980	#60 31 JP Rizal Boulevard	-	0.80	ABSENCE	ABSENCE	2
02/08/2021 12:57	S21-0982	Block 1 Lot 18, Fairfield of Margana Subdivision	-	0.86	ABSENCE	ABSENCE	< 1
02/08/2021 12:28	S21-0990	Water Pump, Rosewood Homes I	-	1.15	ABSENCE	ABSENCE	< 1
02/08/2021 12:34	S21-0991	Block 3 Lot 31, Rosewood Homes I	-	0.74	ABSENCE	ABSENCE	< 1
02/08/2021 13:07	S21-0992	Block 2 Lot 18, Rosewood Homes II	-	1.07	ABSENCE	ABSENCE	< 1
02/08/2021 10:34	S21-0981	Pump house, Buena Rosa 1 Subdivision	-	0.10	ABSENCE	ABSENCE	< 1
02/08/2021 12:02	S21-0983	Block 1 Lot 64, Buena Rosa 10 Subdivision	-	0.11	ABSENCE	ABSENCE	< 1
02/08/2021 10:58	S21-0984	Cistern Tank, SM Santa Rosa	-	0.38	ABSENCE	ABSENCE	< 1
02/08/2021 11:06	S21-0985	Admin Pantry, SM Santa Rosa	-	0.76	ABSENCE	ABSENCE	< 1
02/08/2021 11:34	S21-0986	Cistern Tank, Robinson's Mall	-	0.21	ABSENCE	ABSENCE	< 1
02/08/2021 11:41	S21-0987	Sizzler's, Robinson's Mall	-	0.14	ABSENCE	ABSENCE	3
02/11/2021 15:18	S21-1209	Water Pump, Metrogate Heritage Subd.	7.56 / 29.0	0.59	ABSENCE	ABSENCE	-
02/11/2021 15:31	S21-1210	Clubhouse, Metrogate Heritage Subd.	7.38 / 28.1	0.48	ABSENCE	ABSENCE	-

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

**CUSTOMER NAME : LAGUNA AAAWATER CORPORATION**

**ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna**

**ATTENTION : SANTA ROSA CITY HEALTH OFFICE II**

### SUMMARY OF LABORATORY ANALYSIS

**NO. OF SAMPLES : 47**

**TOTAL PARAMETERS TESTED : 5**

**ANALYSIS DATE(S) : 02/01/2021 – 02/25/2021**

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
<b>BRGY. BIÑAN</b>							
02/01/2021 12:59	S20-0223	Laguna Wellfield 1	7.57 / 29.7	0.70	ABSENCE	ABSENCE	< 1
<b>BRGY. BALIBAGO</b>							
02/08/2021 14:34	S21-0979	#1354 Facundo Compound	-	0.32	ABSENCE	ABSENCE	< 1
02/10/2021 10:49	S21-1095	Clubhouse, South Hampton Residences	7.55 / 28.3	0.22	ABSENCE	ABSENCE	1
02/11/2021 14:21	S21-1208	Block 5 Lot 25, JB Village	7.41 / 26.1	0.28	ABSENCE	ABSENCE	-
02/22/2021 10:59	S21-1507	Cistern Tank, Waltermart Santa Rosa	7.48 / 28.7	0.14	ABSENCE	ABSENCE	< 1
02/23/2021 14:15	S21-1537	2 <sup>nd</sup> Floor faucet, Waltermart, Santa Rosa	7.49 / 27.5	0.10	ABSENCE	ABSENCE	< 1
<b>BRGY. DILA</b>							
02/11/2021 11:00	S21-1196	Water Pump, Phase 3E, Mabuhay Homes 2000	7.40 / 27.8	0.24	ABSENCE	ABSENCE	-
02/11/2021 11:16	S21-1197	Block 2 Lot 10, Phase 3E, Mabuhay Homes 2000	7.37 / 27.8	0.23	ABSENCE	ABSENCE	-
02/11/2021 11:31	S21-1198	Water Pump, Block 12, Phase 2E, Mabuhay Homes 2000	7.44 / 28.8	0.19	ABSENCE	ABSENCE	-
02/11/2021 11:40	S21-1199	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	7.45 / 27.1	0.14	ABSENCE	ABSENCE	-
02/10/2021 12:25	S21-1105	Clubhouse, Alabaster St., Villa Esmeralda	7.47 / 28.4	0.30	ABSENCE	ABSENCE	< 1
02/11/2021 12:30	S21-1200	Drinking Fountain, Dila Elementary	7.48 / 28.6	0.13	ABSENCE	ABSENCE	-
<b>BRGY. DITA</b>							
02/11/2021 12:41	S21-1201	Block 24 Lot 2, New Santa Rosa Homes	7.38 / 28.6	0.11	ABSENCE	ABSENCE	-
02/11/2021 13:30	S21-1202	Block 19 Lot 11, New Santa Rosa Homes	7.38 / 27.3	0.08	ABSENCE	ABSENCE	-
02/11/2021 10:41	S21-1203	Water Tank, SolCar Ville Subdivision	7.51 / 27.6	0.49	ABSENCE	ABSENCE	-

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.*



ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> ( - / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
02/11/2021 10:30	S21-1204	Block 3 Lot 7, SolCar Ville Subdivision	7.48 / 27.1	0.47	ABSENCE	ABSENCE	-
02/11/2021 13:59	S21-1205	#1780, National Road	7.38 / 27.1	0.36	ABSENCE	ABSENCE	-
02/11/2021 16:40	S21-1211	R & B Ice Plant, Inc.	7.46 / 27.1	0.50	ABSENCE	ABSENCE	-
02/10/2021 11:03	S21-1096	Clubhouse, San Lorenzo Royale	7.52 / 27.4	0.08	ABSENCE	ABSENCE	< 1
<b>BRGY. DON JOSE</b>							
02/11/2021 13:20	S21-1189	Science High School, Phase 1, Laguna Bel-Air	7.41 / 29.7	0.30	ABSENCE	ABSENCE	-
02/11/2021 17:24	S21-1191	Church, Block 108, Phase 5, Laguna Bel-Air	7.47 / 29.6	0.14	ABSENCE	ABSENCE	-
02/11/2021 13:47	S21-1190	Block 34 Lot 59, Phase 1, Laguna Bel-Air	7.55 / 28.4	0.25	ABSENCE	ABSENCE	-
02/11/2021 16:20	S21-1195	Block 47 Lot 12, Phase 4, Laguna Bel-Air	7.60 / 28.6	0.35	ABSENCE	ABSENCE	-
02/10/2021 13:17	S21-1106	8001, Pump 1, Acacia St., Santa Rosa Village I	7.30 / 27.5	0.32	ABSENCE	ABSENCE	< 1
02/10/2021 13:23	S21-1107	Clubhouse. Phase 4B, Santa Rosa Village I	7.47 / 27.9	0.28	ABSENCE	ABSENCE	< 1
02/10/2021 13:40	S21-1108	Clubhouse, Santa Rosa Village II	7.51 / 28.3	0.30	ABSENCE	ABSENCE	< 1
02/10/2021 14:10	S21-1109	Pump 9 & 10, Santa Rosa Estates I	7.42 / 27.5	0.42	ABSENCE	ABSENCE	< 1
02/10/2021 14:14	S21-1110	Clubhouse, Santa Rosa Estates I	7.55 / 27.6	0.24	ABSENCE	ABSENCE	< 1
02/10/2021 14:58	S21-1112	Drinking Fountain, Don Jose National High School	7.55 / 28.1	0.15	ABSENCE	ABSENCE	< 1
<b>BRGY. MACABLING</b>							
02/08/2021 13:50	S21-0993	Water Pump, Buena Rosa 9 Subdivision	-	0.56	ABSENCE	ABSENCE	3
02/08/2021 13:55	S21-0994	Block 4 Lot 44, Phase 2, Buena Rosa 9 Subdivision	-	0.48	ABSENCE	ABSENCE	2
02/08/2021 13:30	S21-0988	Water Pump, Corinthian Subdivision	-	0.98	ABSENCE	ABSENCE	13
02/08/2021 13:38	S21-0989	Block 11 Lot 19, Corinthian Subdivision	-	0.94	ABSENCE	ABSENCE	< 1
<b>BRGY. MALITLIT</b>							
02/11/2021 14:16	S21-1206	Clubhouse, Casan Residencia Subdivision	7.43 / 28.5	0.07	ABSENCE	ABSENCE	-
02/10/2021 11:17	S21-1097	Water Pump, Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	7.60 / 29.6	0.24	ABSENCE	ABSENCE	1
02/10/2021 11:24	S21-1098	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	7.55 / 29.6	0.20	ABSENCE	ABSENCE	1
02/10/2021 12:08	S21-1101	Water Pump, Main Road, Phase 2, Terra Fortuna	7.42 / 28.7	0.08	ABSENCE	ABSENCE	< 1
02/10/2021 12:14	S21-1102	Block 11 Lot 16, Terra Fortuna	7.40 / 27.6	0.05	ABSENCE	ABSENCE	< 1
02/10/2021 11:38	S21-1099	Water Pump, 9999 W, Villa Las Casas	7.42 / 27.4	0.18	ABSENCE	ABSENCE	< 1
02/10/2021 11:57	S21-1100	Block 1 Lot 17, Villa Las Casas	7.51 / 27.5	0.14	ABSENCE	ABSENCE	1
02/11/2021 14:36	S21-1207	Drinking Fountain, Malitlit Elementary	7.40 / 27.3	0.08	ABSENCE	ABSENCE	-

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
CONTACT NO.: (049) 543-1916  
WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature <sup>A</sup> (- / °C)	RESIDUAL CHLORINE <sup>B</sup> (mg/L)	COLIFORM <sup>C</sup>		HPC <sup>D</sup> (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
<b>BRGY. POOC</b>							
02/15/2021 11:16	S21-1270	Water Pump, Villa Mercedes	-	0.15	ABSENCE	ABSENCE	< 1
02/15/2021 11:23	S21-1271	Block 2 Lot 1, Villa Mercedes	-	0.13	ABSENCE	ABSENCE	< 1
<b>BRGY. PULONG STA. CRUZ</b>							
02/10/2021 10:17	S21-1094	Block 6 Lot 8, Buklod Diwa	7.47 / 27.4	0.27	ABSENCE	ABSENCE	< 1
02/10/2021 12:50	S21-1103	Drinking Fountain 1, Pulong Sta. Cruz Elementary School	7.51 / 27.9	0.17	ABSENCE	ABSENCE	< 1
02/10/2021 12:56	S21-1104	Drinking Fountain II, Pulong Sta. Cruz Elementary School	7.52 / 28.3	0.13	ABSENCE	ABSENCE	< 1
<b>BRGY. SANTO DOMINGO</b>							
02/10/2021 14:37	S21-1111	Clubhouse Santa Rosa Estates II	7.47 / 27.4	0.34	ABSENCE	ABSENCE	< 1

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT  
Microbiology Unit Manager (OIC)  
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT  
Laboratory Services Manager  
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.