

DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916 WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-3990

DATE/TIME SUBMITTED : 06/22/2020 17:10

DATE/TIME COLLECTION : 06/22/2020 8:40

COLLECTED BY: Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

: SOURCE AFTER DMI-65 FILTRATION, LAGUNA SPORTS COMPLEX, BRGY. BUBUKAL, STA CRUZ CITY, **SAMPLE LOCATION**

LAGUNA

SAMPLE **CHARACTERISTICS**

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	06/22/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

Microbiology Unit Manager

Laboratory Services Manager License No(s). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : **S20-3991 DATE/TIME SUBMITTED** : 06/22/2020 17:10

DATE/TIME COLLECTION : 06/22/2020 8:15 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : GRANDSTAND, LAGUNA SPORTS COMPLEX, BRGY. BUBUKAL, STA CRUZ CITY, LAGUNA

SAMPLE

CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	АСР
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	06/22/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: <u>A</u> – Method is not part of DENR-ELR Recognized Parameters **DEVIATIONS:** No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN Microbiology Unit Manager ANNA KARLA 8. GUTTERREZ, RMT Laboratory Services Manager License No(s). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS: G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : **S20-3992 DATE/TIME SUBMITTED** : 06/22/2020 17:10

DATE/TIME COLLECTION : 06/22/2020 07:30 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVENUE, LAGUNA PROVINCIAL CAPITOL, STA

CRUZ CITY, LAGUNA

SAMPLE CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	06/22/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: $\underline{\mathbf{A}}$ – Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN Microbiology Unit Manager ANNA KARLA S. GUT FRREZ, RMT Laboratory Services Manager License No(s) (PRC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S20-3993

DATE/TIME SUBMITTED : 06/22/2020 17:10

DATE/TIME COLLECTION : 06/22/2020 06:51

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION

: OLD CAPITOL BUILDING, CAPITOL COMPOUND, P. GUEVARRA AVENUE, LAGUNA PROVINCIAL

CAPITOL, STA CRUZ CITY, LAGUNA

SAMPLE

CHARACTERISTICS

: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	ВҮ
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	06/22/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: A - Method is not part of DENR-ELR Recognized Parameters

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN Microbiology Unit Manager ANNA KARIA GUTIERREZ, AMT Laboratory Services Manager License Nols). (PRC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

DATE/TIME COLLECTION : 06/22/2020 04:43 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : CISTERN TANK, LAGUNA MEDICAL CENTER, STA CRUZ CITY, LAGUNA

SAMPLE

CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	06/22/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: <u>A</u> — Method is not part of DENR-ELR Recognized Parameters **DEVIATIONS:** No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN Microbiology Unit Manager ANNA KARLA S. GUT ERREZ, RMT Laboratory Services Manager

License No(s). (PBC 0060968)



DOH Accredited Testing Laboratory (04A-001-1820-LW-2); DENR Environmental Laboratory Recognition (ELR Code 04-30); PNRI (RML No. Y04.04132.17) PRC Certificate of Authority to Operate No. 111 PNP (License No. PDD03-230616-04201)

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME: Laguna Water Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S): **\$20-3995 DATE/TIME SUBMITTED**: 06/22/2020 17:10

DATE/TIME COLLECTION : 06/22/2020 07:15 COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1 TOTAL PARAMETERS TESTED : 3

SAMPLE LOCATION : KITCHEN, LAGUNA MEDICAL CENTER, STA CRUZ CITY, LAGUNA

SAMPLE

CHARACTERISTICS: 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

PARAMETER(S)	UNIT(S)	RESULT(S)	METHOD(S)	ANALYSIS	
				DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Thermotolerant Coliform / Escherichia coli	Coliforms/100 mL	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	06/22/2020	ACP
Heterotrophic Plate Count (HPC) ^A	Colony Forming Unit (CFU)/mL	<1	9215B. Pour Plate Method	06/22/2020	ACP

REMARKS: Samples were analyzed as submitted.

NOTE: $\underline{\mathbf{A}}$ – Method is not part of DENR-ELR Recognized Parameters **DEVIATIONS:** No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE

REVIEWED BY:

CERTIFIED CORRECT BY:

JETHRO D. ESCOBIN Microbiology Unit Manager ANNA KARLA S. OUT ERREZ, RMT Laboratory Services Manager

License No(s) (PRC 0060968)