

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S21-6140

DATE/TIME SUBMITTED : 08/23/2021 16:30

DATE/TIME COLLECTION : 08/23/2021 14:24

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : WATER PUMP, REBONG ST., BRGY. NANHAYA, VICTORIA, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|--|---------------------------------|-----------|--|------------|-----|
| | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.28 | 4500-Cl-G.DPD Colorimetric | 08/23/2021 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 08/23/2021 | NGR |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 08/23/2021 | NGR |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 08/23/2021 | NGR |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A -- Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : Laguna AAWater Corporation

ADDRESS : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

ATTENTION : N/A

SUMMARY OF LABORATORY ANALYSIS

SAMPLE CODE(S) : S21-6141

DATE/TIME SUBMITTED : 08/23/2021 16:30

DATE/TIME COLLECTION : 08/23/2021 14:45

COLLECTED BY : Edwin O. Aguilar

NO. OF SAMPLES : 1

TOTAL PARAMETERS TESTED : 4

SAMPLE LOCATION : BAUTISTA RESIDENCE, BRGY. NANHAYA, VICTORIA, LAGUNA

SAMPLE CHARACTERISTICS : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

| PARAMETER(S) | UNIT(S) | RESULT(S) | METHOD(S) | ANALYSIS | |
|--|---------------------------------|-----------|--|------------|-----|
| | | | | DATE | BY |
| *Residual Chlorine | mg/L | 0.16 | 4500-Cl-G.DPD Colorimetric | 08/23/2021 | EOA |
| Total Coliform | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 08/23/2021 | NGR |
| Thermotolerant Coliform / <i>Escherichia coli</i> | Coliforms/100 mL | ABSENCE | 9223B. Enzyme Substrate Test (Colilert-18®) | 08/23/2021 | NGR |
| Heterotrophic Plate Count (HPC) ^A | Colony Forming Unit (CFU)/mL | < 1 | 9215B. Pour Plate Method | 08/23/2021 | NGR |

REMARKS: Sample collection was performed by LWC accredited samplers and was analyzed as submitted.

NOTE: A – Method is not part of DENR-ELR Recognized Parameters

*- Performed onsite

DEVIATIONS: No deviations noted on sample collection and submission.

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


KRISTEEN Y. ALDAY, RCh
Analytical Service Unit Manager
License No(s). (PRC 0013295)


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0050968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis