

CITY/MUNICIPALITY : BIÑAN		MONTH : July		YEAR : 2019		
DOH ACCREDIATION NO : 04A-001-1820-LW-2		VALIDITY : December 31, 2020		DOCUMENT NO. : 19WQM-07-BIN		
NO	SAMPLE LOCATION ADDRESS	TYPE	DATE COLLECTED	MICROBIOLOGICAL QUALITY		
				HPC <sup>1</sup> CFU/mL	Coliforms/100 mL <sup>2</sup>	
					TOTAL	<i>Escherichia coli</i>
<b>BRGY. BIÑAN</b>						
1	Laguna Well Field 1	S	8-Jul	< 1	ABSENCE	ABSENCE
2	Guardhouse Entrance, Phase 4C, San Jose Village I	D	10-Jul	2	ABSENCE	ABSENCE
3	Clubhouse, Phase 3B, San Jose Village I	D	10-Jul	< 1	ABSENCE	ABSENCE
4	Pump 11, Phase 5, San Jose Village II	S	10-Jul	< 1	ABSENCE	ABSENCE
5	Clubhouse, Phase 5, San Jose Village II	D	10-Jul	< 1	ABSENCE	ABSENCE
6	Clubhouse, Phase 6, San Jose Village III	D	10-Jul	12	ABSENCE	ABSENCE
7	Guardhouse, AVIDA Shophouse	D	10-Jul	< 1	ABSENCE	ABSENCE
8	De La Salle University and Technology Complex	D	10-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. CANLALAY</b>						
9	Clubhouse, Golden City Canlalay	D	16-Jul	< 1	ABSENCE	ABSENCE
10	Drinking Fountain, Canlalay Elementary School	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. DELA PAZ</b>						
11	Water Pump, Almeda Subdivision	S	16-Jul	< 1	ABSENCE	ABSENCE
12	Barangay Hall	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. GANADO</b>						
13	Drinking Fountain, Ganado Elementary School	D	18-Jul	-	ABSENCE	ABSENCE
<b>BRGY. HALANG</b>						
14	9999 WP Metroville Complex	S	16-Jul	< 1	ABSENCE	ABSENCE
15	Clubhouse, Metroville Complex	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. LANGKIWA</b>						
16	Block 3 Lot 9, Phase II, Southville, Langkiwa	D	24-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. LOMA</b>						
17	Water Pump, Block 4 Lot 37, Celina Technopark	S	10-Jul	4	ABSENCE	ABSENCE
18	Block 43 Lot 13, Celina Technopark	D	10-Jul	26	ABSENCE	ABSENCE
19	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air 3	D	15-Jul	< 1	ABSENCE	ABSENCE
20	Block 10 Lot 24, Laguna Bel-Air 3	D	15-Jul	< 1	ABSENCE	ABSENCE
21	Clubhouse, Laguna Bel-Air 3	D	15-Jul	< 1	ABSENCE	ABSENCE
22	Drinking Fountain, Loma Elementary School	D	10-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. MAMPLASAN</b>						
23	Clubhouse, Verdana Homes Subdivision	D	10-Jul	< 1	ABSENCE	ABSENCE
24	United Laboratories (UNILAB) Inc.	D	18-Jul	-	ABSENCE	ABSENCE
<b>BRGY. POBLACION</b>						
25	Water Pump, Brgy. Poblacion	S	28-Jul	-	ABSENCE	ABSENCE
26	Brgy. Hall	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. PLATERO</b>						
27	Elevated Water Tank, Mondo Bambini	S	24-Jul	140	ABSENCE	ABSENCE
28	Clubhouse, Mondo Bambini	D	24-Jul	220	ABSENCE	ABSENCE
29	Elevated Water Tank, Prima Casa	S	24-Jul	23	ABSENCE	ABSENCE
30	Clubhouse, Prima Casa	D	24-Jul	91	ABSENCE	ABSENCE
31	Water Pump, Spring Time	S	24-Jul	< 1	ABSENCE	ABSENCE
32	Block 1 Lot 7, Spring Time	D	24-Jul	2	ABSENCE	ABSENCE

33	Drinking Fountain, St. Michael School of Biñan	D	18-Jul	-	ABSENCE	ABSENCE
34	Sea-oil, National Road	D	18-Jul	-	ABSENCE	ABSENCE
<b>BRGY. SAN ANTONIO</b>						
35	Biñan City Hall	S	18-Jul	-	ABSENCE	ABSENCE
36	Alonte Stadium	D	18-Jul	-	ABSENCE	ABSENCE
37	Water Pump, Margarita Homes Subdivision	S	18-Jul	-	ABSENCE	ABSENCE
38	Block 5 Lot 12, Margarita Homes Subdivision	D	18-Jul	-	ABSENCE	ABSENCE
39	9022 Water Pump (WP) Faraon Subdivision	S	16-Jul	< 1	ABSENCE	ABSENCE
40	Malaban Health Center	D	16-Jul	< 1	ABSENCE	ABSENCE
41	Drinking Fountain 1, Malaban Elementary School	D	16-Jul	< 1	ABSENCE	ABSENCE
42	Drinking Fountain 2, Malaban Elementary School	D	16-Jul	< 1	ABSENCE	ABSENCE
43	Cistern Tank, Pavillion Mall	D	18-Jul	-	ABSENCE	ABSENCE
44	Mesa Inasal, Pavillion Mall	D	18-Jul	-	ABSENCE	ABSENCE
<b>BRGY. SANTO NIÑO</b>						
45	Jollibee National Hi-Way	D	18-Jul	-	ABSENCE	ABSENCE
<b>BRGY. SAN VICENTE</b>						
46	407 Water Pump, San Vicente Subdivision	S	24-Jul	< 1	ABSENCE	ABSENCE
47	Block 8 Lot 6, Bayabas St., Phase 8 Olivarez Homes	D	24-Jul	6	ABSENCE	ABSENCE
48	Biñan Doctors Hospital	D	18-Jul	-	ABSENCE	ABSENCE
49	Cistern Tank, Central Mall	D	24-Jul	< 1	ABSENCE	ABSENCE
50	Drinking Fountain, San Vicente Elementary Sch.	D	24-Jul	< 1	ABSENCE	ABSENCE
51	Biñan Intergrated National High School	D			ABSENCE	ABSENCE
<b>BRGY. SANTO TOMAS</b>						
52	HOA Office, Adelina Subdivsion	S	18-Jul	-	ABSENCE	ABSENCE
53	Block 1 Lot 16, Phase 4, Olivarez Homes South	D	24-Jul	< 1	ABSENCE	ABSENCE
54	Water Pump, Pragmatic	S	24-Jul	< 1	ABSENCE	ABSENCE
55	Block 1 Lot 5, Bais St., Pragmatic	D	24-Jul	11	ABSENCE	ABSENCE
56	Tawi Tawi St., Phase 6, South City Homes	D	24-Jul	< 1	ABSENCE	ABSENCE
57	Pump, South Plains II Subdivision	S	24-Jul	< 1	ABSENCE	ABSENCE
58	Block 11 Lot 2, South Plains II Subdivision	D	24-Jul	6	ABSENCE	ABSENCE
59	Block 35 Lot 21, Southville Town and Country	D	24-Jul	< 1	ABSENCE	ABSENCE
60	Water Pump, Town & Country - Amsterdam	S	24-Jul	< 1	ABSENCE	ABSENCE
61	Block 35 Lot 21, Town & Country - Amsterdam	D	24-Jul	3	ABSENCE	ABSENCE
62	Block 2 Lot 5, Town & Country - Pennsylvania	D	24-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. SORO - SORO</b>						
63	9067 Soro-soro	S	16-Jul	1	ABSENCE	ABSENCE
64	#76 Soro-Soro	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. TUBIGAN</b>						
65	#60 Florinda Compound	D	24-Jul	4	ABSENCE	ABSENCE
<b>BRGY. ZAPOTE</b>						
66	Wate Pump, Summer Breeze	S	24-Jul	< 1	ABSENCE	ABSENCE
67	Clubhouse, Summer Breeze	D	24-Jul	15	ABSENCE	ABSENCE
68	Elevated Water Tank, Evergreen	S	24-Jul	33	ABSENCE	ABSENCE
69	Clubhouse, Evergreen	D	24-Jul	4	ABSENCE	ABSENCE
70	Clubhouse, Althea	D	18-Jul	-	ABSENCE	ABSENCE
<b>TOTAL SAMPLES ANALYZED</b>		<b>70</b>	<b>PNSDW LIMIT</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>

**REMARKS:** Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: <sup>1</sup>Pour Plate, <sup>2</sup>Enzyme Substrate (Colilert®-18)

**CERTIFIED CORRECT:**

  
**ANNA KARLA S. GUTIERREZ, RMT**

Microbiologist

PRC License No. 0060968

**NOTED BY:**

  
**CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>**

Laboratory Services Manager

License No(s). (PRC 0054161/ASCP 10981)

CITY/MUNICIPALITY : CABUYAO	MONTH : July	YEAR : 2019
DOH ACCREDIATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-07-CAB

NO	SAMPLE LOCATION			DATE COLLECTED	MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE	HPC <sup>1</sup>		Coliforms/100 mL <sup>2</sup>		
					TOTAL	<i>Escherichia coli</i>	
				CFU/mL			
<b>BRGY. BANAY-BANAY</b>							
1	Water Pump, Block 63, Lakeside Nest Subdivision	S	9-Jul	< 1	ABSENCE	ABSENCE	
2	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	D	9-Jul	< 1	ABSENCE	ABSENCE	
<b>BRGY. BANLIC</b>							
3	Water Pump, Gran Seville Subdivision	S	23-Jul	12	ABSENCE	ABSENCE	
4	Gate Entrance, Gran Seville Subdivision	D	23-Jul	< 1	ABSENCE	ABSENCE	
<b>BRGY. BIGAA</b>							
5	#253 Elsol Subdivision	D	9-Jul	< 1	ABSENCE	ABSENCE	
<b>BRGY. GULOD</b>							
6	Block 12, Noah St., Celestine Ville	S	18-Jul	-	ABSENCE	ABSENCE	
7	Guardhouse, Celestine Ville	D	18-Jul	-	ABSENCE	ABSENCE	
<b>BRGY. MARINIG</b>							
8	Block 3 Lot 17, Phase 1, Celestine Homes	S	9-Jul	< 1	ABSENCE	ABSENCE	
9	Block 23, Lot 10, Phase 1, Celestine Homes	D	9-Jul	< 1	ABSENCE	ABSENCE	
10	Block 9, Carnation St., Phase 2, Celestine Homes	S	9-Jul	< 1	ABSENCE	ABSENCE	
11	Block 13 Lot 2, Phase 2, Celestine Homes	D	9-Jul	< 1	ABSENCE	ABSENCE	
<b>BRGY. NIUGAN</b>							
12	Water Pump, Block 25, Phase 3, Southville	S	9-Jul	< 1	ABSENCE	ABSENCE	
13	Block 19 Lot 33, Phase 3, Southville	D	9-Jul	< 1	ABSENCE	ABSENCE	
14	Block 2 Lot 6, St. Francis Homes 6	D	9-Jul	< 1	ABSENCE	ABSENCE	
15	Water Pump, Block 45, Phase 8, Southville	S	9-Jul	< 1	ABSENCE	ABSENCE	
16	Block 40 Lot 132, Southville	D	9-Jul	< 1	ABSENCE	ABSENCE	
17	Water Pump, Block 54, Phase 10, Southville	S	9-Jul	< 1	ABSENCE	ABSENCE	
18	Block 47 Lot 101, Phase 10, Southville	D	9-Jul	< 1	ABSENCE	ABSENCE	
<b>BRGY. SAN ISIDRO</b>							
19	Block 3 Lot 33, Multiland IV	D	23-Jul	< 1	ABSENCE	ABSENCE	
20	Water Pump, San Isidro Heights Subdivision	S	23-Jul	< 1	ABSENCE	ABSENCE	
21	Block 3 Lot 1, San Isidro Heights Subdivision	D	23-Jul	< 1	ABSENCE	ABSENCE	
<b>TOTAL SAMPLES ANALYZED</b>			<b>21</b>	<b>PNSDW</b>	<b>&lt; 1</b>	<b>ABSENCE</b>	<b>ABSENCE</b>

**REMARKS:** Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: <sup>1</sup>Pour Plate, <sup>2</sup>Enzyme Substrate (Colilert®-18)

**CERTIFIED CORRECT:**

**ANNA KARLA S. GUTIERREZ, RMT**

Microbiologist

PRC License No. 0060968

**NOTED BY:**

**CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>**

Laboratory Services Manager

License No(s). (PRC 0054161/ASCP 10981)

<b>CITY/MUNICIPALITY</b> : CABUYAO	<b>MONTH</b> : July	<b>YEAR</b> : 2019
<b>DOH ACCREDITATION NO</b> : 04A-001-1820-LW-2	<b>VALIDITY</b> : December 31, 2020	<b>DOCUMENT NO.</b> : 19WQM-07-CAB

NO	SAMPLE LOCATION ADDRESS	TYPE	DATE COLLECTED	MICROBIOLOGICAL QUALITY		
				HPC <sup>1</sup> CFU/mL	Coliforms/100 mL <sup>2</sup>	
					TOTAL	<i>Escherichia coli</i>
<b>BRGY. MAMATID</b>						
1	Tank, Buena Rosario Subdivision	S	18-Jul	-	ABSENCE	ABSENCE
2	Block 7 Lot 6, Buena Rosario Subdivision	D	18-Jul	-	ABSENCE	ABSENCE
3	Block 101 Samar st., Phase 2, Mabuhay City	S	18-Jul	-	ABSENCE	ABSENCE
4	Block 94 Lot 57, Guimaras St., Phase 1, Mabuhay City	D	18-Jul	-	ABSENCE	ABSENCE
5	Block 141, Carmona St., Phase 2, Mabuhay City	S	18-Jul	-	ABSENCE	ABSENCE
6	Block 134 Lot 22, Phase 2, Mabuhay City	D	18-Jul	-	ABSENCE	ABSENCE
7	Block 198, Galacia St., Phase 2, Mabuhay City	S	18-Jul	-	ABSENCE	ABSENCE
8	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	D	18-Jul	-	ABSENCE	ABSENCE
9	Panganig St., Phase 3 Cluster, Mabuhay City	S	23-Jul	9	ABSENCE	ABSENCE
10	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	D	23-Jul	< 1	ABSENCE	ABSENCE
11	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	S	18-Jul	-	ABSENCE	ABSENCE
12	Block 19 Lot 13, Malang St., Phase 3 Luxury, Mabuhay	D	18-Jul	-	ABSENCE	ABSENCE
13	Water Pump, Joshua St., Phase 5, Mabuhay City	S	23-Jul	2	ABSENCE	ABSENCE
14	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	D	23-Jul	52	ABSENCE	ABSENCE
15	Source, Phase 1E Mabuhay Executive	S	18-Jul	-	ABSENCE	ABSENCE
16	Block 236 Lot 9, Phase 1E Mabuhay Executive	D	18-Jul	-	ABSENCE	ABSENCE
<b>BRGY. PULO</b>						
17	Water Pump, Block 12 Lot 22, Cabuyao Central	S	23-Jul	< 1	ABSENCE	ABSENCE
18	Clubhouse, Narra Avenue, Cabuyao Central	D	23-Jul	< 1	ABSENCE	ABSENCE
19	Water Pump, Block 11, Willow Park Homes	S	23-Jul	< 1	ABSENCE	ABSENCE
20	Clubhouse, Willow Park Homes	D	23-Jul	15	ABSENCE	ABSENCE
<b>TOTAL SAMPLES ANALYZED</b>		<b>20</b>	<b>PNSDW</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>

**REMARKS:** Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: <sup>1</sup>Pour Plate, <sup>2</sup>Enzyme Substrate (Colilert®-18)

**CERTIFIED CORRECT:**

**ANNA KARLA S. GUTIERREZ, RMT**

Microbiologist

PRC License No. 0060968

**NOTED BY:**

**CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>**

Laboratory Services Manager

License No(s). (PRC 0054161/ASCP 10981)

CITY/MUNICIPALITY : SANTA ROSA	MONTH : July	YEAR : 2019
DOH ACCREDIATION NO : 04A-001-1820-LW-2	VALIDITY : December 31, 2020	DOCUMENT NO. : 19WQM-07-STR


SAMPLE LOCATION				MICROBIOLOGICAL QUALITY		
NO	ADDRESS	TYPE	DATE COLLECTED	HPC <sup>1</sup>	Coliforms/100 mL <sup>2</sup>	
				CFU/mL	TOTAL	<i>Escherichia coli</i>
<b>BRGY. CAINGIN</b>						
1	Water Pump, Block 57, Phase 1, Southville	S	16-Jul	< 1	ABSENCE	ABSENCE
2	Block 25 Lot 7, Phase 3, Southville	D	16-Jul	1	ABSENCE	ABSENCE
4	Phase 8 & 9, Southville	S	16-Jul	< 1	ABSENCE	ABSENCE
5	Block 2 Lot 16, Phase 9, Southville	D	16-Jul	< 1	ABSENCE	ABSENCE
6	Water Pump, Phase 5, Southville	s	16-Jul	3	ABSENCE	ABSENCE
7	Southville National High School, Southville	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. KANLURAN</b>						
8	#621 Rizal Boulevard	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. LABAS</b>						
9	Block 18 Lot 2, Alfonso Homes I	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. MALUSAK</b>						
10	Drinking Fountain 1, Central 1 Elementary Sch.	D	16-Jul	< 1	ABSENCE	ABSENCE
11	Drinking Fountain, Santa Rosa City Hall	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. MARKET AREA</b>						
12	Source, Market Area	S	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. SINALHAN</b>						
13	Block 8 Lot 16, Bayshore III	D	16-Jul	< 1	ABSENCE	ABSENCE
14	4026, Sinalhan Road, Purok 2	S	16-Jul	< 1	ABSENCE	ABSENCE
15	Amoranto Compund, Phase 2, Sinalhan	D	16-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. TAGAPO</b>						
16	Water Pump, Fairfield of Margana Subdivision	S	11-Jul	-	ABSENCE	ABSENCE
17	Block 2 Lot 21, Fairfield of Margana Subdivision	D	11-Jul	-	ABSENCE	ABSENCE
18	Water Pump, Rosewood Homes I	S	11-Jul	-	ABSENCE	ABSENCE
19	Block 3 Lot 31, Rosewood Homes I	D	11-Jul	-	ABSENCE	ABSENCE
20	Block 4 Lot 1, Rosewood Homes II	D	11-Jul	-	ABSENCE	ABSENCE
21	#31 JP Rizal Boulevard	D	11-Jul	-	ABSENCE	ABSENCE
22	Water Pump, Buena Rosa 1 Subdivision	S	11-Jul	-	ABSENCE	ABSENCE
23	Clubhouse, Buena Rosa 1 Subdivision	D	11-Jul	-	ABSENCE	ABSENCE
24	Water Pump, Buena Rosa 10 Subdivision	S	11-Jul	-	ABSENCE	ABSENCE
25	Block 1 Lot 64, Buena Rosa 10 Subdivision	D	11-Jul	-	ABSENCE	ABSENCE
26	Cistern Tank, SM Sta. Rosa	D	11-Jul	-	ABSENCE	ABSENCE
27	Admin Pantry, SM Sta. Rosa	D	11-Jul	-	ABSENCE	ABSENCE
28	Cistern Tank, Robinson's Mall	D	11-Jul	-	ABSENCE	ABSENCE
29	Ilonggo Express, Robinson's Mall	D	11-Jul	-	ABSENCE	ABSENCE
<b>TOTAL SAMPLES ANALYZED</b>			<b>29</b>	<b>PNSDW</b>	<b>&lt;500</b>	<b>ABSENCE</b>

**REMARKS:** Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: <sup>1</sup>Pour Plate, <sup>2</sup>Enzyme Substrate (Collert®-18)

**CERTIFIED CORRECT:**

  
**ANNA KARLA S. GUTIERREZ, RMT**  
Microbiologist  
PRC License No. 0060968

**NOTED BY:**

  
**CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>**  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

<b>CITY/MUNICIPALITY</b> : SANTA ROSA	<b>MONTH</b> : July	<b>YEAR</b> : 2019
<b>DOH ACCREDIATION NO</b> : 04A-001-1820-LW-2	<b>VALIDITY</b> : December 31, 2020	<b>DOCUMENT NO.</b> : 19WQM-07-STR

NO	SAMPLE LOCATION ADDRESS	TYPE	DATE COLLECTED	MICROBIOLOGICAL QUALITY		
				HPC <sup>1</sup> CFU/mL	Coliforms/100 mL <sup>2</sup>	
					TOTAL	<i>Escherichia coli</i>
<b>BRGY. BALIBAGO</b>						
1	#1354 Facundo Compound	D	11-Jul	-	ABSENCE	ABSENCE
2	5555 Water Pump Elevated, South Hampton	S	17-Jul	< 1	ABSENCE	ABSENCE
3	Clubhouse, South Hampton	D	17-Jul	1	ABSENCE	ABSENCE
4	Block 5 Lot 19, JB Village, Sta. Rosa Tagaytay Road	D	10-Jul	< 1	ABSENCE	ABSENCE
5	Cistern Tank, Walter Mart	D	23-Jul	< 1	ABSENCE	ABSENCE
6	2nd Floor Faucet, Walter Mart	D	23-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. DILA</b>						
7	Phase 3E, Mabuhay Homes 2000	S	10-Jul	< 1	ABSENCE	ABSENCE
8	Block 2 Lot 10, Mabuhay Homes 2000	D	10-Jul	< 1	ABSENCE	ABSENCE
9	Block 12, Phase 2E, Mabuhay Homes 2000	S	10-Jul	< 1	ABSENCE	ABSENCE
10	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	D	10-Jul	< 1	ABSENCE	ABSENCE
11	Drinking Fountain, Dila Elementary School	D	10-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. DITA</b>						
12	Block 24 Lot 2, New Santa Rosa Homes	S	10-Jul	< 1	ABSENCE	ABSENCE
13	Block 19 Lot 11, New Santa Rosa Homes	D	10-Jul	1	ABSENCE	ABSENCE
14	Clubhouse, San Lorenzo Royale	D	17-Jul	< 1	ABSENCE	ABSENCE
15	Water Tank, SolCar Ville Subdivision	S	10-Jul	< 1	ABSENCE	ABSENCE
16	Block 3 Lot 7, SolCar Ville Subdivision	D	10-Jul	< 1	ABSENCE	ABSENCE
17	Clubhouse, Villa Esmeralda	D	17-Jul	< 1	ABSENCE	ABSENCE
18	#1780 National Road	D	10-Jul	< 1	ABSENCE	ABSENCE
19	R & B Ice Plant, Inc.	D	10-Jul	< 1	ABSENCE	ABSENCE
20	Science HighSchool, Phase 1, Laguna Bel-Air	D	15-Jul	< 1	ABSENCE	ABSENCE
21	56 Cypress, Laguna Bel-Air	D	15-Jul	< 1	ABSENCE	ABSENCE
22	Church, Block 108, Phase 5, Laguna Bel-Air	D	15-Jul	< 1	ABSENCE	ABSENCE
23	Block 47 Lot 12 Laguna Bel-Air IV	D	15-Jul	< 1	ABSENCE	ABSENCE
24	8001, Pump 1, Acacia St., Santa Rosa Village I	S	15-Jul	< 1	ABSENCE	ABSENCE
25	Clubhouse, Phase 4B, Santa Rosa Village I	D	15-Jul	< 1	ABSENCE	ABSENCE
26	Clubhouse, Santa Rosa Village II	D	15-Jul	4	ABSENCE	ABSENCE
27	Pump 9 & 10, Santa Rosa Estates I	S	15-Jul	< 1	ABSENCE	ABSENCE
28	Clubhouse Santa Rosa Estates I	D	15-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. DON JOSE</b>						
29	Drinking Fountain, Don Jose National High School	D	15-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. MACABLING</b>						
30	Deepwell, Buena Rosa 9 Subdivision	S	11-Jul	-	ABSENCE	ABSENCE
31	Block 4 Lot 26, Phase 2, Buena Rosa 9 Subdivision	D	11-Jul	-	ABSENCE	ABSENCE
32	Deepwell, Corinthian Subdivision	S	11-Jul	-	ABSENCE	ABSENCE
33	Block 11 Lot 19, Corinthian Subdivision	D	11-Jul	-	ABSENCE	ABSENCE
34	Water Pump, Metrogate	S	10-Jul	< 1	ABSENCE	ABSENCE
35	Clubhouse, Metrogate	D	10-Jul	< 1	ABSENCE	ABSENCE
<b>BRGY. MALITLIT</b>						
36	Clubhouse Casan Residencia Subdivision	D	10-Jul	< 1	ABSENCE	ABSENCE




37	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	S	17-Jul	< 1	ABSENCE	ABSENCE
38	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	D	17-Jul	13	ABSENCE	ABSENCE
39	Main Road, Phase 2, Terra Fortuna	S	17-Jul	1	ABSENCE	ABSENCE
40	Block 11 Lot 16, Terra Fortuna	D	17-Jul	< 1	ABSENCE	ABSENCE
41	9999 W, Villa Las Casas	S	17-Jul	< 1	ABSENCE	ABSENCE
42	Block 1 Lot 17, Villa Las Casas	D	17-Jul	< 1	ABSENCE	ABSENCE
43	Drinking Fountain, Malitlit Elementary School	D	10-Jul	2	ABSENCE	ABSENCE
44	Blowoff, Eton City	D	15-Jul	2	ABSENCE	ABSENCE
<b>BRGY. POOC</b>						
45	Deepwell, Alinsod	S	16-Jul	< 1	ABSENCE	ABSENCE
46	Tank, Villa Mercedes	S	16-Jul	< 1	PRESENCE	ABSENCE
47	Block 2 Lot 1, Villa Mercedes	D	16-Jul	< 1	ABSENCE	ABSENCE
48	Drinking Fountain 1, Pulong Sta. Cruz Elementary Sch.	D	17-Jul	10	ABSENCE	ABSENCE
49	Drinking Fountain 2, Pulong Sta. Cruz Elementary Sch.	D	17-Jul	< 1	ABSENCE	ABSENCE
50	Block 6 Lot 8, Buklod Diwa	D	17-Jul	3	ABSENCE	ABSENCE
<b>BRGY. SANTO DOMINGO</b>						
51	Clubhouse Santa Rosa Estates II	D	15-Jul	< 1	ABSENCE	ABSENCE
<b>TOTAL SAMPLES ANALYZED</b>		<b>51</b>	<b>PNSDW LIMIT</b>	<b>&lt;500</b>	<b>ABSENCE</b>	<b>ABSENCE</b>

**REMARKS:** Samples analyzed as submitted

LEGEND: HPC - Heterotrophic Plate Count, S - Source, D - Distribution

METHODS USED: <sup>1</sup>Pour Plate, <sup>2</sup>Enzyme Substrate (Colilert®-18)

**CERTIFIED CORRECT:**

  
**ANNA KARLA S. GUTIERREZ, RMT**  
 Microbiologist  
 PRC License No. 0060968

**NOTED BY:**

  
**CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>**  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2249 Date Prepared : 07/30/2019  
 Sample Code : S19-3397  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 10:31 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : WATER PUMP, PUROK 6, MORESCO VILLE 2, SABANG, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>16</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2250 Date Prepared : 07/30/2019  
 Sample Code : S19-3398  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 10:41 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : RESERVOIR, PUROK 6, MORESCO VILLE 2, SABANG, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2251 Date Prepared : 07/30/2019  
 Sample Code : S19-3399  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 10:35 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

**RESULTS OF LABORATORY ANALYSIS**


**SAMPLE LOCATION : DE DIOS RESIDENCE, BRGY. UNO, POBLACION 1, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2252 Date Prepared : 07/30/2019  
 Sample Code : S19-3400  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 13:17 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

**RESULTS OF LABORATORY ANALYSIS**


**SAMPLE LOCATION : MENDOZA RESIDENCE, BRGY. UNO, POBLACION 1, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2253 Date Prepared : 07/30/2019  
 Sample Code : S19-3401  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 14:03 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : PUMP STATION 5, BRGY. POBLACION 2, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	2	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2254 Date Prepared : 07/30/2019  
 Sample Code : S19-3402  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 15:53 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

**RESULTS OF LABORATORY ANALYSIS**


**SAMPLE LOCATION : BIG BOY EATERY, RIZAL STREET, BRGY. DOS, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: CFU – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Bifan (Poblacion), Bifan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2255 Date Prepared : 07/30/2019  
 Sample Code : S19-3403  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 14:18 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : DELOS REYES RESIDENCE, BRGY. DOS, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*



ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2256 Date Prepared : 07/30/2019  
 Sample Code : S19-3404  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 15:56 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : PUMP STATION #4, BRGY. UNO, POBLACION 1, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>8</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2257 Date Prepared : 07/30/2019

Sample Code : S19-3405

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 07/09/2019 11:13 Date/Time Submitted : 07/09/2019 18:55

Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.

Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate

Sample Source Characteristics : Source – Treated Water (w/ Chlorination)

References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : PUMP STATION #7, BRGY. PINAGSANJAN, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2258 Date Prepared : 07/30/2019  
 Sample Code : S19-3406  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 11:59 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : EMIL'S PANSITAN, BRGY. PINAGSANGAN, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>14</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2259 Date Prepared : 07/30/2019  
 Sample Code : S19-3407  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 11:42 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : PUMP STATION #2, BRGY. PINAGSANGAN, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2260 Date Prepared : 07/30/2019  
 Sample Code : S19-3408  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 11:32 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : MANALO RESIDENCE, BRGY. PINAGSANGAN, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2261 Date Prepared : 07/30/2019  
 Sample Code : S19-3409  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 12:20 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : #248 GEN LUNA STREET, BRGY. MAULAWIN, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>21</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2262 Date Prepared : 07/30/2019  
 Sample Code : S19-3410  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/09/2019 15:37 Date/Time Submitted : 07/09/2019 18:55  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : PAGWAD OFFICE, J.P RIZAL ST., BRGY. DOS, PAGSANJAN, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/09/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>1</b>	500 (max.)	9215B. Pour Plate Method	7/09/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2263 Date Prepared : 07/30/2019  
 Sample Code : S19-3483  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/15/2019 12:15 Date/Time Submitted : 07/15/2019 13:01  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : BLOCK 12 SAMAT ST., PHASE 1, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Heterotrophic Plate Count	CFU/mL	5	500 (max.)	9215B. Pour Plate Method	7/15/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*



**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2264 Date Prepared : 07/30/2019  
 Sample Code : S19-3484  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/15/2019 12:08 Date/Time Submitted : 07/15/2019 13:01  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

**RESULTS OF LABORATORY ANALYSIS**


**SAMPLE LOCATION : BLOCK 11 KANLAON ST., AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>6</b>	500 (max.)	9215B. Pour Plate Method	7/15/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0960968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2265 Date Prepared : 07/30/2019  
 Sample Code : S19-3485  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/15/2019 12:27 Date/Time Submitted : 07/15/2019 13:01  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

**RESULTS OF LABORATORY ANALYSIS**


**SAMPLE LOCATION : CLUBHOUSE, AYALA GREENFIELDS ESTATE, BRGY. PUTING LUPA, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>1</b>	500 (max.)	9215B. Pour Plate Method	7/15/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0960968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2266 Date Prepared : 07/30/2019  
 Sample Code : S19-3486  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/15/2019 10:47 Date/Time Submitted : 07/15/2019 13:01  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

**RESULTS OF LABORATORY ANALYSIS**


**SAMPLE LOCATION : WATER PUMP 1, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>&lt; 1</b>	500 (max.)	9215B. Pour Plate Method	7/15/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/30/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2267 Date Prepared : 07/30/2019  
 Sample Code : S19-3487  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/15/2019 11:46 Date/Time Submitted : 07/15/2019 13:01  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

### RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : BLOCK 1 LOT 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Heterotrophic Plate Count	CFU/mL	<b>13</b>	500 (max.)	9215B. Pour Plate Method	7/15/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2268 Date Prepared : 07/30/2019  
 Sample Code : S19-3488  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/15/2019 11:26 Date/Time Submitted : 07/15/2019 13:01  
 Collected By : Elmer P. Palmares, Jr. Submitted By : Elmer P. Palmares, Jr.  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : WATER PUMP 2, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Heterotrophic Plate Count	CFU/mL	< 1	500 (max.)	9215B. Pour Plate Method	7/15/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2269

Date Prepared : 07/30/2019

Sample Code : S19-3489

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 07/15/2019 10:58

Date/Time Submitted : 07/15/2019 13:01

Collected By : Elmer P. Palmares, Jr.

Submitted By : Elmer P. Palmares, Jr.

Condition of Sample Upon Receipt : 100 mL water sample in clear, glass, sterile container with 3% sodium thiosulfate

Sample Source Characteristics : Distribution – Network Sampling Point

References

: Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"

## RESULTS OF LABORATORY ANALYSIS


**SAMPLE LOCATION : BLOCK 39 LOT 5, AMAIA SCAPES CALAMBA, BRGY. BARANDAL, CALAMBA CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	ABSENCE	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/15/2019	JDE
Heterotrophic Plate Count	CFU/mL	3	500 (max.)	9215B. Pour Plate Method	7/15/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

Legend: **CFU** – Colony Forming Units

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 7/20/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2272 Date Prepared : 08/06/2019  
 Sample Code : S19-3856  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/29/2019 14:01 Date/Time Submitted : 07/30/2019 10:00  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


**RESULTS OF LABORATORY ANALYSIS**

**SAMPLE LOCATION : WATER PUMP, BELLA VITA SUBDIVISION, SAN BARTOLOME, SAN PABLO, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/16/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2273 Date Prepared : 08/06/2019  
 Sample Code : S19-3857  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/29/2019 14:11 Date/Time Submitted : 07/30/2019 10:00  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : CLUBHOUSE, BELLA VITA SUBDIVISION, SAN BARTOLOME, SAN PABLO, LAGUNA**


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*



**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2270 Date Prepared : 08/06/2019  
 Sample Code : S19-3854  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/29/2019 12:35 Date/Time Submitted : 07/30/2019 10:00  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : WATER TANK, BELLA VITA HOMES, SAN ANDRES, ALAMINOS, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/6/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2271 Date Prepared : 08/06/2019  
 Sample Code : S19-3855  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/29/2019 12:42 Date/Time Submitted : 07/30/2019 10:00  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : CLUBHOUSE, BELLA VITA HOMES, SAN ANDRES, ALAMINOS, LAGUNA**


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/6/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2274 Date Prepared : 08/06/2019  
 Sample Code : S19-3860  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/29/2019 15:04 Date/Time Submitted : 07/30/2019 10:00  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : WATER PUMP, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO, LAGUNA**


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICARMIT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/6/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2275 Date Prepared : 08/06/2019  
Sample Code : S19-3861  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 07/29/2019 15:13 Date/Time Submitted : 07/30/2019 10:00  
Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Distribution – Network Sampling Point  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : BLOCK 65 LOT 2, AMAIA SCAPES SUBDIVISION, BRGY. SAN LUCAS, SAN PABLO, LAGUNA**


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2278 Date Prepared : 08/06/2019  
 Sample Code : S19-3862  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/29/2019 17:32 Date/Time Submitted : 07/30/2019 10:00  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


**RESULTS OF LABORATORY ANALYSIS**

**SAMPLE LOCATION : SOURCE, AFTER DMI-65 FILTRATION, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>PRESENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0050968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/6/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2279 Date Prepared : 08/06/2019  
 Sample Code : S19-3863  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/29/2019 17:32 Date/Time Submitted : 07/30/2019 10:00  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : GRANDSTAND, LAGUNA SPORTS COMPLEX, BUBUKAL, STA. CRUZ, LAGUNA**


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/6/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2280 Date Prepared : 08/06/2019  
Sample Code : S19-3864  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 07/29/2019 17:32 Date/Time Submitted : 07/30/2019 10:00  
Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


## RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : WATER PUMP, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA  
PROVINCIAL CAPITOL, STA. CRUZ, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/4/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2281 Date Prepared : 08/06/2019  
Sample Code : S19-3865  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 07/29/2019 18:07 Date/Time Submitted : 07/30/2019 10:00  
Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Distribution – Network Sampling Point  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : OLD CAPITOL BUILDING, CAPITOL COMPOUND, P. GUEVARRA AVE., LAGUNA PROVINCIAL CAPITOL, STA. CRUZ, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*



**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2282 Date Prepared : 08/06/2019  
 Sample Code : S19-3866  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/29/2019 18:01 Date/Time Submitted : 07/30/2019 10:00  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


**RESULTS OF LABORATORY ANALYSIS**

**SAMPLE LOCATION : FAUCET, LAGUNA MEDICAL CENTER, STA. CRUZ, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/6/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2276 Date Prepared : 08/06/2019  
 Sample Code : S19-3858  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/29/2019 16:15 Date/Time Submitted : 07/30/2019 10:00  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Source – Treated Water (w/ Chlorination)  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


**RESULTS OF LABORATORY ANALYSIS**

**SAMPLE LOCATION : WATER PUMP, REBONG ST., BRGY. NANHAYA, VICTORIA, LAGUNA**


PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/6/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna  
**CONTACT NO.:** (049) 543-1916  
**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2277 Date Prepared : 08/06/2019  
Sample Code : S19-3859  
Name of Company / Customer : Laguna Water Corporation  
Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
Date/Time Collected : 07/29/2019 16:22 Date/Time Submitted : 07/30/2019 10:00  
Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
Sample Source Characteristics : Distribution – Network Sampling Point  
References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : 224 REBONG ST., BRGY. NANHAYA, VICTORIA, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE


Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2285 Date Prepared : 08/06/2019  
 Sample Code : S19-3633  
 Name of Company / Customer : Laguna Water Corporation  
 Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna  
 Date/Time Collected : 07/18/2019 12:11 Date/Time Submitted : 07/18/2019 15:45  
 Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig  
 Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate  
 Sample Source Characteristics : Distribution – Network Sampling Point  
 References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
 : DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : MESA INASAL, PAVILION MALL, NATIONAL ROAD, BRGY. SAN ANTONIO, BIÑAN CITY, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/18/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	07/18/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.


**CERTIFIED CORRECT BY:**

  
 ANNA KARLA S. GUTIERREZ, RMT  
 Microbiologist, Head  
 PRC License No. 0060968

**NOTED BY:**

  
 CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
 Laboratory Services Manager  
 License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*

**ADDRESS:** 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

**CONTACT NO.:** (049) 543-1916

**WEBSITE:** [www.lagunawater.com.ph](http://www.lagunawater.com.ph)

Test Report ID : TR-19-2283 Date Prepared : 08/06/2019

Sample Code : S19-3867

Name of Company / Customer : Laguna Water Corporation

Address : G/F, One Evotech Building, Nuvali, Brgy. Sto. Domingo, Sta. Rosa City, Laguna

Date/Time Collected : 07/29/2019 17:00 Date/Time Submitted : 07/30/2019 10:00

Collected By : Ohwen L. Catindig Submitted By : Ohwen L. Catindig

Condition of Sample Upon Receipt : 100 mL water sample in clear, polystyrene, sterile container with 3% sodium thiosulfate

Sample Source Characteristics : Source – Treated Water (w/ Chlorination)

References : Standard Methods for the Examination of Water and Wastewater, 23<sup>rd</sup> Edition  
: DOH AO 2017-0010 "Philippine National Standards for Drinking Water of 2017"


### RESULTS OF LABORATORY ANALYSIS

**SAMPLE LOCATION : WATER PUMP, BELLA VITA HOMES, PILA, LAGUNA**

PARAMETER(S)	UNIT(S)	RESULT(S)	PNSDW LIMIT(/S)	METHOD(S)	ANALYZED	
					DATE	BY
Total Coliform	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE
Thermotolerant Coliform / <i>Escherichia coli</i>	Coliforms/100 mL	<b>ABSENCE</b>	ABSENCE	9223B. Enzyme Substrate Test (Colilert-18®)	7/30/2019	JDE

Remarks: Samples analyzed as submitted. No deviations noted on sample collection and submission.

**CERTIFIED CORRECT BY:**

  
ANNA KARLA S. GUTIERREZ, RMT  
Microbiologist, Head  
PRC License No. 0060968

**NOTED BY:**

  
CYRIL A. ERICA, RMT, MLS(ASCP)<sup>CM</sup>  
Laboratory Services Manager  
License No(s). (PRC 0054161/ASCP 10981)

Test Report QC Checked By: 

Date of Test Report QC Check: 8/16/19

*This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis*